

Point List

Location: Carleton College / Myers Hall

Run Date: 10/10/2018 5:14:07 PM

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Active Zones	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Max Zones	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Runtime	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Time Satisfied Limit	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Total Percent	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Zone Occ Limit	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Environmental Index Occupancy Status	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Status	BBV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	EI_LOW	BALM			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Active Zones #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Active Zones #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Active Zones #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Active Zones #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Active Zones #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Active Zones #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Max Zones #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Max Zones #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Myer Hall Total Area Rollup	Max Zones #3	POLLTOT			
/Carleton College/Myers	Myer Hall Total Area Rollup	Max Zones #4	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Enviro mental Index						
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Myer Hall Total Area Rollup	Max Zones #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Myer Hall Total Area Rollup	Max Zones #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Myer Hall Total Area Rollup	Weighted EI #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Myer Hall Total Area Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Myer Hall Total Area Rollup	Weighted EI #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Myer Hall Total Area Rollup	Weighted EI #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Myer Hall Total Area Rollup	Weighted EI #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Myer Hall Total Area Rollup	Weighted EI #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Myer Hall Total Area Rollup	Weights #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Myer Hall Total Area Rollup	Weights #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro	Myer Hall Total Area Rollup	Weights #3	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
mental Index						
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Myer Hall Total Area Rollup	Weights #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Myer Hall Total Area Rollup	Weights #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Myer Hall Total Area Rollup	Weights #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	Active Zones	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	Max Zones	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	Runtime	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	Time Satisfied Limit	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	Total Percent	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	Total Weight	BAV			
/Carleton	Basement Area	Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/Enviro mental Index	Rollup					
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	Zone Occ Limit	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	Environmental Index Occupancy Status	BBV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	Status	BBV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	EI_LOW	BALM			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	Active Zones #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	Active Zones #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	Active Zones #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	Active Zones #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	Active Zones #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Basement Area Rollup	Active Zones #6	POLLTOT			
/Carleton College/Myers Hall/Facility	Basement Area Rollup	Max Zones #1	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Environmental Index						
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Basement Area Rollup	Max Zones #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Basement Area Rollup	Max Zones #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Basement Area Rollup	Max Zones #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Basement Area Rollup	Max Zones #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Basement Area Rollup	Max Zones #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weighted EI #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weighted EI #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weighted EI #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weighted EI #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weighted EI #6	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weights #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weights #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weights #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weights #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weights #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weights #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	1st Floor Rollup	Active Zones	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	1st Floor Rollup	EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	1st Floor Rollup	Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	1st Floor Rollup	Max Zones	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	1st Floor Rollup	Runtime	BAV			
/Carleton College/Myers	1st Floor Rollup	Time Satisfied Limit	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Enviro mental Index						
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Total Percent	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Zone Occ Limit	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Environmental Index Occupancy Status	BBV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Status	BBV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	EI_LOW	BALM			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Active Zones #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Active Zones #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Active Zones #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro	1st Floor Rollup	Active Zones #4	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
mental Index						
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Active Zones #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Active Zones #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Max Zones #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Max Zones #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Max Zones #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Max Zones #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Max Zones #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Max Zones #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Weighted EI #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	1st Floor Rollup	Weighted EI #3	POLLTOT			
/Carleton	1st Floor Rollup	Weighted EI #4	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/Environmental Index						
/Carleton College/Myers Hall/Facility Summary/Environmental Index	1st Floor Rollup	Weighted EI #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	1st Floor Rollup	Weighted EI #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	1st Floor Rollup	Weights #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	1st Floor Rollup	Weights #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	1st Floor Rollup	Weights #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	1st Floor Rollup	Weights #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	1st Floor Rollup	Weights #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	1st Floor Rollup	Weights #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Active Zones	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility	2nd Floor Area Rollup	Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Environmental Index						
/Carleton College/Myers Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Max Zones	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Runtime	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Time Satisfied Limit	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Total Percent	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Zone Occ Limit	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Environmental Index Occupancy Status	BBV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Status	BBV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	EI_LOW	BALM			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Active Zones #1	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Active Zones #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Active Zones #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Active Zones #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Active Zones #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Active Zones #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Max Zones #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Max Zones #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Max Zones #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Max Zones #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Max Zones #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Max Zones #6	POLLTOT			
/Carleton College/Myers	2nd Floor Area Rollup	Weighted EI #1	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Enviro mental Index						
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Weighted EI #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Weighted EI #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Weighted EI #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Weighted EI #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Weights #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Weights #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Weights #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Weights #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	2nd Floor Area Rollup	Weights #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro	2nd Floor Area Rollup	Weights #6	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
mental Index						
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Active Zones	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Max Zones	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Runtime	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Time Satisfied Limit	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Total Percent	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Zone Occ Limit	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Environmental Index Occupancy Status	BBV			
/Carleton	3rd Floor Area	Status	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/Environmental Index	Rollup					
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	EI_LOW	BALM			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Active Zones #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Active Zones #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Active Zones #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Active Zones #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Active Zones #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Active Zones #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Max Zones #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Max Zones #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Max Zones #3	POLLTOT			
/Carleton College/Myers Hall/Facility	3rd Floor Area Rollup	Max Zones #4	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Environmental Index						
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Max Zones #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Max Zones #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weighted EI #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weighted EI #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weighted EI #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weighted EI #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weighted EI #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weights #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weights #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weights #3	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	3rd Floor Area Rollup	Weights #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	3rd Floor Area Rollup	Weights #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	3rd Floor Area Rollup	Weights #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Active Zones	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Max Zones	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Runtime	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Time Satisfied Limit	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Total Percent	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Total Weight	BAV			
/Carleton College/Myers	4th Floor Area Rollup	Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Enviro mental Index						
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Zone Occ Limit	BAV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Environmental Index Occupancy Status	BBV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Status	BBV			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	EI_LOW	BALM			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Active Zones #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Active Zones #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Active Zones #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Active Zones #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Active Zones #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Active Zones #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro	4th Floor Area Rollup	Max Zones #1	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
mental Index						
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Max Zones #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Max Zones #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Max Zones #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Max Zones #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Max Zones #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Weighted EI #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Weighted EI #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Weighted EI #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Weighted EI #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	4th Floor Area Rollup	Weighted EI #6	POLLTOT			
/Carleton	4th Floor Area	Weights #1	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/Environmental Index	Rollup					
/Carleton College/Myers Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Weights #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Weights #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Weights #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Weights #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Weights #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Active Zones	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Max Zones	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Runtime	BAV			
/Carleton College/Myers Hall/Facility	Penthouse Area Rollup	Time Satisfied Limit	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Environmental Index						
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Total Percent	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Zone Occ Limit	BAV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Environmental Index Occupancy Status	BBV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Status	BBV			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	EI_LOW	BALM			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Active Zones #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Active Zones #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Active Zones #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Active Zones #4	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Penthouse Area Rollup	Active Zones #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Penthouse Area Rollup	Active Zones #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Penthouse Area Rollup	Max Zones #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Penthouse Area Rollup	Max Zones #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Penthouse Area Rollup	Max Zones #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Penthouse Area Rollup	Max Zones #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Penthouse Area Rollup	Max Zones #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Penthouse Area Rollup	Max Zones #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Penthouse Area Rollup	Weighted EI #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Penthouse Area Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Enviro mental Index	Penthouse Area Rollup	Weighted EI #3	POLLTOT			
/Carleton College/Myers	Penthouse Area Rollup	Weighted EI #4	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Environmental Index						
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Weighted EI #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Weighted EI #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Weights #1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Weights #2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Weights #3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Weights #4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Weights #5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Environmental Index	Penthouse Area Rollup	Weights #6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	Active Zone	BAV			
/Carleton	MYER-RAD1-	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/Basement	RM8					
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility	MYER-RAD1-RM8	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-RAD1-RM8	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	MYER-HX1/HWS.HWDP1	BAI	0	0:0	0-20 mA
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	MYER-HX1/HWS.HWDP2	BAI	0	0:0	0-20 mA
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	MYER-HX1/HWS.HWSP	BAI	0	0:3	Thermistor
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	HWP-1 Status	BBI	normal	0:1	Dry Contact
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	HWP-2 Status	BBI	normal	0:2	Dry Contact
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	MYER-HX1/HWS.BVM	BAO	0	0:3	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	MYER-HX1/HWS.HWS.HX-LPS-VLV1	BAO	0	0:4	Electrical 0-10 Volt

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	MYER-HX1/HWS.HWP1-SS	BBO	normal	0:6	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	MYER-HX1/HWS.HWP2-SS	BBO	normal	0:5	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	Runtime swap time	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	Heat Active	BBV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	MYER-HX1/HWS.SYS-EN	BBV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	MYER-HX1/HWS.HWP-ROT	BMSV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	HW Setpoint Switch	BMSV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	HI DIFFP	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	HI HTG HW Diff PRS	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	MYER-HX1/HWS.HWST-HL	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	HI RHT HW Diff PRS	BALM			
/Carleton College/Myers	MYER-HX1	MYER-HX1/HWS.HWP1-ALM	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Basement						
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	HWP-1 Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	HWP-1 Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	MYER-HX1/HWS.HWP2-ALM	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	HWP-2 Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	HWP-2 Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	LO DIFFP	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	LO HTG HW Diff PRS	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	MYER-HX1/HWS.HWRT-HL	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	LO RHT HW Diff PRS	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	Standby Pump Enabled alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	Differential Pressure across V-1	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Myers Hall/Facility Summary/Basem ent	MYER-HX1	HREQ1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Basem ent	MYER-HX1	HREQ2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Basem ent	MYER-HX1	HREQ3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Basem ent	MYER-HX1	HREQ4	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Basem ent	MYER-HX1	HREQ5	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Basem ent	MYER-HX1	HREQ6	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Basem ent	MYER-HX1	HREQ7	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Basem ent	MYER-HX1	HREQ8	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Basem ent	MYER-HX1	HREQ9	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Basem ent	MYER-HX1	HREQ10	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Basem ent	MYER-HX1	HREQ11	POLLTOT			
/Carleton	MYER-HX1	HREQ12	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/Basement						
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	MYER-HX1/HWS.OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	Bypass Valve Modulation PID	BPID			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	Bypass Valve Modulation PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	Bypass Valve Modulation PID / Input	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	Bypass Valve Modulation PID / PID out	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	Convertor Valve PID	BPID			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	Convertor Valve PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	Convertor Valve PID / Input	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-HX1	Convertor Valve PID / PID out	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -STEAM-METER	Steam Meter	BPTA		0:1	Counter Input
/Carleton College/Myers Hall/Facility	MYER-BUILDING -STEAM-METER	Instant Demand	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -STEAM-METER	Peak MTD	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -STEAM-METER	Peak Today	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -STEAM-METER	Peak YTD	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -STEAM-METER	Prev Day Peak Dmnd	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -STEAM-METER	Prev Day Usage	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -STEAM-METER	Prev Month Peak	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -STEAM-METER	Prev Month Usage	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -STEAM-METER	Prev Year Peak	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -STEAM-METER	Prev Year Usage	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -STEAM-METER	Usage MTD	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -STEAM-METER	Usage Today	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING-STEAM-METER	Usage YTD	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING-STEAM-METER	Use Every Minute	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING-STEAM-METER	Use Every Minute	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING-STEAM-METER	Use Every Minute	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING-STEAM-METER	IN_FAIL	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING-STEAM-METER	Daily Use Write	ANO2			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING-STEAM-METER	Monthly Use Write	ANO2			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING-STEAM-METER	Yearly Use Write	ANO2			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	MYER-DOMESTIC/HW.MYER-HWS-TANKTEMP	BAI	0	0:7	Thermistor
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	MYER-DOMESTIC/HW.MYER-HWS.HWST	BAI	0	0:8	Thermistor
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	MYER-DOMESTIC/HW.MYER-TANK TEMP	BAI	0	0:5	Thermistor
/Carleton College/Myers	MYER-DOMESTIC-HW	MYER-DOMESTIC/HW.MYER-HWR.HWRT	BAI	0	0:6	Thermistor

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Basement						
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	MYER-DOMESTIC/HW.MYER-HWS.HWP4-STAT	BBI	normal	0:3	Dry Contact
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	MYER-DOMESTIC/HW.MYER-HWS.HWP5-STAT	BBI	normal	0:4	Dry Contact
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	not used	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	MYER-DOMESTIC/HW.MYER-HWS.HWP4-SS	BBO	normal	0:6	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	MYER-DOMESTIC/HW.MYER-HWS.HWP5-SS	BBO	normal	0:5	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	Runtime	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	Manual Override Lock	BBV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	Manual Override State	BBV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	Pump Status	BBV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	Run	BBV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	MYER-DOMESTIC/HW.MYER-HWS.HWP-ROT	BMSV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	DHW Supply Temp Low	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	DHW Tank Temp High	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	MYER-DOMESTIC/HW.MYER-HWS.HWST-HL	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	MYER-DOMESTIC/HW.MYER-HWS.HWST-LL	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	MYER-DOMESTIC/HW.MYER-HWS.HWP1-ALM	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	P1_HAND	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	P1_RNTM	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	MYER-DOMESTIC/HW.MYER-HWS.HWP2-ALM	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	P2_HAND	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	P2_RNTM	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	MYER-DOMESTIC/HW.MYER-HWS.OAT	ANI			
/Carleton	MYER-	Convertor Valve PID	BPID			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/Basement	DOMESTIC-HW					
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	Convertor Valve PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	Convertor Valve PID / Input	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-DOMESTIC-HW	Convertor Valve PID / PID out	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	MYERS-METER-INPUT	BPTA		0:1	Dry Contact
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Energy Peak Synchronization	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Energy Use Synchronization	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Instant Demand	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Peak MTD	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Peak Today	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Peak YTD	BAV			
/Carleton College/Myers Hall/Facility	MYER-BUILDING -ELECTRIC-METER	Prev Day Peak Dmnd	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Prev Day Usage	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Prev Month Peak	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Prev Month Usage	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Prev Year Peak	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Prev Year Usage	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Usage MTD	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Usage Today	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Usage YTD	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Use Every Minute	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Use Every Minute	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Use Every Minute	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	IN_FAIL	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Daily Use Write	ANO2			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Energy Peak Synch	ANO2			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Energy Use Synch	ANO2			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Monthly Use Write	ANO2			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -ELECTRIC-METER	Yearly Use Write	ANO2			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU-METER	Energy Rate	BAI	0	0:0	1
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU-METER	Energy Total	BAI	0	0:0	1
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU-METER	HW Flow Meter	BAI	0	0:0	1
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU-METER	HW Loop Return Temp	BAI	0	0:0	1
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU-METER	HW Loop Supply Temp	BAI	0	0:0	1
/Carleton College/Myers	MYER-BUILDING -HW-BTU-	HW BTU/HR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Basement	METER					
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU- METER	Instant Demand	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU- METER	Peak MTD	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU- METER	Peak Today	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU- METER	Peak YTD	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU- METER	Prev Day Peak Dmnd	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU- METER	Prev Day Usage	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU- METER	Prev Month Peak	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU- METER	Prev Month Usage	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU- METER	Prev Year Peak	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU- METER	Prev Year Usage	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU- METER	Usage MTD	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU-METER	Usage Today	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU-METER	Usage YTD	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU-METER	Use Every Minute	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU-METER	Use Every Minute	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU-METER	Use Every Minute	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU-METER	HI HW Loop Return Temp Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU-METER	HI HW Loop Supply Temp Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU-METER	LO HW Loop Return Temp Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU-METER	LO HW Loop Supply Temp Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU-METER	Daily Use Write	ANO2			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-BUILDING -HW-BTU-METER	Monthly Use Write	ANO2			
/Carleton	MYER-BUILDING	Yearly Use Write	ANO2			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/Basement	-HW-BTU-METER					
/Carleton College/Myers Hall/Facility Summary/Basement	Dryer Fan	Dryer Fan Status	BBI	normal	0:6	Dry Contact
/Carleton College/Myers Hall/Facility Summary/Basement	Dryer Fan	Dryer Fan Control	BBO	normal	0:6	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/Basement	Dryer Fan	schedule	BBV			
/Carleton College/Myers Hall/Facility Summary/Basement	Dryer Fan	Dryer Fan Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	Dryer Fan	Dryer Fan Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	Dryer Fan	Dryer Fan Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	Dryer Fan	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/Basement	Misc Inputs	Automatic Transfer Switch Status	BBI	normal	0:9	Dry Contact
/Carleton College/Myers Hall/Facility Summary/Basement	Misc Inputs	Not Used	BBI	normal	0:0	Dry Contact
/Carleton College/Myers Hall/Facility Summary/Basement	Misc Inputs	Fire Alarm Status	BBI	normal	0:7	Dry Contact
/Carleton College/Myers Hall/Facility	Misc Inputs	Tunnel Door Status	BBI	reversed	0:5	Dry Contact

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Myers Hall/Facility Summary/Basement	Misc Inputs	not used	BBI	normal	0:0	Dry Contact
/Carleton College/Myers Hall/Facility Summary/Basement	Misc Inputs	not used	BBI	normal	0:0	Dry Contact
/Carleton College/Myers Hall/Facility Summary/Basement	Misc Inputs	Elevator Emergency Power	BBO	normal	0:5	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/Basement	Misc Inputs	Automatic Transfer Switch	BBV			
/Carleton College/Myers Hall/Facility Summary/Basement	Misc Inputs	Emergency Generator Run	BBV			
/Carleton College/Myers Hall/Facility Summary/Basement	Misc Inputs	Fire Alarm	BBV			
/Carleton College/Myers Hall/Facility Summary/Basement	Misc Inputs	Tunnel Door	BBV			
/Carleton College/Myers Hall/Facility Summary/Basement	Misc Inputs	Water Meter Low Alarm	BBV			
/Carleton College/Myers Hall/Facility Summary/Basement	Misc Inputs	Water Meter Low Alarm	BBV			
/Carleton College/Myers Hall/Facility Summary/Basement	Misc Inputs	FIRE ALARM	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	Misc Inputs	WATER METER HIGH ALARM	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/Basement	Misc Inputs	WATER METER LOW ALARM	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	High Flow	BPTA		0:2	Counter Input
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	Low Flow	BPTA		0:1	Counter Input
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	Instant Demand	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	Peak MTD	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	Peak Today	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	Peak YTD	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	Prev Day Peak Dmnd	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	Prev Day Usage	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	Prev Month Peak	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	Prev Month Usage	BAV			
/Carleton College/Myers	MYER-WATER_METER	Prev Year Peak	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Basement						
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	Prev Year Usage	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	Usage MTD	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	Usage Today	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	Usage YTD	BAV			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	IN_FAIL	BALM			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	Daily Use Write	ANO2			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	Monthly Use Write	ANO2			
/Carleton College/Myers Hall/Facility Summary/Basement	MYER-WATER_METER	Yearly Use Write	ANO2			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	Active Zone	BAV			
/Carleton	MYER-RAD2-	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/1st Floor	RM127					
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility	MYER-RAD2-RM127	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD2-RM127	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	RPCT	BAV			
/Carleton College/Myers	MYER-RAD3-RM128B	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD3-RM128B	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Discharge Temp	BAI	0	0:2	Universal Input
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Mixed Temp	BAI	0	0:3	Universal Input
/Carleton	MYER-FC-1,	OAT	BAI	0	0:4	Universal Input

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/1st Floor	RAD4-RM128C,128D					
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Zone Temp	ASVI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Fan Status	BBI	normal	0:1	Universal Input
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	OA/RA Damper	BAO	0	0:2	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	DX Enable	BBO	normal	0:3	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Fan Start/Stop	BBO	normal	0:4	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Heating Valve	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Heating Valve / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Heating Valve / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Econ Min Pos	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Economizer Setpoint	BAV			
/Carleton College/Myers Hall/Facility	MYER-FC-1, RAD4-RM128C,128D	Enabled Cool Stages	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Heating Run Request	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Heat Request	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Output Override	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Outside Air Temp	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Econ Enable Status	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Energy Saving Mode	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Occ Status	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Output Override Lock	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Override Off	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Override On	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Run	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	DAT_HI	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	DAT_LO	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	DX_RNTM	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	FAN_FAIL	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	FAN_HAND	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	FAN_RNTM	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	MIX_HI	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	MIX_LO	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	ZRH_HI	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	ZRH_LO	BALM			
/Carleton College/Myers	MYER-FC-1, RAD4-	ZS_COMM	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor	RM128C,128D					
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	ZST_FAIL	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	ZTMP_HI	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	ZTMP_LO	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Clg Dmd Level	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Htg Dmd Level	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	OA Temp	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-FC-1, RAD4-RM128C,128D	Setpt Adjust	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	EI Weighting	BAV			
/Carleton	MYER-RAD5-	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/1st Floor	RM130					
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility	MYER-RAD5-RM130	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD5-RM130	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	RUN REQ	BAV			
/Carleton College/Myers	MYER-RAD6-RM131	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD6-RM131	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st	MYER-RAD7-RM134	MYER-RAD2.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton	MYER-RAD7-	MYER-RAD2.RAD.HTG-VLV /	BFM		0:2	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/1st Floor	RM134	close				
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD7-RM134	Heating Plant Broadcast	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD7-RM134	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	Environmental Index Count	BAV			
/Carleton College/Myers	MYER-RAD8-RM136	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st	MYER-RAD8-RM136	MYER-RAD2.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD8-RM136	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton	MYER-RAD9-	MYER-RAD2.RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/1st Floor	RM104					
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD9-RM104	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD9-RM104	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers	MYER-RAD10-RM102W	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/1st	MYER-RAD10-RM102W	MYER-RAD2.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD10-RM102W	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton	MYER-RAD13-	MYER-RAD2.RMT-STP / Heating	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/1st Floor	RM102E	Setpoint Adjust				
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD13-RM102E	RPCT	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD13-RM102E	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers	MYER-RAD14-RM107	MYER-RAD2.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD14-RM107	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton	MYER-RAD15-	MYER-RAD2.RMT-STP / Cooling	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/1st Floor	RM108	Unoccupied Setpoint				
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	Active Zone	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD15-RM108	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD15-RM108	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers	MYER-RAD16-RM110	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16-RM110	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16- RM110	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16- RM110	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16- RM110	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16- RM110	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16- RM110	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16- RM110	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16- RM110	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16- RM110	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16- RM110	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16- RM110	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD16- RM110	OAT	ANI			
/Carleton	MYER-RAD17-	MYER-RAD2.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/1st Floor	RM115					
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility	MYER-RAD17-RM115	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD17-RM115	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18-RM115A	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18-RM115A	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18-RM115A	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18-RM115A	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers	MYER-RAD18-RM115A	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18-RM115A	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18-RM115A	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18-RM115A	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18-RM115A	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18-RM115A	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18-RM115A	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18-RM115A	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18-RM115A	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18-RM115A	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18-RM115A	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18-RM115A	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18- RM115A	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18- RM115A	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18- RM115A	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18- RM115A	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18- RM115A	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18- RM115A	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18- RM115A	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18- RM115A	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18- RM115A	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18- RM115A	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18- RM115A	LO Zone Alarm	BALM			
/Carleton	MYER-RAD18-	MYER-RAD2.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/1st Floor	RM115A					
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18-RM115A	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD18-RM115A	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD19-RM119	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD19-RM119	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers	MYER-RAD20-RM120	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	Heating Plant Broadcast	BBV			
/Carleton	MYER-RAD20-	MYER-RAD2.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/1st Floor	RM120					
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD20-RM120	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD21-RM121E	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	MYER-RAD2.MODE	ANI			
/Carleton College/Myers	MYER-RAD21-RM121E	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-RAD21-RM121E	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	MYER-CUH1.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	MYER-CUH1.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	MYER-CUH1.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	MYER-CUH1.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	MYER-CUH1.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	MYER-CUH1.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	MYER-CUH1.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	MYER-CUH1.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	MYER-CUH1.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st	MYER-CUH1-RM101N,101S	Disch Air Temp-1	BAI	0	0:3	Thermistor

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Disch Air Temp-2	BAI	0	0:4	Thermistor
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	MYER-CUH1.RMT-RMT	BAI	0	0:5	Thermistor
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Fan-1 Status	BBI	normal	0:1	Dry Contact
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Fan-2 Status	BBI	normal	0:2	Dry Contact
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	UH-1 Valve Mod	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	UH-2 Valve Mod	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Fan-1/2 Control	BBO	normal	0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	UH-1 Valve Mod	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	UH-1 Valve Mod / open	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	UH-1 Valve Mod / close	BFM		0:3	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	UH-2 Valve Mod	BFM			
/Carleton	MYER-CUH1-	UH-2 Valve Mod / open	BFM		0:4	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/1st Floor	RM101N,101S					
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	UH-2 Valve Mod / close	BFM		0:5	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility	MYER-CUH1-RM101N,101S	MYER-CUH1.OCCUPANCY	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Fan-1 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Fan-1 Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Fan-1 Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Fan-2 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Fan-2 Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Fan-2 Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	HI DAT-1 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	HI DAT-2 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	LO DAT-1 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	LO DAT-2 Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Heat Available	BNI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Unit Heater HW Valve PID	BPID			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Unit Heater HW Valve PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Unit Heater HW Valve PID / Input	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH1-RM101N,101S	Unit Heater HW Valve PID / PID out	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	MYER-CUH2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	MYER-CUH2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	MYER-CUH2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers	MYER-CUH2-RM102	MYER-CUH2.RMT-STP / Cooling Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	MYER-CUH2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	MYER-CUH2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	MYER-CUH2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	MYER-CUH2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	MYER-CUH2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Disch Air Temp	BAI	0	0:2	Thermistor
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	MYER-CUH2.RMT-RMT	BAI	0	0:3	Thermistor
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Fan-1 Status	BBI	normal	0:1	Dry Contact
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Unit Heater HW Valve	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Fan-1/2 Control	BBO	normal	0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st	MYER-CUH2-RM102	Unit Heater HW Valve	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Unit Heater HW Valve / open	BFM		0:3	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Unit Heater HW Valve / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Zone Weighted Environmental Index	BAV			
/Carleton	MYER-CUH2-	MYER-CUH2.OCCUPANCY	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/1st Floor	RM102					
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Fan-1 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Fan-1 Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Fan-1 Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	HI DAT Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	LO DAT Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Heat Available	BNI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	OAT	ANI			
/Carleton College/Myers Hall/Facility	MYER-CUH2-RM102	Unit Heater HW Valve PID	BPID			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Unit Heater HW Valve PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Unit Heater HW Valve PID / Input	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH2-RM102	Unit Heater HW Valve PID / PID out	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	MYER-CUH3.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	MYER-CUH3.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	MYER-CUH3.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	MYER-CUH3.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	MYER-CUH3.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	MYER-CUH3.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	MYER-CUH3.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	MYER-CUH3.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	MYER-CUH3.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Disch Air Temp-1	BAI	0	0:3	Thermistor
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Disch Air Temp-2	BAI	0	0:4	Thermistor
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	MYER-CUH3.RMT-RMT	BAI	0	0:5	Thermistor
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Fan-1 Status	BBI	normal	0:1	Dry Contact
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Fan-2 Status	BBI	normal	0:2	Dry Contact
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	UH-1 Valve Mod	BAO	0	0:3	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	UH-2 Valve Mod	BAO	0	0:2	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Fan-1/2 Control	BBO	normal	0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	UH-1 Valve Mod	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	UH-1 Valve Mod / open	BFM		0:0	Relay / Triac Output
/Carleton College/Myers	MYER-CUH3-RM118S	UH-1 Valve Mod / close	BFM		0:0	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	UH-2 Valve Mod	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	UH-2 Valve Mod / open	BFM		0:0	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	UH-2 Valve Mod / close	BFM		0:0	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	MYER-CUH3.OCCUPANCY	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Fan-1 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Fan-1 Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Fan-1 Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Fan-2 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Fan-2 Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Fan-2 Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	HI DAT-1 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	HI DAT-2 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	HI Zone Alarm	BALM			
/Carleton	MYER-CUH3-	LO DAT-1 Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/1st Floor	RM118S					
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	LO DAT-2 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Heat Available	BNI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Unit Heater HW Valve PID	BPID			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Unit Heater HW Valve PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Unit Heater HW Valve PID / Input	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH3-RM118S	Unit Heater HW Valve PID / PID out	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	MYER-CUH4.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility	MYER-CUH4-RM122	MYER-CUH4.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	MYER-CUH4.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	MYER-CUH4.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	MYER-CUH4.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	MYER-CUH4.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	MYER-CUH4.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	MYER-CUH4.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	MYER-CUH4.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Disch Air Temp	BAI	0	0:2	Thermistor
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	MYER-CUH4.RMT-RMT	BAI	0	0:3	Thermistor
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Fan-1 Status	BBI	normal	0:1	Dry Contact
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Unit Heater HW Valve	BAO	0	0:1	Electrical 0-10 Volt

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Fan Control	BBO	normal	0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Unit Heater HW Valve	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Unit Heater HW Valve / open	BFM		0:0	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Unit Heater HW Valve / close	BFM		0:0	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Zone EI Total Weight	BAV			
/Carleton College/Myers	MYER-CUH4-RM122	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	MYER-CUH4.OCCUPANCY	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Fan-1 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Fan-1 Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Fan-1 Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	HI DAT Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	LO DAT Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Heat Available	BNI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Unit Heater HW Valve PID	BPID			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Unit Heater HW Valve PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Unit Heater HW Valve PID / Input	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH4-RM122	Unit Heater HW Valve PID / PID out	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	MYER-CUH5.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	MYER-CUH5.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	MYER-CUH5.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	MYER-CUH5.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	MYER-CUH5.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	MYER-CUH5.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton	MYER-CUH5-	MYER-CUH5.RMT-STP / Heating	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/1st Floor	RM128A	Setpoint Adjust				
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	MYER-CUH5.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	MYER-CUH5.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Disch Air Temp	BAI	0	0:2	Thermistor
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	MYER-CUH5.RMT-RMT	BAI	0	0:3	Thermistor
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Fan-1 Status	BBI	normal	0:1	Dry Contact
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Unit Heater HW Valve	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Fan-1/2 Control	BBO	normal	0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Unit Heater HW Valve	BFM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Unit Heater HW Valve / open	BFM		0:0	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Unit Heater HW Valve / close	BFM		0:0	Relay / Triac Output
/Carleton College/Myers Hall/Facility	MYER-CUH5-RM128A	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	MYER-CUH5-RM1.OCCUPANCY	BBV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Fan-1 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Fan-1 Hand Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Fan-1 Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	HI DAT Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	LO DAT Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Heat Available	BNI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Unit Heater HW Valve PID	BPID			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Unit Heater HW Valve PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/1st Floor	MYER-CUH5-RM128A	Unit Heater HW Valve PID / Input	BAV			
/Carleton College/Myers	MYER-CUH5-RM128A	Unit Heater HW Valve PID / PID out	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd	MYER-RAD23-RM241	MYER-RAD2.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	Zone Environmental Index	BAV			
/Carleton	MYER-RAD23-	Zone Weighted Environmental	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/2nd Floor	RM241	Index				
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD23-RM241	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD24-RM240	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	HI Zone Alarm	BALM			
/Carleton College/Myers	MYER-RAD24-RM240	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD24-RM240	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd	MYER-RAD25-RM239	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	RUN REQ	BAV			
/Carleton	MYER-RAD25-	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/2nd Floor	RM239					
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD25-RM239	OAT	ANI			
/Carleton College/Myers Hall/Facility	MYER-RAD26-RM238	MYER-RAD2.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers	MYER-RAD26-RM238	Heating Plant Broadcast	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD26-RM238	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd	MYER-RAD27-RM237	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	Environmental Index Count	BAV			
/Carleton	MYER-RAD27-	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/2nd Floor	RM237					
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility	MYER-RAD27-RM237	MYER-RAD2.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD27-RM237	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	Zone EI Time Satisfied	BAV			
/Carleton College/Myers	MYER-RAD28-RM236	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD28-RM236	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd	MYER-RAD29-RM234	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton	MYER-RAD29-	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/2nd Floor	RM234					
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility	MYER-RAD29-RM234	MYER-RAD2.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD29-RM234	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	HEAT RUN FOR	BAV			
/Carleton College/Myers	MYER-RAD30-RM233	RPCT	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd	MYER-RAD30-RM233	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD30-RM233	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	MYER-RAD2.RMT	ASVI			
/Carleton	MYER-RAD31-	MYER-RAD2.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/2nd Floor	RM201					
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD31-RM201	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD31-RM201	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	Active Zone	BAV			
/Carleton College/Myers	MYER-RAD32-RM202	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32- RM202	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32- RM202	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32- RM202	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32- RM202	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32- RM202	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32- RM202	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32- RM202	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32- RM202	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32- RM202	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32- RM202	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd	MYER-RAD32- RM202	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD32-RM202	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton	MYER-RAD33-	MYER-RAD2.RMT-STP / Effective	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/2nd Floor	RM203	Cooling Setpoint				
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	RPCT	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD33-RM203	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD33-RM203	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers	MYER-RAD34-RM204	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd	MYER-RAD34-RM204	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD34-RM204	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton	MYER-RAD35-	MYER-RAD2.RMT-STP / Heating	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/2nd Floor	RM205	Unoccupied Setpoint				
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD35-RM205	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD35-RM205	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers	MYER-RAD36-RM206	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd	MYER-RAD36-RM206	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD36-RM206	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton	MYER-RAD37-	MYER-RAD2.RMT-STP / Cooling	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/2nd Floor	RM207	Occupied Setpoint				
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility	MYER-RAD37-RM207	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	Heating Plant Broadcast	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD37-RM207	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38-RM208	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38-RM208	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38-RM208	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38-RM208	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38-RM208	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers	MYER-RAD38-RM208	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38-RM208	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38-RM208	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38-RM208	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38-RM208	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38-RM208	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38-RM208	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38-RM208	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38-RM208	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38-RM208	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38-RM208	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd	MYER-RAD38-RM208	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38- RM208	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38- RM208	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38- RM208	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38- RM208	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38- RM208	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38- RM208	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38- RM208	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38- RM208	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38- RM208	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38- RM208	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38- RM208	MYER-RAD2.MODE	ANI			
/Carleton	MYER-RAD38-	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/2nd Floor	RM208					
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD38-RM208	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD39-RM209	MYER-RAD2.RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD39-RM209	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40-RM210	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40-RM210	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers	MYER-RAD40-RM210	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40-RM210	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40-RM210	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40-RM210	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40-RM210	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40-RM210	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40-RM210	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40-RM210	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40-RM210	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40-RM210	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40-RM210	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd	MYER-RAD40-RM210	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40- RM210	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40- RM210	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40- RM210	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40- RM210	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40- RM210	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40- RM210	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40- RM210	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40- RM210	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40- RM210	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40- RM210	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40- RM210	MYER-RAD2.OCC	BBV			
/Carleton	MYER-RAD40-	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/2nd Floor	RM210					
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40-RM210	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40-RM210	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40-RM210	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD40-RM210	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD41-RM211	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	RPCT	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD41-RM211	Demand	ANI			
/Carleton College/Myers	MYER-RAD41-RM211	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd	MYER-RAD42-RM213	MYER-RAD2.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	Zone Environmental Index	BAV			
/Carleton	MYER-RAD42-	Zone Weighted Environmental	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/2nd Floor	RM213	Index				
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD42-RM213	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD43-RM214	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	HI Zone Alarm	BALM			
/Carleton College/Myers	MYER-RAD43-RM214	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD43-RM214	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd	MYER-RAD44-RM246	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	RUN REQ	BAV			
/Carleton	MYER-RAD44-	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/2nd Floor	RM246					
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD44-RM246	OAT	ANI			
/Carleton College/Myers Hall/Facility	MYER-RAD45-RM245	MYER-RAD2.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers	MYER-RAD45-RM245	Heating Plant Broadcast	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD45-RM245	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd	MYER-RAD46-RM244	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	Environmental Index Count	BAV			
/Carleton	MYER-RAD46-	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/2nd Floor	RM244					
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility	MYER-RAD46-RM244	MYER-RAD2.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD46-RM244	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	Zone EI Time Satisfied	BAV			
/Carleton College/Myers	MYER-RAD47-RM243	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD47-RM243	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/2nd	MYER-RAD48-RM242	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton	MYER-RAD48-	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/2nd Floor	RM242					
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility	MYER-RAD48-RM242	MYER-RAD2.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/2nd Floor	MYER-RAD48-RM242	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	HEAT RUN FOR	BAV			
/Carleton College/Myers	MYER-RAD61-RM305	RPCT	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd	MYER-RAD61-RM305	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	MYER-RAD2.RMT	ASVI			
/Carleton	MYER-RAD50-	MYER-RAD2.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/3rd Floor	RM340					
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD50-RM340	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD50-RM340	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	Active Zone	BAV			
/Carleton College/Myers	MYER-RAD51-RM339	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd	MYER-RAD51-RM339	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD51-RM339	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton	MYER-RAD52-	MYER-RAD2.RMT-STP / Effective	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/3rd Floor	RM338	Cooling Setpoint				
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	RPCT	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD52-RM338	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD52-RM338	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers	MYER-RAD53-RM337	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd	MYER-RAD53-RM337	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD53-RM337	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton	MYER-RAD54-	MYER-RAD2.RMT-STP / Heating	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/3rd Floor	RM336	Unoccupied Setpoint				
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD54-RM336	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD54-RM336	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers	MYER-RAD55-RM334	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD55-RM334	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton	MYER-RAD56-	MYER-RAD2.RMT-STP / Cooling	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/3rd Floor	RM333	Occupied Setpoint				
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility	MYER-RAD56-RM333	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	Heating Plant Broadcast	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD56-RM333	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers	MYER-RAD57-RM301	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd	MYER-RAD57-RM301	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	MYER-RAD2.MODE	ANI			
/Carleton	MYER-RAD57-	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/3rd Floor	RM301					
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD57-RM301	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD58-RM302	MYER-RAD2.RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD58-RM302	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59-RM303	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59-RM303	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers	MYER-RAD59-RM303	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59-RM303	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59-RM303	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59-RM303	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59-RM303	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59-RM303	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59-RM303	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59-RM303	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59-RM303	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59-RM303	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59-RM303	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd	MYER-RAD59-RM303	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59- RM303	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59- RM303	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59- RM303	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59- RM303	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59- RM303	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59- RM303	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59- RM303	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59- RM303	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59- RM303	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59- RM303	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59- RM303	MYER-RAD2.OCC	BBV			
/Carleton	MYER-RAD59-	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/3rd Floor	RM303					
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59-RM303	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59-RM303	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59-RM303	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD59-RM303	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD60-RM304	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	RPCT	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD60-RM304	Demand	ANI			
/Carleton College/Myers	MYER-RAD60-RM304	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd	MYER-RAD61-RM305	MYER-RAD2.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	Zone Environmental Index	BAV			
/Carleton	MYER-RAD61-	Zone Weighted Environmental	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/3rd Floor	RM305	Index				
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD61-RM305	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD62-RM306	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	HI Zone Alarm	BALM			
/Carleton College/Myers	MYER-RAD62-RM306	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD62-RM306	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd	MYER-RAD63-RM307	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	RUN REQ	BAV			
/Carleton	MYER-RAD63-	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/3rd Floor	RM307					
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD63-RM307	OAT	ANI			
/Carleton College/Myers Hall/Facility	MYER-RAD64-RM308	MYER-RAD2.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers	MYER-RAD64-RM308	Heating Plant Broadcast	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD64-RM308	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd	MYER-RAD65-RM309	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:3	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	Environmental Index Count	BAV			
/Carleton	MYER-RAD65-	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/3rd Floor	RM309					
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility	MYER-RAD65-RM309	MYER-RAD2.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD65-RM309	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	Zone EI Time Satisfied	BAV			
/Carleton College/Myers	MYER-RAD66-RM310	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD66-RM310	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd	MYER-RAD67-RM311	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton	MYER-RAD67-	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/3rd Floor	RM311					
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility	MYER-RAD67-RM311	MYER-RAD2.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD67-RM311	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	HEAT RUN FOR	BAV			
/Carleton College/Myers	MYER-RAD68-RM313	RPCT	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd	MYER-RAD68-RM313	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD68-RM313	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	MYER-RAD2.RMT	ASVI			
/Carleton	MYER-RAD69-	MYER-RAD2.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/3rd Floor	RM314					
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD69-RM314	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD69-RM314	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	Active Zone	BAV			
/Carleton College/Myers	MYER-RAD70-RM346	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD70-RM346	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton	MYER-RAD71-	MYER-RAD2.RMT-STP / Effective	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/3rd Floor	RM345	Cooling Setpoint				
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	RPCT	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD71-RM345	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD71-RM345	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers	MYER-RAD72-RM344	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd	MYER-RAD72-RM344	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD72-RM344	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton	MYER-RAD73-	MYER-RAD2.RMT-STP / Heating	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/3rd Floor	RM343	Unoccupied Setpoint				
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD73-RM343	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD73-RM343	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers	MYER-RAD74-RM342	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/3rd Floor	MYER-RAD74-RM342	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton	MYER-RAD75-	MYER-RAD2.RMT-STP / Cooling	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	RM441	Occupied Setpoint				
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility	MYER-RAD75-RM441	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	Heating Plant Broadcast	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD75-RM441	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers	MYER-RAD76-RM440	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	MYER-RAD2.MODE	ANI			
/Carleton	MYER-RAD76-	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	RM440					
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD76-RM440	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD77-RM439	MYER-RAD2.RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD77-RM439	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78-RM438	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78-RM438	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers	MYER-RAD78-RM438	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78-RM438	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78-RM438	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78-RM438	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78-RM438	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78-RM438	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78-RM438	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78-RM438	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78-RM438	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78-RM438	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78-RM438	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th	MYER-RAD78-RM438	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78- RM438	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78- RM438	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78- RM438	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78- RM438	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78- RM438	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78- RM438	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78- RM438	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78- RM438	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78- RM438	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78- RM438	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78- RM438	MYER-RAD2.OCC	BBV			
/Carleton	MYER-RAD78-	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	RM438					
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78-RM438	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78-RM438	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78-RM438	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD78-RM438	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD79-RM437	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	RPCT	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD79-RM437	Demand	ANI			
/Carleton College/Myers	MYER-RAD79-RM437	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	MYER-RAD2.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	Zone Environmental Index	BAV			
/Carleton	MYER-RAD80-	Zone Weighted Environmental	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	RM436	Index				
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD80-RM436	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD81-RM434	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	HI Zone Alarm	BALM			
/Carleton College/Myers	MYER-RAD81-RM434	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD81-RM434	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th	MYER-RAD82-RM433	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	RUN REQ	BAV			
/Carleton	MYER-RAD82-	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	RM433					
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD82-RM433	OAT	ANI			
/Carleton College/Myers Hall/Facility	MYER-RAD83-RM401	MYER-RAD2.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers	MYER-RAD83-RM401	Heating Plant Broadcast	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD83-RM401	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	Environmental Index Count	BAV			
/Carleton	MYER-RAD84-	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	RM402					
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility	MYER-RAD84-RM402	MYER-RAD2.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD84-RM402	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	Zone EI Time Satisfied	BAV			
/Carleton College/Myers	MYER-RAD85-RM403	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD85-RM403	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th	MYER-RAD86-RM404	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton	MYER-RAD86-	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	RM404					
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility	MYER-RAD86-RM404	MYER-RAD2.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD86-RM404	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	HEAT RUN FOR	BAV			
/Carleton College/Myers	MYER-RAD87-RM405	RPCT	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD87-RM405	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	MYER-RAD2.RMT	ASVI			
/Carleton	MYER-RAD88-	MYER-RAD2.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	RM406					
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD88-RM406	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD88-RM406	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	Active Zone	BAV			
/Carleton College/Myers	MYER-RAD89-RM407	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th	MYER-RAD89-RM407	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD89-RM407	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton	MYER-RAD90-	MYER-RAD2.RMT-STP / Effective	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	RM408	Cooling Setpoint				
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	RPCT	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD90-RM408	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD90-RM408	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers	MYER-RAD91-RM409	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th	MYER-RAD91-RM409	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD91-RM409	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton	MYER-RAD92-	MYER-RAD2.RMT-STP / Heating	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	RM410	Unoccupied Setpoint				
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD92-RM410	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD92-RM410	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers	MYER-RAD93-RM411	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD93-RM411	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton	MYER-RAD94-	MYER-RAD2.RMT-STP / Cooling	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	RM413	Occupied Setpoint				
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility	MYER-RAD94-RM413	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	Heating Plant Broadcast	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD94-RM413	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers	MYER-RAD95-RM414	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	MYER-RAD2.MODE	ANI			
/Carleton	MYER-RAD95-	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	RM414					
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD95-RM414	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD96-RM446	MYER-RAD2.RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD96-RM446	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97-RM445	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97-RM445	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers	MYER-RAD97-RM445	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97-RM445	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97-RM445	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97-RM445	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97-RM445	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97-RM445	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97-RM445	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97-RM445	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97-RM445	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97-RM445	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97-RM445	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th	MYER-RAD97-RM445	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97- RM445	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97- RM445	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97- RM445	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97- RM445	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97- RM445	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97- RM445	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97- RM445	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97- RM445	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97- RM445	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97- RM445	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97- RM445	MYER-RAD2.OCC	BBV			
/Carleton	MYER-RAD97-	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	RM445					
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97-RM445	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97-RM445	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97-RM445	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD97-RM445	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD98-RM444	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	RPCT	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD98-RM444	Demand	ANI			
/Carleton College/Myers	MYER-RAD98-RM444	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	MYER-RAD2.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	Zone Environmental Index	BAV			
/Carleton	MYER-RAD99-	Zone Weighted Environmental	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	RM443	Index				
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD99-RM443	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	MYER-RAD2.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	MYER-RAD2.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	MYER-RAD2.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility	MYER-RAD100-RM442	MYER-RAD2.RMT-STP / Cooling Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	MYER-RAD2.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	MYER-RAD2.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	MYER-RAD2.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	MYER-RAD2.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	MYER-RAD2.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	MYER-RAD2.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	MYER-RAD2.RAD.HTG-VLV	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	MYER-RAD2.RAD.HTG-VLV / open	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	MYER-RAD2.RAD.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	RPCT	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	Heating Plant Broadcast	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	MYER-RAD2.OCC	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	HI Zone Alarm	BALM			
/Carleton College/Myers	MYER-RAD100-RM442	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	MYER-RAD2.MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-RAD100-RM442	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Setpoint	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Setpoint / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Setpoint / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Setpoint / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Setpoint / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Setpoint / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Setpoint / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th	MYER-CUH-C1-RM415	Setpoint / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Setpoint / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Disch Air Temp	BAI	0	0:0	Thermistor
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Zone Temp	BAI	0	0:2	Thermistor
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Fan-1 Status	BBI	normal	0:0	Dry Contact
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Unit Heater HW Valve	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Fan-1/2 Control	BBO	normal	0:0	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Unit Heater HW Valve	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Unit Heater HW Valve / open	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Unit Heater HW Valve / close	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	EI Weighting	BAV			
/Carleton	MYER-CUH-C1-	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	RM415					
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	schedule	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Fan-1 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Fan-1 Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Fan-1 Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility	MYER-CUH-C1-RM415	HI DAT Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	LO DAT Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Heat Available	BNI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Unit Heater HW Valve PID	BPID			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Unit Heater HW Valve PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Unit Heater HW Valve PID / Input	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C1-RM415	Unit Heater HW Valve PID / PID out	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Setpoint	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Setpoint / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Setpoint / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Setpoint / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Setpoint / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Setpoint / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Setpoint / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Setpoint / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Setpoint / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Disch Air Temp	BAI	0	0:0	Thermistor
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Zone Temp	BAI	0	0:2	Thermistor
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Fan-1 Status	BBI	normal	0:0	Dry Contact
/Carleton College/Myers	MYER-CUH-C2-RM419	Unit Heater HW Valve	BAO	0	0:0	Electrical 0-10 Volt

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Fan-1/2 Control	BBO	normal	0:0	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Unit Heater HW Valve	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Unit Heater HW Valve / open	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Unit Heater HW Valve / close	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2- RM419	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2- RM419	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2- RM419	schedule	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2- RM419	Fan-1 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2- RM419	Fan-1 Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2- RM419	Fan-1 Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2- RM419	HI DAT Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2- RM419	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2- RM419	LO DAT Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2- RM419	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2- RM419	Demand	ANI			
/Carleton	MYER-CUH-C2-	Heat Available	BNI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	RM419					
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Unit Heater HW Valve PID	BPID			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Unit Heater HW Valve PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Unit Heater HW Valve PID / Input	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C2-RM419	Unit Heater HW Valve PID / PID out	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Setpoint	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Setpoint / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Setpoint / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Setpoint / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Setpoint / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility	MYER-CUH-C3-RM421	Setpoint / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Setpoint / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Setpoint / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Setpoint / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Disch Air Temp	BAI	0	0:0	Thermistor
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Zone Temp	BAI	0	0:2	Thermistor
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Fan-1 Status	BBI	normal	0:0	Dry Contact
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Unit Heater HW Valve	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Fan-1/2 Control	BBO	normal	0:0	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Unit Heater HW Valve	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Unit Heater HW Valve / open	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Unit Heater HW Valve / close	BFM		0:1	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3- RM421	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3- RM421	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3- RM421	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3- RM421	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3- RM421	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3- RM421	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3- RM421	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3- RM421	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3- RM421	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3- RM421	schedule	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3- RM421	Fan-1 Alarm	BALM			
/Carleton College/Myers	MYER-CUH-C3- RM421	Fan-1 Hand Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Fan-1 Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	HI DAT Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	LO DAT Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Heat Available	BNI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Unit Heater HW Valve PID	BPID			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Unit Heater HW Valve PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Unit Heater HW Valve PID / Input	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM421	Unit Heater HW Valve PID / PID out	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Setpoint	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Setpoint / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Setpoint / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Setpoint / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Setpoint / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Setpoint / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Setpoint / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Setpoint / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Setpoint / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Disch Air Temp	BAI	0	0:0	Thermistor
/Carleton	MYER-CUH-C3-	Zone Temp	BAI	0	0:2	Thermistor

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	RM420					
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Fan-1 Status	BBI	normal	0:0	Dry Contact
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Unit Heater HW Valve	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Fan-1/2 Control	BBO	normal	0:0	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Unit Heater HW Valve	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Unit Heater HW Valve / open	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Unit Heater HW Valve / close	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility	MYER-CUH-C3-RM420	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	schedule	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Fan-1 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Fan-1 Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Fan-1 Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	HI DAT Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	LO DAT Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Heat Available	BNI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Unit Heater HW Valve PID	BPID			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Unit Heater HW Valve PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Unit Heater HW Valve PID / Input	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C3-RM420	Unit Heater HW Valve PID / PID out	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Setpoint	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Setpoint / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Setpoint / Heating Occupied Setpoint	BAV			
/Carleton College/Myers	MYER-CUH-C4-STAIRS415	Setpoint / Cooling Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Setpoint / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Setpoint / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Setpoint / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Setpoint / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Setpoint / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Disch Air Temp	BAI	0	0:0	Thermistor
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Zone Temp	BAI	0	0:2	Thermistor
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Fan-1 Status	BBI	normal	0:0	Dry Contact
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Unit Heater HW Valve	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Fan-1/2 Control	BBO	normal	0:0	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th	MYER-CUH-C4-STAIRS415	Unit Heater HW Valve	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Unit Heater HW Valve / open	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Unit Heater HW Valve / close	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Zone Weighted Environmental Index	BAV			
/Carleton	MYER-CUH-C4-	schedule	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/4th Floor	STAIRS415					
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Fan-1 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Fan-1 Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Fan-1 Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	HI DAT Shutdown	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	LO DAT Shutdown	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Heat Available	BNI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	OAT	ANI			
/Carleton College/Myers Hall/Facility	MYER-CUH-C4-STAIRS415	Unit Heater HW Valve PID	BPID			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Unit Heater HW Valve PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Unit Heater HW Valve PID / Input	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS415	Unit Heater HW Valve PID / PID out	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Setpoint	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Setpoint / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Setpoint / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Setpoint / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Setpoint / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Setpoint / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Setpoint / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Setpoint / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Setpoint / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Disch Air Temp	BAI	0	0:0	Thermistor
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Zone Temp	BAI	0	0:2	Thermistor
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Fan-1 Status	BBI	normal	0:0	Dry Contact
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Unit Heater HW Valve	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Fan-1/2 Control	BBO	normal	0:0	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Unit Heater HW Valve	BFM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Unit Heater HW Valve / open	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Unit Heater HW Valve / close	BFM		0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	EI Weighting	BAV			
/Carleton College/Myers	MYER-CUH-C4-STAIRS424	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	schedule	BBV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Fan-1 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Fan-1 Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Fan-1 Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	HI DAT Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	LO DAT Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Heat Available	BNI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Unit Heater HW Valve PID	BPID			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Unit Heater HW Valve PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Unit Heater HW Valve PID / Input	BAV			
/Carleton College/Myers Hall/Facility Summary/4th Floor	MYER-CUH-C4-STAIRS424	Unit Heater HW Valve PID / PID out	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-MAU-HV2	MYER-MUA-HV2.FILT-STAT	BAI	0	0:5	0-20 mA
/Carleton	MYER-MAU-HV2	MYER-MUA-HV2.DAT1	BAI	0	0:2	Thermistor

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/Penthouse use						
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-MAU-HV2	HW Loop Diff PRS	BAI	0	0:15	0-20 mA
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-MAU-HV2	HW Loop Return Temp	BAI	0	0:8	Thermistor
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-MAU-HV2	OA Damper feedback	BAI	0	0:6	0-10 Volt
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-MAU-HV2	Duct Smoke Alarm	BBI	normal	0:4	Dry Contact
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-MAU-HV2	Exhaust Fan Status	BBI	normal	0:14	Dry Contact
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-MAU-HV2	Heating Coil Circulation Pump Status	BBI	normal	0:7	Dry Contact
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-MAU-HV2	MYER-MUA-HV2.FRZ	BBI	normal	0:3	Dry Contact
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-MAU-HV2	MYER-MUA-HV2.SF1-STAT	BBI	normal	0:1	Dry Contact
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-MAU-HV2	MYER-MUA-HV2.HTG-VLV1	BAO	0	0:5	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-MAU-HV2	OA damper Open/Close	BAO	0	0:6	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility	MYER-MAU-HV2	Exhaust Fan Control	BBO	normal	0:3	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Pentho use						
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	Heating Coil Circulation Pump Control	BBO	normal	0:5	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	MAU Exhaust Damper	BBO	normal	0:4	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	MYER-MUA-HV2.SF1-SS	BBO	normal	0:6	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	AHU MODE	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	COOLING RUNFOR TIME	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	HEATING RUNFOR TIME	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	HWDIFF	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	COOLING REQUEST	BBV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	HEATING REQUEST	BBV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	Circulation Pump Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	Circulation Pump Hand Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-MAU-HV2	Circulation Pump Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-MAU-HV2	MYER-MUA-HV2.FILT-STAT	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-MAU-HV2	MYER-MUA-HV2.RA-SMK	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-MAU-HV2	Exhaust Fan Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-MAU-HV2	Exhaust Fan Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-MAU-HV2	Exhaust Fan Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-MAU-HV2	HI DAT ALARM	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-MAU-HV2	HI DAT Shutdown	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-MAU-HV2	HI HW Loop Return Temp Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-MAU-HV2	LO DAT ALARM	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-MAU-HV2	LO DAT Shutdown	BALM			
/Carleton College/Myers	MYER-MAU-HV2	LO HW Loop Return Temp Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Pentho use						
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	Low Temp Status Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	Low Temp Stat Warning	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	OA DAMPER ALARM	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	OA DAMPER HAND ALARM	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	Supply Fan Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	Supply Fan Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	Supply Fan Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	CLREQUESTS1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	CLREQUESTS2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	CLREQUESTS3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Pentho	MYER-MAU-HV2	Cool Available	BNI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
use						
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	Heat Available	BNI			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	HTREQUESTS1	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	HTREQUESTS2	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	HTREQUESTS3	POLLTOT			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	MYER-MUA-HV2.OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	RUNFORTIME1	POLLMAX			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	RUNFORTIME2	POLLMAX			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	RUNFORTIME3	POLLMAX			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	Heating Valve PID Loop	BPID			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	Heating Valve PID Loop / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-MAU-HV2	Heating Valve PID Loop / Input	BAV			
/Carleton	MYER-MAU-HV2	Heating Valve PID Loop / PID out	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/Penthouse use						
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-UH-1	MYER-UH1PENT.RMT-STP	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-UH-1	MYER-UH1PENT.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-UH-1	MYER-UH1PENT.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-UH-1	MYER-UH1PENT.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-UH-1	MYER-UH1PENT.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-UH-1	MYER-UH1PENT.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-UH-1	MYER-UH1PENT.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-UH-1	MYER-UH1PENT.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-UH-1	MYER-UH1PENT.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-UH-1	Not Used	BAI	0	0:0	Thermistor
/Carleton College/Myers Hall/Facility	MYER-UH-1	Zone Temp	BAI	0	0:2	Thermistor

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Penthouse						
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	Fan-1 Status	BBI	normal	0:1	Dry Contact
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	Not Used	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	Fan-1/2 Control	BBO	normal	0:1	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	Unit Heater HW Valve	BFM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	Unit Heater HW Valve / open	BFM		0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	Unit Heater HW Valve / close	BFM		0:3	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	Zone Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	MYER-UH1PENT.FAN-MODE	BBV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	Fan-1 Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	Fan-1 Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	Fan-1 Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	HI DAT Shutdown	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-UH-1	LO DAT Shutdown	BALM			
/Carleton College/Myers	MYER-UH-1	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Pentho use						
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-UH-1	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-UH-1	Heat Available	BNI			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-UH-1	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-UH-1	Unit Heater HW Valve PID	BPID			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-UH-1	Unit Heater HW Valve PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-UH-1	Unit Heater HW Valve PID / Input	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-UH-1	Unit Heater HW Valve PID / PID out	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RMKITCHEN	Setpoint	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RMKITCHEN	Setpoint / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RMKITCHEN	Setpoint / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho	MYER-RC- RMKITCHEN	Setpoint / Cooling Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
use						
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RMKITCHEN	Setpoint / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RMKITCHEN	Setpoint / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RMKITCHEN	Setpoint / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RMKITCHEN	Setpoint / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RMKITCHEN	Setpoint / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RMKITCHEN	MYER-RC-RMKITCHEN.DAT	BAI	0	0:9	Thermistor
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RMKITCHEN	MYER-RC-RMKITCHEN.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RMKITCHEN	MYER-RC-RMKITCHEN.HTG-VLV	BAO	0	0:4	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RMKITCHEN	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RMKITCHEN	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RMKITCHEN	schedule	BBV			
/Carleton	MYER-RC-	HI_DAT	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/Pentho use	RMKITCHEN					
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RMKITCHEN	LO_DAT	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RMKITCHEN	AHU MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RMKITCHEN	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RMKITCHEN	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RMKITCHEN	BACnet PID	BPID			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RMKITCHEN	BACnet PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RMKITCHEN	BACnet PID / Input	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RMKITCHEN	BACnet PID / PID out	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM422	Setpoint	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM422	Setpoint / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility	MYER-RC- RM422	Setpoint / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Pentho use						
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM422	Setpoint / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM422	Setpoint / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM422	Setpoint / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM422	Setpoint / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM422	Setpoint / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM422	Setpoint / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM422	MYER-RC-RM422.DAT	BAI	0	0:10	Thermistor
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM422	MYER-RC-RM422.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM422	MYER-RC-RM422.HTG-VLV	BAO	0	0:3	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM422	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM422	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RM422	schedule	BBV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RM422	HI_DAT	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RM422	LO_DAT	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RM422	AHU MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RM422	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RM422	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RM422	BACnet PID	BPID			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RM422	BACnet PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RM422	BACnet PID / Input	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RM422	BACnet PID / PID out	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-RC-RM4TH-HALL	Setpoint	BSPTCS			
/Carleton College/Myers	MYER-RC-RM4TH-HALL	Setpoint / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Pentho use						
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	Setpoint / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	Setpoint / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	Setpoint / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	Setpoint / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	Setpoint / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	Setpoint / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	Setpoint / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	MYER-RC-4TH-HALL.DAT	BAI	0	0:11	Thermistor
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	MYER-RC-RM4TH-HALL.RMT	ASVI			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	MYER-RC-RM4TH-HALL.HTG- VLV	BAO	0	0:2	Electrical 0-10 Volt
/Carleton College/Myers Hall/Facility Summary/Pentho	MYER-RC- RM4TH-HALL	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
use						
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	schedule	BBV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	HI_DAT	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	LO_DAT	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	AHU MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	BACnet PID	BPID			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	BACnet PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	BACnet PID / Input	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC- RM4TH-HALL	BACnet PID / PID out	BAV			
/Carleton	MYER-RC-	Setpoint	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/Penthouse use	RM3RD-HALL					
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-RC-RM3RD-HALL	Setpoint / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-RC-RM3RD-HALL	Setpoint / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-RC-RM3RD-HALL	Setpoint / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-RC-RM3RD-HALL	Setpoint / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-RC-RM3RD-HALL	Setpoint / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-RC-RM3RD-HALL	Setpoint / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-RC-RM3RD-HALL	Setpoint / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-RC-RM3RD-HALL	Setpoint / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-RC-RM3RD-HALL	MYER-RC-3RD-HALL.DAT	BAI	0	0:12	Thermistor
/Carleton College/Myers Hall/Facility Summary/Penthouse use	MYER-RC-RM3RD-HALL	MYER-RC-RM3RD-HALL.RMT	ASVI			
/Carleton College/Myers Hall/Facility	MYER-RC-RM3RD-HALL	MYER-RC-RM3RD-HALL.HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Pentho use						
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM3RD-HALL	HEAT RUN FOR	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM3RD-HALL	RUN REQ	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM3RD-HALL	schedule	BBV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM3RD-HALL	HI_DAT	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM3RD-HALL	LO_DAT	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM3RD-HALL	AHU MODE	ANI			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM3RD-HALL	Demand	ANI			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM3RD-HALL	OAT	ANI			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM3RD-HALL	BACnet PID	BPID			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM3RD-HALL	BACnet PID / Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM3RD-HALL	BACnet PID / Input	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-RC-RM3RD-HALL	BACnet PID / PID out	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMCUST	Setpoint	BSPTCS			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMCUST	Setpoint / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMCUST	Setpoint / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMCUST	Setpoint / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMCUST	Setpoint / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMCUST	Setpoint / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMCUST	Setpoint / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMCUST	Setpoint / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMCUST	Setpoint / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMCUST	Not Used	BAI	0	0:0	0-20 mA
/Carleton College/Myers	MYER-EXFN-RMCUST	Not Used	BAI	0	0:0	Thermistor

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Penthouse						
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN- RMCUST	Exhaust Fan Status	BBI	normal	0:16	Dry Contact
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN- RMCUST	Not Used	BBI	normal	0:0	1
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN- RMCUST	Not Used	BBI	normal	0:0	1
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN- RMCUST	Not Used	BTLO		0:0	Binary Input
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN- RMCUST	Exhaust Fan Control	BBO	normal	0:2	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN- RMCUST	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN- RMCUST	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN- RMCUST	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN- RMCUST	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN- RMCUST	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN- RMCUST	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
use						
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMCUST	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMCUST	EF STATUS	BBV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMCUST	Schedule	BBV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMCUST	Exhaust Fan System Configuration	BMSV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMCUST	EF Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMCUST	EF Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMCUST	EF Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMCUST	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMCUST	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMCUST	AHU ON	BNI			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMCUST	OAT	ANI			
/Carleton	MYER-EXFN-	Setpoint	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Myers Hall/Facility Summary/Pentho use	RMBATH					
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMBATH	Setpoint / Cooling Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMBATH	Setpoint / Heating Occupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMBATH	Setpoint / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMBATH	Setpoint / Heating Unoccupied Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMBATH	Setpoint / Cooling Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMBATH	Setpoint / Heating Setpoint Adjust	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMBATH	Setpoint / Effective Cooling Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMBATH	Setpoint / Effective Heating Setpoint	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMBATH	Exhaust Fan Status	BAI	0	0:0	9
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN- RMBATH	Zone Temp	BAI	0	0:0	Thermistor
/Carleton College/Myers Hall/Facility	MYER-EXFN- RMBATH	Exhaust Fan Status	BBI	normal	0:1	Dry Contact

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Pentho use						
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMBATH	Occupancy Sensor 1	BBI	normal	0:0	1
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMBATH	Occupancy Sensor 2	BBI	normal	0:0	1
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMBATH	Local Switch	BTLO		0:0	Binary Input
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMBATH	Exhaust Damper Control	BBO	normal	0:4	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMBATH	Exhaust Fan Control	BBO	normal	0:5	Relay / Triac Output
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMBATH	Active Zone	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMBATH	EI Weighting	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMBATH	Environmental Index Count	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMBATH	Zone EI Time Satisfied	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMBATH	Zone EI Total Weight	BAV			
/Carleton College/Myers Hall/Facility Summary/Pentho use	MYER-EXFN-RMBATH	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN-RMBATH	Zone Weighted Environmental Index	BAV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN-RMBATH	EF STATUS	BBV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN-RMBATH	Schedule	BBV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN-RMBATH	Exhaust Fan System Configuration	BMSV			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN-RMBATH	EF Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN-RMBATH	EF Hand Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN-RMBATH	EF Runtime Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN-RMBATH	HI Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN-RMBATH	LO Zone Alarm	BALM			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN-RMBATH	AHU ON	BNI			
/Carleton College/Myers Hall/Facility Summary/Penthouse	MYER-EXFN-RMBATH	OAT	ANI			