

Point List

Location: Carleton College / Musser Hall

Run Date: 10/10/2018 5:10:36 PM

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Hall Total Area Rollup	Active Zones	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Hall Total Area Rollup	EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Hall Total Area Rollup	Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Hall Total Area Rollup	Max Zones	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Hall Total Area Rollup	Runtime	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Hall Total Area Rollup	Time Satisfied Limit	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Hall Total Area Rollup	Total Percent	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Hall Total Area Rollup	Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Hall Total Area Rollup	Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Hall Total Area Rollup	Zone Occ Limit	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Hall Total Area Rollup	Environmental Index Occupancy Status	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Musser HallI Total Area Rollup	Status	BBV			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Musser HallI Total Area Rollup	EI_LOW	BALM			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Musser HallI Total Area Rollup	Active Zones #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Musser HallI Total Area Rollup	Active Zones #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Musser HallI Total Area Rollup	Active Zones #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Musser HallI Total Area Rollup	Active Zones #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Musser HallI Total Area Rollup	Active Zones #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Musser HallI Total Area Rollup	Active Zones #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Musser HallI Total Area Rollup	Max Zones #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Musser HallI Total Area Rollup	Max Zones #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Musser HallI Total Area Rollup	Max Zones #3	POLLTOT			
/Carleton College/Musser	Musser HallI Total Area Rollup	Max Zones #4	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Environmental Index						
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Halll Total Area Rollup	Max Zones #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Halll Total Area Rollup	Max Zones #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Halll Total Area Rollup	Weighted EI #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Halll Total Area Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Halll Total Area Rollup	Weighted EI #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Halll Total Area Rollup	Weighted EI #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Halll Total Area Rollup	Weighted EI #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Halll Total Area Rollup	Weighted EI #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Halll Total Area Rollup	Weights #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Halll Total Area Rollup	Weights #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Halll Total Area Rollup	Weights #3	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
mental Index						
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Hall Total Area Rollup	Weights #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Hall Total Area Rollup	Weights #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Musser Hall Total Area Rollup	Weights #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Active Zones	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Max Zones	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Runtime	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Time Satisfied Limit	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Total Percent	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Total Weight	BAV			
/Carleton	Basement Area	Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/Environmental Index	Rollup					
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Zone Occ Limit	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Environmental Index Occupancy Status	BBV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Status	BBV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	EI_LOW	BALM			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Active Zones #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Active Zones #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Active Zones #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Active Zones #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Active Zones #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Active Zones #6	POLLTOT			
/Carleton College/Musser Hall/Facility	Basement Area Rollup	Max Zones #1	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Environmental Index						
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Max Zones #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Max Zones #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Max Zones #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Max Zones #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Max Zones #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weighted EI #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weighted EI #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weighted EI #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weighted EI #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weighted EI #6	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weights #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weights #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weights #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weights #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weights #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Basement Area Rollup	Weights #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Active Zones	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Max Zones	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Runtime	BAV			
/Carleton College/Musser	1st Floor Rollup	Time Satisfied Limit	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Environmental Index						
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Total Percent	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Zone Occ Limit	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Environmental Index Occupancy Status	BBV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Status	BBV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	EI_LOW	BALM			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Active Zones #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Active Zones #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Active Zones #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Active Zones #4	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
mental Index						
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	1st Floor Rollup	Active Zones #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	1st Floor Rollup	Active Zones #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	1st Floor Rollup	Max Zones #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	1st Floor Rollup	Max Zones #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	1st Floor Rollup	Max Zones #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	1st Floor Rollup	Max Zones #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	1st Floor Rollup	Max Zones #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	1st Floor Rollup	Max Zones #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	1st Floor Rollup	Weighted EI #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	1st Floor Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	1st Floor Rollup	Weighted EI #3	POLLTOT			
/Carleton	1st Floor Rollup	Weighted EI #4	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/Environmental Index						
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Weighted EI #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Weighted EI #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Weights #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Weights #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Weights #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Weights #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Weights #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	1st Floor Rollup	Weights #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Active Zones	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility	2nd Floor Area Rollup	Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Environmental Index						
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Max Zones	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Runtime	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Time Satisfied Limit	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Total Percent	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Zone Occ Limit	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Environmental Index Occupancy Status	BBV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Status	BBV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	EI_LOW	BALM			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Active Zones #1	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	2nd Floor Area Rollup	Active Zones #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	2nd Floor Area Rollup	Active Zones #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	2nd Floor Area Rollup	Active Zones #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	2nd Floor Area Rollup	Active Zones #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	2nd Floor Area Rollup	Active Zones #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	2nd Floor Area Rollup	Max Zones #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	2nd Floor Area Rollup	Max Zones #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	2nd Floor Area Rollup	Max Zones #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	2nd Floor Area Rollup	Max Zones #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	2nd Floor Area Rollup	Max Zones #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	2nd Floor Area Rollup	Max Zones #6	POLLTOT			
/Carleton College/Musser	2nd Floor Area Rollup	Weighted EI #1	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Environmental Index						
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Weighted EI #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Weighted EI #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Weighted EI #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Weighted EI #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Weights #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Weights #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Weights #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Weights #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	2nd Floor Area Rollup	Weights #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental	2nd Floor Area Rollup	Weights #6	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
mental Index						
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Active Zones	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Max Zones	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Runtime	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Time Satisfied Limit	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Total Percent	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Zone Occ Limit	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Environmental Index Occupancy Status	BBV			
/Carleton	3rd Floor Area	Status	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/Environmental Index	Rollup					
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	EI_LOW	BALM			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Active Zones #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Active Zones #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Active Zones #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Active Zones #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Active Zones #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Active Zones #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Max Zones #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Max Zones #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Max Zones #3	POLLTOT			
/Carleton College/Musser Hall/Facility	3rd Floor Area Rollup	Max Zones #4	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Environmental Index						
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Max Zones #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Max Zones #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weighted EI #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weighted EI #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weighted EI #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weighted EI #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weighted EI #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weights #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weights #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weights #3	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weights #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weights #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	3rd Floor Area Rollup	Weights #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Active Zones	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Max Zones	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Runtime	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Time Satisfied Limit	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Total Percent	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Total Weight	BAV			
/Carleton College/Musser	4th Floor Area Rollup	Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Environmental Index						
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Zone Occ Limit	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Environmental Index Occupancy Status	BBV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Status	BBV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	EI_LOW	BALM			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Active Zones #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Active Zones #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Active Zones #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Active Zones #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Active Zones #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Active Zones #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental	4th Floor Area Rollup	Max Zones #1	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
mental Index						
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	4th Floor Area Rollup	Max Zones #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	4th Floor Area Rollup	Max Zones #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	4th Floor Area Rollup	Max Zones #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	4th Floor Area Rollup	Max Zones #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	4th Floor Area Rollup	Max Zones #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	4th Floor Area Rollup	Weighted EI #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	4th Floor Area Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	4th Floor Area Rollup	Weighted EI #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	4th Floor Area Rollup	Weighted EI #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	4th Floor Area Rollup	Weighted EI #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	4th Floor Area Rollup	Weighted EI #6	POLLTOT			
/Carleton	4th Floor Area	Weights #1	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/Environmental Index	Rollup					
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Weights #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Weights #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Weights #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Weights #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	4th Floor Area Rollup	Weights #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Active Zones	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Max Zones	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Runtime	BAV			
/Carleton College/Musser Hall/Facility	Roof Area Rollup	Time Satisfied Limit	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Environmental Index						
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Total Percent	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Zone Occ Limit	BAV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Environmental Index Occupancy Status	BBV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Status	BBV			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	EI_LOW	BALM			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Active Zones #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Active Zones #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Active Zones #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Active Zones #4	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Roof Area Rollup	Active Zones #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Roof Area Rollup	Active Zones #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Roof Area Rollup	Max Zones #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Roof Area Rollup	Max Zones #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Roof Area Rollup	Max Zones #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Roof Area Rollup	Max Zones #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Roof Area Rollup	Max Zones #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Roof Area Rollup	Max Zones #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Roof Area Rollup	Weighted EI #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Roof Area Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environ mental Index	Roof Area Rollup	Weighted EI #3	POLLTOT			
/Carleton College/Musser	Roof Area Rollup	Weighted EI #4	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Environmental Index						
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Weighted EI #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Weighted EI #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Weights #1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Weights #2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Weights #3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Weights #4	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Weights #5	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Environmental Index	Roof Area Rollup	Weights #6	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.CLG-DAT	BAI	0	0:4	Thermistor
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.FILT-STAT	BAI	0	0:5	0-20 mA
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.DAT	BAI	0	0:3	Thermistor
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.MAT	BAI	0	0:2	Thermistor
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	not used	BAI	0	0:0	0-20 mA
/Carleton	MUSS-AHU1	not used	BAI	0	0:0	Thermistor

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/Basement						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.FRZ	BBI	reversed	0:6	Dry Contact
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.SF1-STAT	BBI	normal	0:1	Dry Contact
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.CLG-VLV1	BAO	0	0:2	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.PH-DMPR	BAO	0	0:4	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.HTG-VLV1	BAO	0	0:3	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.OA-DMPR	BAO	0	0:6	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.RA-DMPR	BAO	0	0:5	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.SF1-SS	BBO	normal	0:6	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Active Zone	BAV			
/Carleton College/Musser Hall/Facility	MUSS-AHU1	COOLING RUNFOR TIME	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	HEATING RUNFOR TIME	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	COOLING REQUEST	BBV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	HEATING REQUEST	BBV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.FILT-STAT	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.RA-SMK	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.DAT-HL	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	HI DAT Shutdown	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	High Zone Temp Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.MAT-HL	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	HI RAH Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.RAT-HL	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.DAT-LL	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	LO DAT Shutdown	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.MAT-LL	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	LO RAH Alarm	BALM			
/Carleton College/Musser	MUSS-AHU1	MUSS-AHU1.RAT-LL	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Basement						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Low Temp Status Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Low Temp Stat Warning	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Low Zone Temp Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Supply Fan Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Supply Fan Hand Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Supply Fan Runtime Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Cool Available	BNI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.RA-SMK	BNI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Heat Available	BNI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	MUSS-AHU1.OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU1	Outside Air Enthalpy	ANI			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU1	Cooling Coil Valve PID Loop	BPID			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU1	Cooling Coil Valve PID Loop / MUSS-AHU1.CLG-STP	BAV			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU1	Cooling Coil Valve PID Loop / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU1	Cooling Coil Valve PID Loop / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU1	Cooling Mode Bypass PID Loop	BPID			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU1	Cooling Mode Bypass PID Loop / Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU1	Cooling Mode Bypass PID Loop / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU1	Cooling Mode Bypass PID Loop / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU1	Economizer OA/RA PID	BPID			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU1	Economizer OA/RA PID / Setpoint	BAV			
/Carleton	MUSS-AHU1	Economizer OA/RA PID / Input	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/Basement						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Economizer OA/RA PID / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Heating Valve PID Loop	BPID			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Heating Valve PID Loop / MUSS-AHU1.HTG-STP	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Heating Valve PID Loop / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Heating Valve PID Loop / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Heating Valve PID Loop	BPID			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Heating Valve PID Loop / Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Heating Valve PID Loop / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Heating Valve PID Loop / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Low Temp Protection PID Loop	BPID			
/Carleton College/Musser Hall/Facility	MUSS-AHU1	Low Temp Protection PID Loop / Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Low Temp Protection PID Loop / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU1	Low Temp Protection PID Loop / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.CLG-DAT	BAI	0	0:4	Thermistor
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.FILT-STAT	BAI	0	0:5	0-20 mA
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.DAT	BAI	0	0:3	Thermistor
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.MAT	BAI	0	0:2	Thermistor
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	not used	BAI	0	0:0	0-20 mA
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	not used	BAI	0	0:0	Thermistor
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.FRZ	BBI	reversed	0:6	Dry Contact
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.SF2-STAT	BBI	normal	0:1	Dry Contact
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.CLG-VLV1	BAO	0	0:2	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.PH-DMPR	BAO	0	0:4	Electrical 0-10 Volt
/Carleton College/Musser	MUSS-AHU2	MUSS-AHU2.HTG-VLV1	BAO	0	0:3	Electrical 0-10 Volt

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Basement						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.OA-DMPR	BAO	0	0:6	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.RA-DMPR	BAO	0	0:5	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.SF2-SS	BBO	normal	0:6	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	COOLING RUNFOR TIME	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	HEATING RUNFOR TIME	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU2	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU2	COOLING REQUEST	BBV			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU2	HEATING REQUEST	BBV			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU2	MUSS-AHU2.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU2	MUSS-AHU2.FILT-STAT	BALM			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU2	MUSS-AHU2.RA-SMK	BALM			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU2	MUSS-AHU2.DAT-HL	BALM			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU2	HI DAT Shutdown	BALM			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU2	High Zone Temp Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU2	MUSS-AHU2.MAT-HL	BALM			
/Carleton College/Musser Hall/Facility Summary/Basem ent	MUSS-AHU2	HI RAH Alarm	BALM			
/Carleton	MUSS-AHU2	MUSS-AHU2.RAT-HL	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/Basement						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.DAT-LL	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	LO DAT Shutdown	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.MAT-LL	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	LO RAH Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.RAT-LL	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Low Temp Status Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Low Temp Stat Warning	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Low Zone Temp Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Supply Fan Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Supply Fan Hand Alarm	BALM			
/Carleton College/Musser Hall/Facility	MUSS-AHU2	Supply Fan Runtime Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Cool Available	BNI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.RA-SMK	BNI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Heat Available	BNI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	MUSS-AHU2.OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Outside Air Enthalpy	ANI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Cooling Coil Valve PID Loop	BPID			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Cooling Coil Valve PID Loop / MUSS-AHU2.CLG-STP	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Cooling Coil Valve PID Loop / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Cooling Coil Valve PID Loop / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Cooling Mode Bypass PID Loop	BPID			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Cooling Mode Bypass PID Loop / Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Cooling Mode Bypass PID Loop / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Cooling Mode Bypass PID Loop / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Economizer OA/RA PID	BPID			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Economizer OA/RA PID / Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Economizer OA/RA PID / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Economizer OA/RA PID / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Heating Valve PID Loop	BPID			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Heating Valve PID Loop / MUSS-AHU2.HTG-STP	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Heating Valve PID Loop / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Heating Valve PID Loop / PID out	BAV			
/Carleton College/Musser	MUSS-AHU2	Heating Valve PID Loop	BPID			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Basement						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Heating Valve PID Loop / Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Heating Valve PID Loop / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Heating Valve PID Loop / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Low Temp Protection PID Loop	BPID			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Low Temp Protection PID Loop / Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Low Temp Protection PID Loop / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-AHU2	Low Temp Protection PID Loop / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	MUSS-FC1-RMVEST.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	MUSS-FC1-RMVEST.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	MUSS-FC1-RMVEST.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	MUSS-FC1-RMVEST.RMT-STP / Cooling Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	MUSS-FC1-RMVEST.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	MUSS-FC1-RMVEST.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	MUSS-FC1-RMVEST.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	MUSS-FC1-RMVEST.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	MUSS-FC1-RMVEST.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	MUSS-FC1-RMVEST.FILT-STAT	BAI	0	0:1	0-5 Volt
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	MUSS-FC1-RMVEST.DAT	BAI	0	0:3	Thermistor
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	MUSS-FC1-RMVEST.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	MUSS-FC1-RMVEST.P-4-Circulation-STAT	BBI	normal	0:2	Dry Contact
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	MUSS-FC1-RMVEST.FRZ	BBI	reversed	0:4	Dry Contact
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	MUSS-FC1-RMVEST.STAT	BBI	normal	0:5	Dry Contact
/Carleton	MUSS-FC1-	MUSS-FC1-RMVEST.HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/Basement	RMVEST					
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	MUSS-FC1-RMVEST.P-4-CTRL	BBO	normal	0:1	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	MUSS-FC1-RMVEST.SS	BBO	normal	0:2	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Circulation Pump Alarm	BALM			
/Carleton College/Musser Hall/Facility	MUSS-FC1-RMVEST	Circulation Pump Hand Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Circulation Pump Runtime Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Dirty Filter Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	HI DAT ALARM	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	HI DAT Shutdown	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	LO DAT ALARM	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	LO DAT Shutdown	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Low Temp Status Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Low Temp Stat Warning	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Supply Fan Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Supply Fan Hand Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Supply Fan Runtime Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Cooling Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Heat Available	BNI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Heating Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Heating Valve PID Loop	BPID			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Heating Valve PID Loop / Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Heating Valve PID Loop / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-FC1-RMVEST	Heating Valve PID Loop / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWRT	BAI	0	0:9	Thermistor
/Carleton College/Musser	MUSS-HX1	MUSS-HWS.HWSP	BAI	0	0:8	Thermistor

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Basement						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWDP2	BAI	0	0:5	0-20 mA
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWRT	BAI	0	0:7	Thermistor
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWSP	BAI	0	0:6	Thermistor
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWP1-STAT	BAI	0	0:1	0-20 mA
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWP2-STAT	BAI	0	0:2	0-20 mA
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	HWR System / Pump Suction Pressure	BAI	0	0:10	0-20 mA
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWDP1	BAI	0	0:4	0-20 mA
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.BVM	BAO	0	0:3	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWP1-VFD	BAO	0	0:6	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWP2-VFD	BAO	0	0:5	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWS.HX-VLV10	BAO	0	0:2	Electrical 0-10 Volt

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWP1-SS	BBO	normal	0:6	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWP2-SS	BBO	normal	0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	Makeup WTR Fill Valve (V-20)	BBO	normal	0:3	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	Heating Requests	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	Runtime swap time	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	Heat Active	BBV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.SYS-EN	BBV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWP-ROT	BMSV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	HW Setpoint Switch	BMSV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	Fill Valve Runtime Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	HI DIFFP	BALM			
/Carleton	MUSS-HX1	HI ERU-1 HW Loop Return Temp	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/Basement		Alarm				
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	HI ERU-1 HW Loop Supply Temp Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	HI HTG HW Diff PRS	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWST-LL	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWST-HL	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	HI HWR System Pressure	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	HI RHT HW Diff PRS	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWP1-ALM	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	HWP-1 Hand Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	HWP-1 Runtime Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWP2-ALM	BALM			
/Carleton College/Musser Hall/Facility	MUSS-HX1	HWP-2 Hand Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	HWP-2 Runtime Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	Lockout Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	LO DIFFP	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	LO ERU-1 HW Loop Return Temp Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	LO ERU-1 HW Loop Supply Temp Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	LO HTG HW Diff PRS	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWRT-LL	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.HWRT-HL	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	LO HWR System Pressure	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	LO RHT HW Diff PRS	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	Standby Pump Enabled alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	ERU HTG Valve Status (V-4)	ANI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	ERU RHT Valve Status (V-1)	ANI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	HREQ1	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	HREQ2	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	HREQ3	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	MUSS-HWS.OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	Bypass Valve Modulation PID	BPID			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	Bypass Valve Modulation PID / Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	Bypass Valve Modulation PID / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	Bypass Valve Modulation PID / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	Convertor Valve PID	BPID			
/Carleton College/Musser	MUSS-HX1	Convertor Valve PID / Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Basement						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	Convertor Valve PID / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	Convertor Valve PID / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	HW Differential Pressure PID	BPID			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	HW Differential Pressure PID / Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	HW Differential Pressure PID / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-HX1	HW Differential Pressure PID / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-MISC-POINTS	Main Steam Pressure	BAI	0	0:9	0-20 mA
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-MISC-POINTS	Burton Tunnel West Door Alarm	BBI	reversed	0:8	Dry Contact
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-MISC-POINTS	Emergency Transfer Switch	BBI	normal	0:2	Dry Contact
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-MISC-POINTS	Exhaust Fan Status	BBI	normal	0:3	Dry Contact
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-MISC-POINTS	MUSS-CRITICAL.FIRE	BBI	normal	0:4	Dry Contact

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-MISC-POINTS	MUSS-CRITICAL.GEN1-STAT	BBI	reversed	0:6	Dry Contact
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-MISC-POINTS	Musser Tunnel Alarm	BBI	reversed	0:5	Dry Contact
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-MISC-POINTS	MUSS-CRITICAL.PASS-ELEV1st-FLOOR	BBO	reversed	0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-MISC-POINTS	MUSS-CRITICAL.FIRE	BBV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-MISC-POINTS	Burton Tunnel West Door Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-MISC-POINTS	Emergency Transfer Switch	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-MISC-POINTS	Exhaust Fan status	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-MISC-POINTS	MUSS-CRITICAL.FIRE	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-MISC-POINTS	MUSS-CRITICAL.GEN2-STAT	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-MISC-POINTS	HI Main Steam Pressure Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-MISC-POINTS	LO Main Steam Pressure Alarm	BALM			
/Carleton	MUSS-MISC-	Musser Tunnel Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/Basement	POINTS					
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-DOMESTIC-HOT-WATER-WH-1	MUSS-DHW.Tank-Temp	BAI	0	0:1	Thermistor
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-DOMESTIC-HOT-WATER-WH-1	MUSS-DHW.Steam-Coil-VLV19	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-DOMESTIC-HOT-WATER-WH-1	Schedule	BBV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-DOMESTIC-HOT-WATER-WH-1	HI HW Temp ALARM	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-DOMESTIC-HOT-WATER-WH-1	LO HW Temp ALARM	BALM			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-DOMESTIC-HOT-WATER-WH-1	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-DOMESTIC-HOT-WATER-WH-1	DHW Steam Coil Valve PID	BPID			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-DOMESTIC-HOT-WATER-WH-1	DHW Steam Coil Valve PID / Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-DOMESTIC-HOT-WATER-WH-1	DHW Steam Coil Valve PID / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-DOMESTIC-HOT-WATER-WH-1	DHW Steam Coil Valve PID / PID out	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD-HEAT-REQUEST-ROLLUP	Rad Rollup	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-RAD-HEAT-REQUEST-ROLLUP	Rad Rollup	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-RAD-HEAT-REQUEST-ROLLUP	Rad Rollup	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-RAD-HEAT-REQUEST-ROLLUP	Rad Rollup	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-RAD-HEAT-REQUEST-ROLLUP	Rad Rollup	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-RAD-HEAT-REQUEST-ROLLUP	Rad Rollup	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-RAD-HEAT-REQUEST-ROLLUP	Rad Rollup	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-RAD-HEAT-REQUEST-ROLLUP	Rad Rollup	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-RAD-HEAT-REQUEST-ROLLUP	Rad Rollup	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-RAD-HEAT-REQUEST-ROLLUP	Rad Rollup	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-RAD-HEAT-REQUEST-ROLLUP	Rad Rollup	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-RAD-HEAT-REQUEST-ROLLUP	Rad Rollup	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-RAD-HEAT-REQUEST-ROLLUP	Rad Rollup	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-RAD-HEAT-REQUEST-ROLLUP	Rad Rollup	POLLTOT			
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-RAD-HEAT-REQUEST-ROLLUP	Rad Rollup	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/Basement	MUSS-RAD-HEAT-REQUEST-ROLLUP	Rad Valve Requests	ANO			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	MUSS-RAD1-RM119.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	MUSS-RAD1-RM119.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	MUSS-RAD1-RM119.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	MUSS-RAD1-RM119.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	MUSS-RAD1-RM119.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	MUSS-RAD1-RM119.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	MUSS-RAD1-RM119.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	MUSS-RAD1-RM119.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	MUSS-RAD1-RM119.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	MUSS-RAD1-RM119.RMT	ASVI			
/Carleton College/Musser	MUSS-RAD1-RM119	MUSS-RAD1-RM119.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	MUSS-RAD1-RM119.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	MUSS-RAD1-RM119.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	MUSS-RAD1-RM119.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	MUSS-RAD1-RM119.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD1-RM119	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	MUSS-RAD2-RM117.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	MUSS-RAD2-RM117.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	MUSS-RAD2-RM117.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton	MUSS-RAD2-	MUSS-RAD2-RM117.RMT-STP /	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/1st Floor	RM117	Cooling Unoccupied Setpoint				
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	MUSS-RAD2-RM117.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	MUSS-RAD2-RM117.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	MUSS-RAD2-RM117.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	MUSS-RAD2-RM117.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	MUSS-RAD2-RM117.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	MUSS-RAD2-RM117.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	MUSS-RAD2-RM117.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	MUSS-RAD2-RM117.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	MUSS-RAD2-RM117.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	Active Zone	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD2-RM117	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	MUSS-RAD2-RM117.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	MUSS-RAD2-RM117.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD2-RM117	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	MUSS-RAD3-RMEntrance.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	MUSS-RAD3-RMEntrance.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	MUSS-RAD3-RMEntrance.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	MUSS-RAD3-RMEntrance.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	MUSS-RAD3-RMEntrance.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	MUSS-RAD3-RMEntrance.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	MUSS-RAD3-RMEntrance.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	MUSS-RAD3-RMEntrance.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	MUSS-RAD3-RMEntrance.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	MUSS-RAD3-RMEntrance.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	MUSS-RAD3-RMEntrance.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	MUSS-RAD3-RMEntrance.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	MUSS-RAD3-RMEntrance.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	MUSS-RAD3-RMEntrance.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	MUSS-RAD3-RMEntrance.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD3-RMEntrance	OAT	ANI			
/Carleton	MUSS-RAD4-	MUSS-RAD4-RMEntrance.RMT-	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/1st Floor	RMEntrance	STP				
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	MUSS-RAD4-RMEntrance.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	MUSS-RAD4-RMEntrance.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	MUSS-RAD4-RMEntrance.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	MUSS-RAD4-RMEntrance.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	MUSS-RAD4-RMEntrance.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	MUSS-RAD4-RMEntrance.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	MUSS-RAD4-RMEntrance.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	MUSS-RAD4-RMEntrance.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	MUSS-RAD4-RMEntrance.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	MUSS-RAD4-RMEntrance.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility	MUSS-RAD4-RMEntrance	MUSS-RAD4-RMEntrance.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	MUSS-RAD4-RMEntrance.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	MUSS-RAD4-RMEntrance.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	MUSS-RAD4-RMEntrance.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD4-RMEntrance	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	MUSS-RAD5-RM113.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	MUSS-RAD5-RM113.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	MUSS-RAD5-RM113.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	MUSS-RAD5-RM113.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	MUSS-RAD5-RM113.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	MUSS-RAD5-RM113.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	MUSS-RAD5-RM113.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	MUSS-RAD5-RM113.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	MUSS-RAD5-RM113.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	MUSS-RAD5-RM113.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	MUSS-RAD5-RM113.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	MUSS-RAD5-RM113.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	MUSS-RAD5-RM113.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5- RM113	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5- RM113	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5- RM113	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5- RM113	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5- RM113	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5- RM113	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5- RM113	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5- RM113	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5- RM113	MUSS-RAD5-RM113.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5- RM113	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5- RM113	LO Zone Alarm	BALM			
/Carleton	MUSS-RAD5-	MUSS-RAD5-RM113.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/1st Floor	RM113					
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD5-RM113	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	MUSS-RAD6-RM111.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	MUSS-RAD6-RM111.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	MUSS-RAD6-RM111.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	MUSS-RAD6-RM111.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	MUSS-RAD6-RM111.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	MUSS-RAD6-RM111.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	MUSS-RAD6-RM111.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	MUSS-RAD6-RM111.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD6-RM111	MUSS-RAD6-RM111.RMT-STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	MUSS-RAD6-RM111.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	MUSS-RAD6-RM111.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	MUSS-RAD6-RM111.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	MUSS-RAD6-RM111.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	MUSS-RAD6-RM111.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	MUSS-RAD6-RM111.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD6-RM111	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7-RM108	MUSS-RAD7-RM108.RMT-STP	BSPTCS			
/Carleton College/Musser	MUSS-RAD7-RM108	MUSS-RAD7-RM108.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7-RM108	MUSS-RAD7-RM108.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7-RM108	MUSS-RAD7-RM108.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7-RM108	MUSS-RAD7-RM108.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7-RM108	MUSS-RAD7-RM108.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7-RM108	MUSS-RAD7-RM108.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7-RM108	MUSS-RAD7-RM108.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7-RM108	MUSS-RAD7-RM108.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7-RM108	MUSS-RAD7-RM108.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7-RM108	MUSS-RAD7-RM108.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7-RM108	MUSS-RAD7-RM108.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7-RM108	MUSS-RAD7-RM108.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7- RM108	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7- RM108	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7- RM108	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7- RM108	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7- RM108	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7- RM108	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7- RM108	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7- RM108	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7- RM108	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7- RM108	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7- RM108	Heating Plant Broadcast	BBV			
/Carleton	MUSS-RAD7-	MUSS-RAD7-RM108.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/1st Floor	RM108					
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7-RM108	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7-RM108	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7-RM108	MUSS-RAD7-RM108.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7-RM108	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD7-RM108	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	MUSS-RAD8-RM108.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	MUSS-RAD8-RM108.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	MUSS-RAD8-RM108.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	MUSS-RAD8-RM108.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	MUSS-RAD8-RM108.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD8-RM108	MUSS-RAD8-RM108.RMT-STP / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	MUSS-RAD8-RM108.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	MUSS-RAD8-RM108.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	MUSS-RAD8-RM108.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	MUSS-RAD8-RM108.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	MUSS-RAD8-RM108.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	MUSS-RAD8-RM108.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	MUSS-RAD8-RM108.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	MUSS-RAD8-RM108.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	MUSS-RAD8-RM108.MODE	ANI			
/Carleton College/Musser	MUSS-RAD8-RM108	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD8-RM108	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	MUSS-RAD9-RM106.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	MUSS-RAD9-RM106.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	MUSS-RAD9-RM106.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	MUSS-RAD9-RM106.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	MUSS-RAD9-RM106.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	MUSS-RAD9-RM106.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	MUSS-RAD9-RM106.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	MUSS-RAD9-RM106.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	MUSS-RAD9-RM106.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st	MUSS-RAD9-RM106	MUSS-RAD9-RM106.RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	MUSS-RAD9-RM106.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	MUSS-RAD9-RM106.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	MUSS-RAD9-RM106.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	Zone EI Total Weight	BAV			
/Carleton	MUSS-RAD9-	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/1st Floor	RM106					
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	MUSS-RAD9-RM106.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	MUSS-RAD9-RM106.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD9-RM106	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10-RM105	MUSS-RAD10-RM105.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10-RM105	MUSS-RAD10-RM105.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD10-RM105	MUSS-RAD10-RM105.RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10-RM105	MUSS-RAD10-RM105.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10-RM105	MUSS-RAD10-RM105.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10-RM105	MUSS-RAD10-RM105.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10-RM105	MUSS-RAD10-RM105.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10-RM105	MUSS-RAD10-RM105.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10-RM105	MUSS-RAD10-RM105.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10-RM105	MUSS-RAD10-RM105.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10-RM105	MUSS-RAD10-RM105.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10-RM105	MUSS-RAD10-RM105.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10-RM105	MUSS-RAD10-RM105.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10-RM105	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10- RM105	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10- RM105	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10- RM105	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10- RM105	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10- RM105	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10- RM105	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10- RM105	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10- RM105	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10- RM105	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10- RM105	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10- RM105	MUSS-RAD10-RM105.OCC	BBV			
/Carleton College/Musser	MUSS-RAD10- RM105	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10-RM105	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10-RM105	MUSS-RAD10-RM105.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10-RM105	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD10-RM105	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11-RM104	MUSS-RAD11-RM104.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11-RM104	MUSS-RAD11-RM104.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11-RM104	MUSS-RAD11-RM104.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11-RM104	MUSS-RAD11-RM104.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11-RM104	MUSS-RAD11-RM104.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11-RM104	MUSS-RAD11-RM104.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st	MUSS-RAD11-RM104	MUSS-RAD11-RM104.RMT-STP / Heating Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11-RM104	MUSS-RAD11-RM104.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11-RM104	MUSS-RAD11-RM104.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11-RM104	MUSS-RAD11-RM104.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11-RM104	MUSS-RAD11-RM104.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11-RM104	MUSS-RAD11-RM104.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11-RM104	MUSS-RAD11-RM104.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11-RM104	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11-RM104	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11-RM104	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11-RM104	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11-RM104	RPCT	BAV			
/Carleton	MUSS-RAD11-	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/1st Floor	RM104					
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11- RM104	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11- RM104	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11- RM104	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11- RM104	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11- RM104	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11- RM104	MUSS-RAD11-RM104.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11- RM104	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11- RM104	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11- RM104	MUSS-RAD11-RM104.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD11- RM104	Demand	ANI			
/Carleton College/Musser Hall/Facility	MUSS-RAD11- RM104	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	MUSS-RAD12-RM103.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	MUSS-RAD12-RM103.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	MUSS-RAD12-RM103.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	MUSS-RAD12-RM103.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	MUSS-RAD12-RM103.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	MUSS-RAD12-RM103.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	MUSS-RAD12-RM103.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	MUSS-RAD12-RM103.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	MUSS-RAD12-RM103.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	MUSS-RAD12-RM103.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	MUSS-RAD12-RM103.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	MUSS-RAD12-RM103.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	MUSS-RAD12-RM103.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	MUSS-RAD12-RM103.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	MUSS-RAD12-RM103.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD12-RM103	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	MUSS-RAD13-RM102.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	MUSS-RAD13-RM102.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	MUSS-RAD13-RM102.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st	MUSS-RAD13-RM102	MUSS-RAD13-RM102.RMT-STP / Cooling Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	MUSS-RAD13-RM102.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	MUSS-RAD13-RM102.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	MUSS-RAD13-RM102.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	MUSS-RAD13-RM102.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	MUSS-RAD13-RM102.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	MUSS-RAD13-RM102.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	MUSS-RAD13-RM102.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	MUSS-RAD13-RM102.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	MUSS-RAD13-RM102.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	EI Weighting	BAV			
/Carleton	MUSS-RAD13-	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/1st Floor	RM102					
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	MUSS-RAD13-RM102.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility	MUSS-RAD13-RM102	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	MUSS-RAD13-RM102.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD13-RM102	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	MUSS-RAD14-RM101.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	MUSS-RAD14-RM101.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	MUSS-RAD14-RM101.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	MUSS-RAD14-RM101.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	MUSS-RAD14-RM101.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	MUSS-RAD14-RM101.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	MUSS-RAD14-RM101.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	MUSS-RAD14-RM101.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	MUSS-RAD14-RM101.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	MUSS-RAD14-RM101.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	MUSS-RAD14-RM101.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	MUSS-RAD14-RM101.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	MUSS-RAD14-RM101.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	MUSS-RAD14-RM101.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	MUSS-RAD14-RM101.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD14-RM101	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st	MUSS-RAD15-RM100	MUSS-RAD15-RM100.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	MUSS-RAD15-RM100.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	MUSS-RAD15-RM100.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	MUSS-RAD15-RM100.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	MUSS-RAD15-RM100.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	MUSS-RAD15-RM100.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	MUSS-RAD15-RM100.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	MUSS-RAD15-RM100.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	MUSS-RAD15-RM100.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	MUSS-RAD15-RM100.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	MUSS-RAD15-RM100.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	MUSS-RAD15-RM100.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton	MUSS-RAD15-	MUSS-RAD15-RM100.RAD.HTG-	BFM		0:5	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/1st Floor	RM100	VLV / close				
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD15-RM100	Heating Plant Broadcast	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	MUSS-RAD15-RM100.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	MUSS-RAD15-RM100.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD15-RM100	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	MUSS-RAD16-RM132.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	MUSS-RAD16-RM132.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	MUSS-RAD16-RM132.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	MUSS-RAD16-RM132.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	MUSS-RAD16-RM132.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	MUSS-RAD16-RM132.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	MUSS-RAD16-RM132.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	MUSS-RAD16-RM132.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	MUSS-RAD16-RM132.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	MUSS-RAD16-RM132.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	MUSS-RAD16-RM132.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	MUSS-RAD16-RM132.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	MUSS-RAD16-RM132.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16- RM132	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16- RM132	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16- RM132	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16- RM132	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16- RM132	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16- RM132	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16- RM132	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16- RM132	MUSS-RAD16-RM132.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16- RM132	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16- RM132	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st	MUSS-RAD16- RM132	MUSS-RAD16-RM132.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD16-RM132	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	MUSS-RAD17-RM131.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	MUSS-RAD17-RM131.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	MUSS-RAD17-RM131.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	MUSS-RAD17-RM131.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	MUSS-RAD17-RM131.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	MUSS-RAD17-RM131.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	MUSS-RAD17-RM131.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	MUSS-RAD17-RM131.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	MUSS-RAD17-RM131.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton	MUSS-RAD17-	MUSS-RAD17-RM131.RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/1st Floor	RM131					
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	MUSS-RAD17-RM131.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	MUSS-RAD17-RM131.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	MUSS-RAD17-RM131.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD17-RM131	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	MUSS-RAD17-RM131.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	MUSS-RAD17-RM131.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD17-RM131	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	MUSS-RAD18-RM130.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	MUSS-RAD18-RM130.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	MUSS-RAD18-RM130.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	MUSS-RAD18-RM130.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	MUSS-RAD18-RM130.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	MUSS-RAD18-RM130.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	MUSS-RAD18-RM130.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	MUSS-RAD18-RM130.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	MUSS-RAD18-RM130.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	MUSS-RAD18-RM130.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	MUSS-RAD18-RM130.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	MUSS-RAD18-RM130.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	MUSS-RAD18-RM130.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser	MUSS-RAD18-RM130	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18- RM130	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18- RM130	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18- RM130	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18- RM130	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18- RM130	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18- RM130	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18- RM130	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18- RM130	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18- RM130	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18- RM130	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st	MUSS-RAD18- RM130	MUSS-RAD18-RM130.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	MUSS-RAD18-RM130.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD18-RM130	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	MUSS-RAD19-RM129 .RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	MUSS-RAD19-RM129 .RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	MUSS-RAD19-RM129 .RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	MUSS-RAD19-RM129 .RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	MUSS-RAD19-RM129 .RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	MUSS-RAD19-RM129 .RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton	MUSS-RAD19-	MUSS-RAD19-RM129 .RMT-STP /	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/1st Floor	RM1129	Heating Setpoint Adjust				
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	MUSS-RAD19-RM129 .RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	MUSS-RAD19-RM129 .RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	MUSS-RAD19-RM129 .RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	MUSS-RAD19-RM129 .RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	MUSS-RAD19-RM129 .RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	MUSS-RAD19-RM129 .RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD19-RM1129	RPCT	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	MUSS-RAD19-RM1129 .OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	MUSS-RAD19-RM1129 .MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD19-RM1129	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	MUSS-RAD20-RM128.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	MUSS-RAD20-RM128.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	MUSS-RAD20-RM128.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	MUSS-RAD20-RM128.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	MUSS-RAD20-RM128.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	MUSS-RAD20-RM128.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	MUSS-RAD20-RM128.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	MUSS-RAD20-RM128.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	MUSS-RAD20-RM128.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	MUSS-RAD20-RM128.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	MUSS-RAD20-RM128.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	MUSS-RAD20-RM128.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	MUSS-RAD20-RM128.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	MUSS-RAD20-RM128.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	MUSS-RAD20-RM128.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD20-RM128	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	MUSS-RAD21-RM120.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	MUSS-RAD21-RM120.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	MUSS-RAD21-RM120.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton	MUSS-RAD21-	MUSS-RAD21-RM120.RMT-STP /	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/1st Floor	RM120	Cooling Unoccupied Setpoint				
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	MUSS-RAD21-RM120.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	MUSS-RAD21-RM120.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	MUSS-RAD21-RM120.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	MUSS-RAD21-RM120.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	MUSS-RAD21-RM120.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	MUSS-RAD21-RM120.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	MUSS-RAD21-RM120.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	MUSS-RAD21-RM120.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	MUSS-RAD21-RM120.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	Active Zone	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD21-RM120	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	MUSS-RAD21-RM120.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	MUSS-RAD21-RM120.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD21-RM120	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	MUSS-RAD22-RM121 .RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	MUSS-RAD22-RM121 .RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	MUSS-RAD22-RM121 .RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	MUSS-RAD22-RM121 .RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	MUSS-RAD22-RM121 .RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	MUSS-RAD22-RM121 .RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	MUSS-RAD22-RM121 .RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	MUSS-RAD22-RM121 .RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/1st Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	MUSS-RAD22-RM121 .RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	MUSS-RAD22-RM121 .RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	MUSS-RAD22-RM121 .RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	MUSS-RAD22-RM121 .RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	MUSS-RAD22-RM121 .RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	MUSS-RAD22-RM121 .OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	MUSS-RAD22-RM121 .MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/1st Floor	MUSS-RAD22-RM121	OAT	ANI			
/Carleton	MUSS-RAD23-	MUSS-RAD23-RM222.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/2nd Floor	RM222					
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	MUSS-RAD23-RM222.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	MUSS-RAD23-RM222.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	MUSS-RAD23-RM222.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	MUSS-RAD23-RM222.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	MUSS-RAD23-RM222.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	MUSS-RAD23-RM222.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	MUSS-RAD23-RM222.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	MUSS-RAD23-RM222.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	MUSS-RAD23-RM222.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	MUSS-RAD23-RM222.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility	MUSS-RAD23-RM222	MUSS-RAD23-RM222.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	MUSS-RAD23-RM222.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	MUSS-RAD23-RM222.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	MUSS-RAD23-RM222.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD23-RM222	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24-RM221	MUSS-RAD24-RM221.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24-RM221	MUSS-RAD24-RM221.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24-RM221	MUSS-RAD24-RM221.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24-RM221	MUSS-RAD24-RM221.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24-RM221	MUSS-RAD24-RM221.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24-RM221	MUSS-RAD24-RM221.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24-RM221	MUSS-RAD24-RM221.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24-RM221	MUSS-RAD24-RM221.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24-RM221	MUSS-RAD24-RM221.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24-RM221	MUSS-RAD24-RM221.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24-RM221	MUSS-RAD24-RM221.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24-RM221	MUSS-RAD24-RM221.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24-RM221	MUSS-RAD24-RM221.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24-RM221	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24-RM221	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd	MUSS-RAD24-RM221	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24- RM221	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24- RM221	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24- RM221	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24- RM221	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24- RM221	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24- RM221	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24- RM221	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24- RM221	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24- RM221	MUSS-RAD24-RM221.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24- RM221	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24- RM221	LO Zone Alarm	BALM			
/Carleton	MUSS-RAD24-	MUSS-RAD24-RM221.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/2nd Floor	RM221					
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24-RM221	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD24-RM221	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	MUSS-RAD25-RM220.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	MUSS-RAD25-RM220.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	MUSS-RAD25-RM220.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	MUSS-RAD25-RM220.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	MUSS-RAD25-RM220.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	MUSS-RAD25-RM220.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	MUSS-RAD25-RM220.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	MUSS-RAD25-RM220.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD25-RM220	MUSS-RAD25-RM220.RMT-STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	MUSS-RAD25-RM220.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	MUSS-RAD25-RM220.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	MUSS-RAD25-RM220.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	MUSS-RAD25-RM220.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	MUSS-RAD25-RM220.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	MUSS-RAD25-RM220.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD25-RM220	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26-RM219	MUSS-RAD26-RM219.RMT-STP	BSPTCS			
/Carleton College/Musser	MUSS-RAD26-RM219	MUSS-RAD26-RM219.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26-RM219	MUSS-RAD26-RM219.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26-RM219	MUSS-RAD26-RM219.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26-RM219	MUSS-RAD26-RM219.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26-RM219	MUSS-RAD26-RM219.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26-RM219	MUSS-RAD26-RM219.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26-RM219	MUSS-RAD26-RM219.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26-RM219	MUSS-RAD26-RM219.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26-RM219	MUSS-RAD26-RM219.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26-RM219	MUSS-RAD26-RM219.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26-RM219	MUSS-RAD26-RM219.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd	MUSS-RAD26-RM219	MUSS-RAD26-RM219.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26- RM219	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26- RM219	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26- RM219	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26- RM219	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26- RM219	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26- RM219	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26- RM219	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26- RM219	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26- RM219	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26- RM219	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26- RM219	Heating Plant Broadcast	BBV			
/Carleton	MUSS-RAD26-	MUSS-RAD26-RM219.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/2nd Floor	RM219					
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26-RM219	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26-RM219	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26-RM219	MUSS-RAD26-RM219.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26-RM219	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD26-RM219	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	MUSS-RAD27-RM218.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	MUSS-RAD27-RM218.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	MUSS-RAD27-RM218.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	MUSS-RAD27-RM218.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	MUSS-RAD27-RM218.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD27-RM218	MUSS-RAD27-RM218.RMT-STP / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	MUSS-RAD27-RM218.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	MUSS-RAD27-RM218.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	MUSS-RAD27-RM218.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	MUSS-RAD27-RM218.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	MUSS-RAD27-RM218.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	MUSS-RAD27-RM218.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	MUSS-RAD27-RM218.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	MUSS-RAD27-RM218.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	MUSS-RAD27-RM218.MODE	ANI			
/Carleton College/Musser	MUSS-RAD27-RM218	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD27-RM218	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	MUSS-RAD28-RM217.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	MUSS-RAD28-RM217.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	MUSS-RAD28-RM217.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	MUSS-RAD28-RM217.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	MUSS-RAD28-RM217.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	MUSS-RAD28-RM217.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	MUSS-RAD28-RM217.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	MUSS-RAD28-RM217.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	MUSS-RAD28-RM217.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd	MUSS-RAD28-RM217	MUSS-RAD28-RM217.RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	MUSS-RAD28-RM217.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	MUSS-RAD28-RM217.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	MUSS-RAD28-RM217.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	Zone EI Total Weight	BAV			
/Carleton	MUSS-RAD28-	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/2nd Floor	RM217					
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	MUSS-RAD28-RM217.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	MUSS-RAD28-RM217.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD28-RM217	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29-RM216	MUSS-RAD29-RM216.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29-RM216	MUSS-RAD29-RM216.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD29-RM216	MUSS-RAD29-RM216.RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29-RM216	MUSS-RAD29-RM216.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29-RM216	MUSS-RAD29-RM216.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29-RM216	MUSS-RAD29-RM216.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29-RM216	MUSS-RAD29-RM216.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29-RM216	MUSS-RAD29-RM216.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29-RM216	MUSS-RAD29-RM216.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29-RM216	MUSS-RAD29-RM216.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29-RM216	MUSS-RAD29-RM216.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29-RM216	MUSS-RAD29-RM216.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29-RM216	MUSS-RAD29-RM216.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29-RM216	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29- RM216	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29- RM216	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29- RM216	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29- RM216	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29- RM216	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29- RM216	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29- RM216	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29- RM216	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29- RM216	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29- RM216	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29- RM216	MUSS-RAD29-RM216.OCC	BBV			
/Carleton College/Musser	MUSS-RAD29- RM216	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29-RM216	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29-RM216	MUSS-RAD29-RM216.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29-RM216	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD29-RM216	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	MUSS-RAD30-RM215.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	MUSS-RAD30-RM215.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	MUSS-RAD30-RM215.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	MUSS-RAD30-RM215.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	MUSS-RAD30-RM215.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	MUSS-RAD30-RM215.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd	MUSS-RAD30-RM215	MUSS-RAD30-RM215.RMT-STP / Heating Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	MUSS-RAD30-RM215.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	MUSS-RAD30-RM215.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	MUSS-RAD30-RM215.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	MUSS-RAD30-RM215.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	MUSS-RAD30-RM215.RAD.HTG-VLV / open	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	MUSS-RAD30-RM215.RAD.HTG-VLV / close	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	RPCT	BAV			
/Carleton	MUSS-RAD30-	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/2nd Floor	RM215					
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	MUSS-RAD30-RM215.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	MUSS-RAD30-RM215.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD30-RM215	Demand	ANI			
/Carleton College/Musser Hall/Facility	MUSS-RAD30-RM215	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	MUSS-RAD31-RM214.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	MUSS-RAD31-RM214.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	MUSS-RAD31-RM214.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	MUSS-RAD31-RM214.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	MUSS-RAD31-RM214.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	MUSS-RAD31-RM214.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	MUSS-RAD31-RM214.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	MUSS-RAD31-RM214.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	MUSS-RAD31-RM214.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	MUSS-RAD31-RM214.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	MUSS-RAD31-RM214.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	MUSS-RAD31-RM214.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	MUSS-RAD31-RM214.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	MUSS-RAD31-RM214.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	MUSS-RAD31-RM214.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD31-RM214	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	MUSS-RAD32-RM213.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	MUSS-RAD32-RM213.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	MUSS-RAD32-RM213.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd	MUSS-RAD32-RM213	MUSS-RAD32-RM213.RMT-STP / Cooling Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	MUSS-RAD32-RM213.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	MUSS-RAD32-RM213.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	MUSS-RAD32-RM213.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	MUSS-RAD32-RM213.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	MUSS-RAD32-RM213.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	MUSS-RAD32-RM213.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	MUSS-RAD32-RM213.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	MUSS-RAD32-RM213.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	MUSS-RAD32-RM213.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	EI Weighting	BAV			
/Carleton	MUSS-RAD32-	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/2nd Floor	RM213					
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	MUSS-RAD32-RM213.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility	MUSS-RAD32-RM213	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	MUSS-RAD32-RM213.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD32-RM213	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	MUSS-RAD33-RM211.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	MUSS-RAD33-RM211.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	MUSS-RAD33-RM211.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	MUSS-RAD33-RM211.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	MUSS-RAD33-RM211.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	MUSS-RAD33-RM211.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	MUSS-RAD33-RM211.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	MUSS-RAD33-RM211.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	MUSS-RAD33-RM211.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	MUSS-RAD33-RM211.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	MUSS-RAD33-RM211.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	MUSS-RAD33-RM211.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	MUSS-RAD33-RM211.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	MUSS-RAD33-RM211.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	MUSS-RAD33-RM211.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD33-RM211	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd	MUSS-RAD34-RM210	MUSS-RAD34-RM210.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	MUSS-RAD34-RM210.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	MUSS-RAD34-RM210.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	MUSS-RAD34-RM210.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	MUSS-RAD34-RM210.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	MUSS-RAD34-RM210.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	MUSS-RAD34-RM210.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	MUSS-RAD34-RM210.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	MUSS-RAD34-RM210.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	MUSS-RAD34-RM210.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	MUSS-RAD34-RM210.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	MUSS-RAD34-RM210.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton	MUSS-RAD34-	MUSS-RAD34-RM210.RAD.HTG-	BFM		0:5	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/2nd Floor	RM210	VLV / close				
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD34-RM210	Heating Plant Broadcast	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	MUSS-RAD34-RM210.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	MUSS-RAD34-RM210.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD34-RM210	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35-RM209	MUSS-RAD35-RM209.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35-RM209	MUSS-RAD35-RM209.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35-RM209	MUSS-RAD35-RM209.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35-RM209	MUSS-RAD35-RM209.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35-RM209	MUSS-RAD35-RM209.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35-RM209	MUSS-RAD35-RM209.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35-RM209	MUSS-RAD35-RM209.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35-RM209	MUSS-RAD35-RM209.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35-RM209	MUSS-RAD35-RM209.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35-RM209	MUSS-RAD35-RM209.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35-RM209	MUSS-RAD35-RM209.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35-RM209	MUSS-RAD35-RM209.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35-RM209	MUSS-RAD35-RM209.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35-RM209	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35-RM209	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35-RM209	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35-RM209	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35- RM209	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35- RM209	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35- RM209	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35- RM209	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35- RM209	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35- RM209	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35- RM209	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35- RM209	MUSS-RAD35-RM209.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35- RM209	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35- RM209	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd	MUSS-RAD35- RM209	MUSS-RAD35-RM209.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35- RM209	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD35- RM209	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36- RM208	MUSS-RAD36-RM208.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36- RM208	MUSS-RAD36-RM208.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36- RM208	MUSS-RAD36-RM208.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36- RM208	MUSS-RAD36-RM208.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36- RM208	MUSS-RAD36-RM208.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36- RM208	MUSS-RAD36-RM208.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36- RM208	MUSS-RAD36-RM208.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36- RM208	MUSS-RAD36-RM208.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36- RM208	MUSS-RAD36-RM208.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton	MUSS-RAD36-	MUSS-RAD36-RM208.RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/2nd Floor	RM208					
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	MUSS-RAD36-RM208.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	MUSS-RAD36-RM208.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	MUSS-RAD36-RM208.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD36-RM208	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	MUSS-RAD36-RM208.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	MUSS-RAD36-RM208.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD36-RM208	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	MUSS-RAD37-RM207.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	MUSS-RAD37-RM207.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	MUSS-RAD37-RM207.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	MUSS-RAD37-RM207.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	MUSS-RAD37-RM207.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	MUSS-RAD37-RM207.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	MUSS-RAD37-RM207.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	MUSS-RAD37-RM207.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	MUSS-RAD37-RM207.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	MUSS-RAD37-RM207.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	MUSS-RAD37-RM207.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	MUSS-RAD37-RM207.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	MUSS-RAD37-RM207.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser	MUSS-RAD37-RM207	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd	MUSS-RAD37-RM207	MUSS-RAD37-RM207.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	MUSS-RAD37-RM207.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD37-RM207	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	MUSS-RAD38-RM206.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	MUSS-RAD38-RM206.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	MUSS-RAD38-RM206.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	MUSS-RAD38-RM206.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	MUSS-RAD38-RM206.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	MUSS-RAD38-RM206.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton	MUSS-RAD38-	MUSS-RAD38-RM206.RMT-STP /	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/2nd Floor	RM206	Heating Setpoint Adjust				
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	MUSS-RAD38-RM206.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	MUSS-RAD38-RM206.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	MUSS-RAD38-RM206.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	MUSS-RAD38-RM206.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	MUSS-RAD38-RM206.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	MUSS-RAD38-RM206.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD38-RM206	RPCT	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	MUSS-RAD38-RM206.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	MUSS-RAD38-RM206.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD38-RM206	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	MUSS-RAD39-RM205.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	MUSS-RAD39-RM205.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	MUSS-RAD39-RM205.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	MUSS-RAD39-RM205.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	MUSS-RAD39-RM205.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	MUSS-RAD39-RM205.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	MUSS-RAD39-RM205.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	MUSS-RAD39-RM205.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	MUSS-RAD39-RM205.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	MUSS-RAD39-RM205.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	MUSS-RAD39-RM205.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	MUSS-RAD39-RM205.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	MUSS-RAD39-RM205.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd	MUSS-RAD39-RM205	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	MUSS-RAD39-RM205.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	MUSS-RAD39-RM205.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD39-RM205	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	MUSS-RAD40-RM204.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	MUSS-RAD40-RM204.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	MUSS-RAD40-RM204.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton	MUSS-RAD40-	MUSS-RAD40-RM204.RMT-STP /	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/2nd Floor	RM204	Cooling Unoccupied Setpoint				
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	MUSS-RAD40-RM204.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	MUSS-RAD40-RM204.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	MUSS-RAD40-RM204.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	MUSS-RAD40-RM204.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	MUSS-RAD40-RM204.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	MUSS-RAD40-RM204.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	MUSS-RAD40-RM204.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	MUSS-RAD40-RM204.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	MUSS-RAD40-RM204.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	Active Zone	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD40-RM204	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	MUSS-RAD40-RM204.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	MUSS-RAD40-RM204.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD40-RM204	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	MUSS-RAD41-RM203.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	MUSS-RAD41-RM203.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	MUSS-RAD41-RM203.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	MUSS-RAD41-RM203.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	MUSS-RAD41-RM203.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	MUSS-RAD41-RM203.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	MUSS-RAD41-RM203.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	MUSS-RAD41-RM203.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	MUSS-RAD41-RM203.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	MUSS-RAD41-RM203.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	MUSS-RAD41-RM203.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	MUSS-RAD41-RM203.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	MUSS-RAD41-RM203.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41-RM203	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd	MUSS-RAD41-RM203	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41- RM203	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41- RM203	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41- RM203	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41- RM203	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41- RM203	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41- RM203	MUSS-RAD41-RM203.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41- RM203	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41- RM203	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41- RM203	MUSS-RAD41-RM203.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41- RM203	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD41- RM203	OAT	ANI			
/Carleton	MUSS-RAD42-	MUSS-RAD42-RM202.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/2nd Floor	RM202					
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	MUSS-RAD42-RM202.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	MUSS-RAD42-RM202.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	MUSS-RAD42-RM202.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	MUSS-RAD42-RM202.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	MUSS-RAD42-RM202.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	MUSS-RAD42-RM202.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	MUSS-RAD42-RM202.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	MUSS-RAD42-RM202.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	MUSS-RAD42-RM202.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	MUSS-RAD42-RM202.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility	MUSS-RAD42-RM202	MUSS-RAD42-RM202.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	MUSS-RAD42-RM202.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	MUSS-RAD42-RM202.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	MUSS-RAD42-RM202.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD42-RM202	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43-RM201	MUSS-RAD43-RM201.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43-RM201	MUSS-RAD43-RM201.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43-RM201	MUSS-RAD43-RM201.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43-RM201	MUSS-RAD43-RM201.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43-RM201	MUSS-RAD43-RM201.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43-RM201	MUSS-RAD43-RM201.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43-RM201	MUSS-RAD43-RM201.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43-RM201	MUSS-RAD43-RM201.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43-RM201	MUSS-RAD43-RM201.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43-RM201	MUSS-RAD43-RM201.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43-RM201	MUSS-RAD43-RM201.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43-RM201	MUSS-RAD43-RM201.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43-RM201	MUSS-RAD43-RM201.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43-RM201	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43-RM201	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd	MUSS-RAD43-RM201	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43- RM201	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43- RM201	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43- RM201	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43- RM201	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43- RM201	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43- RM201	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43- RM201	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43- RM201	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43- RM201	MUSS-RAD43-RM201.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43- RM201	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43- RM201	LO Zone Alarm	BALM			
/Carleton	MUSS-RAD43-	MUSS-RAD43-RM201.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/2nd Floor	RM201					
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43-RM201	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD43-RM201	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	MUSS-RAD44-RM228.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	MUSS-RAD44-RM228.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	MUSS-RAD44-RM228.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	MUSS-RAD44-RM228.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	MUSS-RAD44-RM228.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	MUSS-RAD44-RM228.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	MUSS-RAD44-RM228.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	MUSS-RAD44-RM228.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD44-RM228	MUSS-RAD44-RM228.RMT-STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	MUSS-RAD44-RM228.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	MUSS-RAD44-RM228.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	MUSS-RAD44-RM228.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	MUSS-RAD44-RM228.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	MUSS-RAD44-RM228.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	MUSS-RAD44-RM228.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD44-RM228	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45-RM227	MUSS-RAD45-RM227.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45-RM227	MUSS-RAD45-RM227.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45-RM227	MUSS-RAD45-RM227.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45-RM227	MUSS-RAD45-RM227.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45-RM227	MUSS-RAD45-RM227.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45-RM227	MUSS-RAD45-RM227.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45-RM227	MUSS-RAD45-RM227.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45-RM227	MUSS-RAD45-RM227.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45-RM227	MUSS-RAD45-RM227.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45-RM227	MUSS-RAD45-RM227.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45-RM227	MUSS-RAD45-RM227.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45-RM227	MUSS-RAD45-RM227.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd	MUSS-RAD45-RM227	MUSS-RAD45-RM227.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45- RM227	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45- RM227	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45- RM227	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45- RM227	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45- RM227	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45- RM227	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45- RM227	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45- RM227	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45- RM227	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45- RM227	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45- RM227	Heating Plant Broadcast	BBV			
/Carleton	MUSS-RAD45-	MUSS-RAD45-RM227.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/2nd Floor	RM227					
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45-RM227	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45-RM227	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45-RM227	MUSS-RAD45-RM227.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45-RM227	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD45-RM227	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46-RM226	MUSS-RAD46-RM226.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46-RM226	MUSS-RAD46-RM226.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46-RM226	MUSS-RAD46-RM226.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46-RM226	MUSS-RAD46-RM226.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46-RM226	MUSS-RAD46-RM226.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD46-RM226	MUSS-RAD46-RM226.RMT-STP / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46-RM226	MUSS-RAD46-RM226.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46-RM226	MUSS-RAD46-RM226.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46-RM226	MUSS-RAD46-RM226.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46-RM226	MUSS-RAD46-RM226.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46-RM226	MUSS-RAD46-RM226.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46-RM226	MUSS-RAD46-RM226.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46-RM226	MUSS-RAD46-RM226.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46-RM226	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46-RM226	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46-RM226	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46-RM226	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46- RM226	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46- RM226	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46- RM226	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46- RM226	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46- RM226	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46- RM226	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46- RM226	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46- RM226	MUSS-RAD46-RM226.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46- RM226	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46- RM226	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46- RM226	MUSS-RAD46-RM226.MODE	ANI			
/Carleton College/Musser	MUSS-RAD46- RM226	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD46-RM226	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	MUSS-RAD47-RM225.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	MUSS-RAD47-RM225.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	MUSS-RAD47-RM225.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	MUSS-RAD47-RM225.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	MUSS-RAD47-RM225.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	MUSS-RAD47-RM225.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	MUSS-RAD47-RM225.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	MUSS-RAD47-RM225.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	MUSS-RAD47-RM225.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd	MUSS-RAD47-RM225	MUSS-RAD47-RM225.RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	MUSS-RAD47-RM225.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	MUSS-RAD47-RM225.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	MUSS-RAD47-RM225.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	Zone EI Total Weight	BAV			
/Carleton	MUSS-RAD47-	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/2nd Floor	RM225					
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	MUSS-RAD47-RM225.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	MUSS-RAD47-RM225.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD47-RM225	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48-RM224	MUSS-RAD48-RM224.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48-RM224	MUSS-RAD48-RM224.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD48-RM224	MUSS-RAD48-RM224.RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48-RM224	MUSS-RAD48-RM224.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48-RM224	MUSS-RAD48-RM224.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48-RM224	MUSS-RAD48-RM224.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48-RM224	MUSS-RAD48-RM224.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48-RM224	MUSS-RAD48-RM224.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48-RM224	MUSS-RAD48-RM224.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48-RM224	MUSS-RAD48-RM224.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48-RM224	MUSS-RAD48-RM224.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48-RM224	MUSS-RAD48-RM224.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48-RM224	MUSS-RAD48-RM224.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48-RM224	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48- RM224	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48- RM224	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48- RM224	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48- RM224	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48- RM224	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48- RM224	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48- RM224	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48- RM224	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48- RM224	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48- RM224	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48- RM224	MUSS-RAD48-RM224.OCC	BBV			
/Carleton College/Musser	MUSS-RAD48- RM224	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48-RM224	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48-RM224	MUSS-RAD48-RM224.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48-RM224	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD48-RM224	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	MUSS-RAD49-RM223.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	MUSS-RAD49-RM223.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	MUSS-RAD49-RM223.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	MUSS-RAD49-RM223.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	MUSS-RAD49-RM223.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	MUSS-RAD49-RM223.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd	MUSS-RAD49-RM223	MUSS-RAD49-RM223.RMT-STP / Heating Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	MUSS-RAD49-RM223.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	MUSS-RAD49-RM223.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	MUSS-RAD49-RM223.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	MUSS-RAD49-RM223.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	MUSS-RAD49-RM223.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	MUSS-RAD49-RM223.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	RPCT	BAV			
/Carleton	MUSS-RAD49-	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/2nd Floor	RM223					
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	MUSS-RAD49-RM223.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	MUSS-RAD49-RM223.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/2nd Floor	MUSS-RAD49-RM223	Demand	ANI			
/Carleton College/Musser Hall/Facility	MUSS-RAD49-RM223	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/2nd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	MUSS-RAD50-RM322.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	MUSS-RAD50-RM322.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	MUSS-RAD50-RM322.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	MUSS-RAD50-RM322.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	MUSS-RAD50-RM322.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	MUSS-RAD50-RM322.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	MUSS-RAD50-RM322.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	MUSS-RAD50-RM322.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	MUSS-RAD50-RM322.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	MUSS-RAD50-RM322.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	MUSS-RAD50-RM322.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	MUSS-RAD50-RM322.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	MUSS-RAD50-RM322.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	MUSS-RAD50-RM322.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	MUSS-RAD50-RM322.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD50-RM322	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	MUSS-RAD51-RM321.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	MUSS-RAD51-RM321.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	MUSS-RAD51-RM321.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd	MUSS-RAD51-RM321	MUSS-RAD51-RM321.RMT-STP / Cooling Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	MUSS-RAD51-RM321.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	MUSS-RAD51-RM321.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	MUSS-RAD51-RM321.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	MUSS-RAD51-RM321.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	MUSS-RAD51-RM321.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	MUSS-RAD51-RM321.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	MUSS-RAD51-RM321.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	MUSS-RAD51-RM321.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	MUSS-RAD51-RM321.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	EI Weighting	BAV			
/Carleton	MUSS-RAD51-	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/3rd Floor	RM321					
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	MUSS-RAD51-RM321.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility	MUSS-RAD51-RM321	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	MUSS-RAD51-RM321.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD51-RM321	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	MUSS-RAD52-RM320.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	MUSS-RAD52-RM320.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	MUSS-RAD52-RM320.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	MUSS-RAD52-RM320.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	MUSS-RAD52-RM320.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	MUSS-RAD52-RM320.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	MUSS-RAD52-RM320.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	MUSS-RAD52-RM320.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	MUSS-RAD52-RM320.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	MUSS-RAD52-RM320.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	MUSS-RAD52-RM320.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	MUSS-RAD52-RM320.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	MUSS-RAD52-RM320.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	MUSS-RAD52-RM320.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	MUSS-RAD52-RM320.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD52-RM320	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd	MUSS-RAD53-RM319	MUSS-RAD53-RM319.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	MUSS-RAD53-RM319.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	MUSS-RAD53-RM319.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	MUSS-RAD53-RM319.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	MUSS-RAD53-RM319.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	MUSS-RAD53-RM319.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	MUSS-RAD53-RM319.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	MUSS-RAD53-RM319.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	MUSS-RAD53-RM319.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	MUSS-RAD53-RM319.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	MUSS-RAD53-RM319.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	MUSS-RAD53-RM319.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton	MUSS-RAD53-	MUSS-RAD53-RM319.RAD.HTG-	BFM		0:5	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/3rd Floor	RM319	VLV / close				
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD53-RM319	Heating Plant Broadcast	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	MUSS-RAD53-RM319.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	MUSS-RAD53-RM319.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD53-RM319	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	MUSS-RAD54-RM318.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	MUSS-RAD54-RM318.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	MUSS-RAD54-RM318.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	MUSS-RAD54-RM318.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	MUSS-RAD54-RM318.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	MUSS-RAD54-RM318.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	MUSS-RAD54-RM318.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	MUSS-RAD54-RM318.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	MUSS-RAD54-RM318.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	MUSS-RAD54-RM318.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	MUSS-RAD54-RM318.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	MUSS-RAD54-RM318.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	MUSS-RAD54-RM318.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	MUSS-RAD54-RM318.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54-RM318	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd	MUSS-RAD54-RM318	MUSS-RAD54-RM318.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54- RM318	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD54- RM318	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55- RM317	MUSS-RAD55-RM317.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55- RM317	MUSS-RAD55-RM317.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55- RM317	MUSS-RAD55-RM317.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55- RM317	MUSS-RAD55-RM317.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55- RM317	MUSS-RAD55-RM317.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55- RM317	MUSS-RAD55-RM317.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55- RM317	MUSS-RAD55-RM317.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55- RM317	MUSS-RAD55-RM317.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55- RM317	MUSS-RAD55-RM317.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton	MUSS-RAD55-	MUSS-RAD55-RM317.RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/3rd Floor	RM317					
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	MUSS-RAD55-RM317.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	MUSS-RAD55-RM317.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	MUSS-RAD55-RM317.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD55-RM317	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	MUSS-RAD55-RM317.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	MUSS-RAD55-RM317.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD55-RM317	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	MUSS-RAD56-RM316.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	MUSS-RAD56-RM316.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	MUSS-RAD56-RM316.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	MUSS-RAD56-RM316.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	MUSS-RAD56-RM316.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	MUSS-RAD56-RM316.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	MUSS-RAD56-RM316.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	MUSS-RAD56-RM316.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	MUSS-RAD56-RM316.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	MUSS-RAD56-RM316.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	MUSS-RAD56-RM316.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	MUSS-RAD56-RM316.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	MUSS-RAD56-RM316.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser	MUSS-RAD56-RM316	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd	MUSS-RAD56-RM316	MUSS-RAD56-RM316.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	MUSS-RAD56-RM316.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD56-RM316	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	MUSS-RAD57-RM315.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	MUSS-RAD57-RM315.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	MUSS-RAD57-RM315.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	MUSS-RAD57-RM315.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	MUSS-RAD57-RM315.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	MUSS-RAD57-RM315.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton	MUSS-RAD57-	MUSS-RAD57-RM315.RMT-STP /	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/3rd Floor	RM315	Heating Setpoint Adjust				
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	MUSS-RAD57-RM315.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	MUSS-RAD57-RM315.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	MUSS-RAD57-RM315.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	MUSS-RAD57-RM315.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	MUSS-RAD57-RM315.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	MUSS-RAD57-RM315.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD57-RM315	RPCT	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	MUSS-RAD57-RM315.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	MUSS-RAD57-RM315.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD57-RM315	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	MUSS-RAD58-RM314.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	MUSS-RAD58-RM314.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	MUSS-RAD58-RM314.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	MUSS-RAD58-RM314.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	MUSS-RAD58-RM314.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	MUSS-RAD58-RM314.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	MUSS-RAD58-RM314.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	MUSS-RAD58-RM314.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	MUSS-RAD58-RM314.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	MUSS-RAD58-RM314.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	MUSS-RAD58-RM314.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	MUSS-RAD58-RM314.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	MUSS-RAD58-RM314.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	MUSS-RAD58-RM314.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	MUSS-RAD58-RM314.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD58-RM314	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	MUSS-RAD59-RM313.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	MUSS-RAD59-RM313.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	MUSS-RAD59-RM313.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton	MUSS-RAD59-	MUSS-RAD59-RM313.RMT-STP /	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/3rd Floor	RM313	Cooling Unoccupied Setpoint				
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	MUSS-RAD59-RM313.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	MUSS-RAD59-RM313.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	MUSS-RAD59-RM313.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	MUSS-RAD59-RM313.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	MUSS-RAD59-RM313.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	MUSS-RAD59-RM313.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	MUSS-RAD59-RM313.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	MUSS-RAD59-RM313.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	MUSS-RAD59-RM313.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	Active Zone	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD59-RM313	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	MUSS-RAD59-RM313.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	MUSS-RAD59-RM313.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD59-RM313	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	MUSS-RAD60-RM311.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	MUSS-RAD60-RM311.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	MUSS-RAD60-RM311.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	MUSS-RAD60-RM311.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	MUSS-RAD60-RM311.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	MUSS-RAD60-RM311.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	MUSS-RAD60-RM311.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	MUSS-RAD60-RM311.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	MUSS-RAD60-RM311.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	MUSS-RAD60-RM311.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	MUSS-RAD60-RM311.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	MUSS-RAD60-RM311.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	MUSS-RAD60-RM311.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60-RM311	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd	MUSS-RAD60-RM311	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60- RM311	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60- RM311	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60- RM311	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60- RM311	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60- RM311	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60- RM311	MUSS-RAD60-RM311.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60- RM311	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60- RM311	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60- RM311	MUSS-RAD60-RM311.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60- RM311	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD60- RM311	OAT	ANI			
/Carleton	MUSS-RAD61-	MUSS-RAD61-RM310.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/3rd Floor	RM310					
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	MUSS-RAD61-RM310.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	MUSS-RAD61-RM310.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	MUSS-RAD61-RM310.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	MUSS-RAD61-RM310.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	MUSS-RAD61-RM310.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	MUSS-RAD61-RM310.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	MUSS-RAD61-RM310.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	MUSS-RAD61-RM310.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	MUSS-RAD61-RM310.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	MUSS-RAD61-RM310.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility	MUSS-RAD61-RM310	MUSS-RAD61-RM310.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	MUSS-RAD61-RM310.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	MUSS-RAD61-RM310.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	MUSS-RAD61-RM310.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD61-RM310	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62-RM309	MUSS-RAD62-RM309.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62-RM309	MUSS-RAD62-RM309.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62-RM309	MUSS-RAD62-RM309.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62-RM309	MUSS-RAD62-RM309.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62-RM309	MUSS-RAD62-RM309.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62-RM309	MUSS-RAD62-RM309.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62-RM309	MUSS-RAD62-RM309.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62-RM309	MUSS-RAD62-RM309.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62-RM309	MUSS-RAD62-RM309.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62-RM309	MUSS-RAD62-RM309.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62-RM309	MUSS-RAD62-RM309.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62-RM309	MUSS-RAD62-RM309.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62-RM309	MUSS-RAD62-RM309.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62-RM309	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62-RM309	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd	MUSS-RAD62-RM309	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62- RM309	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62- RM309	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62- RM309	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62- RM309	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62- RM309	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62- RM309	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62- RM309	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62- RM309	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62- RM309	MUSS-RAD62-RM309.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62- RM309	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62- RM309	LO Zone Alarm	BALM			
/Carleton	MUSS-RAD62-	MUSS-RAD62-RM309.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/3rd Floor	RM309					
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62-RM309	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD62-RM309	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	MUSS-RAD63-RM308.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	MUSS-RAD63-RM308.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	MUSS-RAD63-RM308.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	MUSS-RAD63-RM308.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	MUSS-RAD63-RM308.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	MUSS-RAD63-RM308.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	MUSS-RAD63-RM308.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	MUSS-RAD63-RM308.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD63-RM308	MUSS-RAD63-RM308.RMT-STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	MUSS-RAD63-RM308.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	MUSS-RAD63-RM308.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	MUSS-RAD63-RM308.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	MUSS-RAD63-RM308.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	MUSS-RAD63-RM308.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	MUSS-RAD63-RM308.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD63-RM308	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64-RM307	MUSS-RAD64-RM307.RMT-STP	BSPTCS			
/Carleton College/Musser	MUSS-RAD64-RM307	MUSS-RAD64-RM307.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64-RM307	MUSS-RAD64-RM307.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64-RM307	MUSS-RAD64-RM307.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64-RM307	MUSS-RAD64-RM307.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64-RM307	MUSS-RAD64-RM307.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64-RM307	MUSS-RAD64-RM307.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64-RM307	MUSS-RAD64-RM307.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64-RM307	MUSS-RAD64-RM307.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64-RM307	MUSS-RAD64-RM307.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64-RM307	MUSS-RAD64-RM307.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64-RM307	MUSS-RAD64-RM307.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd	MUSS-RAD64-RM307	MUSS-RAD64-RM307.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64- RM307	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64- RM307	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64- RM307	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64- RM307	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64- RM307	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64- RM307	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64- RM307	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64- RM307	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64- RM307	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64- RM307	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64- RM307	Heating Plant Broadcast	BBV			
/Carleton	MUSS-RAD64-	MUSS-RAD64-RM307.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/3rd Floor	RM307					
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64-RM307	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64-RM307	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64-RM307	MUSS-RAD64-RM307.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64-RM307	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD64-RM307	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	MUSS-RAD65-RM306.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	MUSS-RAD65-RM306.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	MUSS-RAD65-RM306.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	MUSS-RAD65-RM306.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	MUSS-RAD65-RM306.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD65-RM306	MUSS-RAD65-RM306.RMT-STP / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	MUSS-RAD65-RM306.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	MUSS-RAD65-RM306.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	MUSS-RAD65-RM306.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	MUSS-RAD65-RM306.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	MUSS-RAD65-RM306.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	MUSS-RAD65-RM306.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	MUSS-RAD65-RM306.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	MUSS-RAD65-RM306.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	MUSS-RAD65-RM306.MODE	ANI			
/Carleton College/Musser	MUSS-RAD65-RM306	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD65-RM306	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	MUSS-RAD66-RM305.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	MUSS-RAD66-RM305.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	MUSS-RAD66-RM305.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	MUSS-RAD66-RM305.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	MUSS-RAD66-RM305.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	MUSS-RAD66-RM305.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	MUSS-RAD66-RM305.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	MUSS-RAD66-RM305.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	MUSS-RAD66-RM305.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd	MUSS-RAD66-RM305	MUSS-RAD66-RM305.RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	MUSS-RAD66-RM305.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	MUSS-RAD66-RM305.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	MUSS-RAD66-RM305.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	Zone EI Total Weight	BAV			
/Carleton	MUSS-RAD66-	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/3rd Floor	RM305					
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	MUSS-RAD66-RM305.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	MUSS-RAD66-RM305.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD66-RM305	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67-RM304	MUSS-RAD67-RM304.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67-RM304	MUSS-RAD67-RM304.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD67-RM304	MUSS-RAD67-RM304.RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67-RM304	MUSS-RAD67-RM304.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67-RM304	MUSS-RAD67-RM304.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67-RM304	MUSS-RAD67-RM304.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67-RM304	MUSS-RAD67-RM304.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67-RM304	MUSS-RAD67-RM304.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67-RM304	MUSS-RAD67-RM304.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67-RM304	MUSS-RAD67-RM304.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67-RM304	MUSS-RAD67-RM304.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67-RM304	MUSS-RAD67-RM304.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67-RM304	MUSS-RAD67-RM304.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67-RM304	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67- RM304	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67- RM304	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67- RM304	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67- RM304	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67- RM304	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67- RM304	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67- RM304	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67- RM304	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67- RM304	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67- RM304	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67- RM304	MUSS-RAD67-RM304.OCC	BBV			
/Carleton College/Musser	MUSS-RAD67- RM304	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67-RM304	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67-RM304	MUSS-RAD67-RM304.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67-RM304	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD67-RM304	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68-RM303	MUSS-RAD68-RM303.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68-RM303	MUSS-RAD68-RM303.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68-RM303	MUSS-RAD68-RM303.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68-RM303	MUSS-RAD68-RM303.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68-RM303	MUSS-RAD68-RM303.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68-RM303	MUSS-RAD68-RM303.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd	MUSS-RAD68-RM303	MUSS-RAD68-RM303.RMT-STP / Heating Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68- RM303	MUSS-RAD68-RM303.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68- RM303	MUSS-RAD68-RM303.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68- RM303	MUSS-RAD68-RM303.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68- RM303	MUSS-RAD68-RM303.RAD.HTG- VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68- RM303	MUSS-RAD68-RM303.RAD.HTG- VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68- RM303	MUSS-RAD68-RM303.RAD.HTG- VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68- RM303	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68- RM303	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68- RM303	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68- RM303	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68- RM303	RPCT	BAV			
/Carleton	MUSS-RAD68-	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/3rd Floor	RM303					
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68-RM303	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68-RM303	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68-RM303	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68-RM303	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68-RM303	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68-RM303	MUSS-RAD68-RM303.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68-RM303	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68-RM303	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68-RM303	MUSS-RAD68-RM303.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD68-RM303	Demand	ANI			
/Carleton College/Musser Hall/Facility	MUSS-RAD68-RM303	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	MUSS-RAD69-RM302.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	MUSS-RAD69-RM302.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	MUSS-RAD69-RM302.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	MUSS-RAD69-RM302.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	MUSS-RAD69-RM302.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	MUSS-RAD69-RM302.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	MUSS-RAD69-RM302.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	MUSS-RAD69-RM302.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	MUSS-RAD69-RM302.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	MUSS-RAD69-RM302.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	MUSS-RAD69-RM302.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	MUSS-RAD69-RM302.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	MUSS-RAD69-RM302.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	MUSS-RAD69-RM302.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	MUSS-RAD69-RM302.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD69-RM302	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	MUSS-RAD70-RM301.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	MUSS-RAD70-RM301.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	MUSS-RAD70-RM301.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd	MUSS-RAD70-RM301	MUSS-RAD70-RM301.RMT-STP / Cooling Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	MUSS-RAD70-RM301.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	MUSS-RAD70-RM301.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	MUSS-RAD70-RM301.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	MUSS-RAD70-RM301.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	MUSS-RAD70-RM301.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	MUSS-RAD70-RM301.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	MUSS-RAD70-RM301.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	MUSS-RAD70-RM301.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	MUSS-RAD70-RM301.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	EI Weighting	BAV			
/Carleton	MUSS-RAD70-	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/3rd Floor	RM301					
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	MUSS-RAD70-RM301.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility	MUSS-RAD70-RM301	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	MUSS-RAD70-RM301.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD70-RM301	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	MUSS-RAD71-RM328.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	MUSS-RAD71-RM328.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	MUSS-RAD71-RM328.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	MUSS-RAD71-RM328.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	MUSS-RAD71-RM328.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	MUSS-RAD71-RM328.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	MUSS-RAD71-RM328.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	MUSS-RAD71-RM328.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	MUSS-RAD71-RM328.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	MUSS-RAD71-RM328.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	MUSS-RAD71-RM328.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	MUSS-RAD71-RM328.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	MUSS-RAD71-RM328.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	MUSS-RAD71-RM328.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	MUSS-RAD71-RM328.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD71-RM328	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd	MUSS-RAD72-RM327	MUSS-RAD72-RM327.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	MUSS-RAD72-RM327.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	MUSS-RAD72-RM327.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	MUSS-RAD72-RM327.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	MUSS-RAD72-RM327.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	MUSS-RAD72-RM327.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	MUSS-RAD72-RM327.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	MUSS-RAD72-RM327.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	MUSS-RAD72-RM327.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	MUSS-RAD72-RM327.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	MUSS-RAD72-RM327.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	MUSS-RAD72-RM327.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton	MUSS-RAD72-	MUSS-RAD72-RM327.RAD.HTG-	BFM		0:5	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/3rd Floor	RM327	VLV / close				
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD72-RM327	Heating Plant Broadcast	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	MUSS-RAD72-RM327.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	MUSS-RAD72-RM327.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD72-RM327	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	MUSS-RAD73-RM326.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	MUSS-RAD73-RM326.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	MUSS-RAD73-RM326.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	MUSS-RAD73-RM326.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	MUSS-RAD73-RM326.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	MUSS-RAD73-RM326.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	MUSS-RAD73-RM326.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	MUSS-RAD73-RM326.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	MUSS-RAD73-RM326.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	MUSS-RAD73-RM326.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	MUSS-RAD73-RM326.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	MUSS-RAD73-RM326.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	MUSS-RAD73-RM326.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	MUSS-RAD73-RM326.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd	MUSS-RAD73-RM326	MUSS-RAD73-RM326.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD73-RM326	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	MUSS-RAD74-RM325.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	MUSS-RAD74-RM325.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	MUSS-RAD74-RM325.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	MUSS-RAD74-RM325.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	MUSS-RAD74-RM325.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	MUSS-RAD74-RM325.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	MUSS-RAD74-RM325.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	MUSS-RAD74-RM325.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	MUSS-RAD74-RM325.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton	MUSS-RAD74-	MUSS-RAD74-RM325.RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/3rd Floor	RM325					
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	MUSS-RAD74-RM325.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	MUSS-RAD74-RM325.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	MUSS-RAD74-RM325.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD74-RM325	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	MUSS-RAD74-RM325.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	MUSS-RAD74-RM325.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD74-RM325	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	MUSS-RAD75-RM324.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	MUSS-RAD75-RM324.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	MUSS-RAD75-RM324.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	MUSS-RAD75-RM324.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	MUSS-RAD75-RM324.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	MUSS-RAD75-RM324.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	MUSS-RAD75-RM324.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	MUSS-RAD75-RM324.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	MUSS-RAD75-RM324.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	MUSS-RAD75-RM324.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	MUSS-RAD75-RM324.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	MUSS-RAD75-RM324.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	MUSS-RAD75-RM324.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser	MUSS-RAD75-RM324	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75- RM324	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75- RM324	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75- RM324	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75- RM324	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75- RM324	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75- RM324	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75- RM324	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75- RM324	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75- RM324	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75- RM324	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd	MUSS-RAD75- RM324	MUSS-RAD75-RM324.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	MUSS-RAD75-RM324.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD75-RM324	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	MUSS-RAD76-RM323.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	MUSS-RAD76-RM323.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	MUSS-RAD76-RM323.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	MUSS-RAD76-RM323.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	MUSS-RAD76-RM323.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	MUSS-RAD76-RM323.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton	MUSS-RAD76-	MUSS-RAD76-RM323.RMT-STP /	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/3rd Floor	RM323	Heating Setpoint Adjust				
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	MUSS-RAD76-RM323.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	MUSS-RAD76-RM323.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	MUSS-RAD76-RM323.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	MUSS-RAD76-RM323.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	MUSS-RAD76-RM323.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	MUSS-RAD76-RM323.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD76-RM323	RPCT	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/3rd Floor						
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	MUSS-RAD76-RM323.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	MUSS-RAD76-RM323.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/3rd Floor	MUSS-RAD76-RM323	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	MUSS-RAD77-RM422.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	MUSS-RAD77-RM422.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	MUSS-RAD77-RM422.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	MUSS-RAD77-RM422.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	MUSS-RAD77-RM422.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	MUSS-RAD77-RM422.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	MUSS-RAD77-RM422.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	MUSS-RAD77-RM422.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	MUSS-RAD77-RM422.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	MUSS-RAD77-RM422.RMT	ASVI			
/Carleton College/Musser	MUSS-RAD77-RM422	MUSS-RAD77-RM422.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	MUSS-RAD77-RM422.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	MUSS-RAD77-RM422.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	MUSS-RAD77-RM422.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	MUSS-RAD77-RM422.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD77-RM422	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	MUSS-RAD78-RM421.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	MUSS-RAD78-RM421.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	MUSS-RAD78-RM421.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton	MUSS-RAD78-	MUSS-RAD78-RM421.RMT-STP /	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/4th Floor	RM421	Cooling Unoccupied Setpoint				
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	MUSS-RAD78-RM421.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	MUSS-RAD78-RM421.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	MUSS-RAD78-RM421.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	MUSS-RAD78-RM421.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	MUSS-RAD78-RM421.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	MUSS-RAD78-RM421.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	MUSS-RAD78-RM421.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	MUSS-RAD78-RM421.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	MUSS-RAD78-RM421.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	Active Zone	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD78-RM421	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	MUSS-RAD78-RM421.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	MUSS-RAD78-RM421.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD78-RM421	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	MUSS-RAD79-RM420.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	MUSS-RAD79-RM420.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	MUSS-RAD79-RM420.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	MUSS-RAD79-RM420.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	MUSS-RAD79-RM420.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	MUSS-RAD79-RM420.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	MUSS-RAD79-RM420.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	MUSS-RAD79-RM420.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	MUSS-RAD79-RM420.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	MUSS-RAD79-RM420.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	MUSS-RAD79-RM420.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	MUSS-RAD79-RM420.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	MUSS-RAD79-RM420.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79-RM420	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79- RM420	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79- RM420	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79- RM420	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79- RM420	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79- RM420	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79- RM420	MUSS-RAD79-RM420.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79- RM420	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79- RM420	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79- RM420	MUSS-RAD79-RM420.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79- RM420	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD79- RM420	OAT	ANI			
/Carleton	MUSS-RAD80-	MUSS-RAD80-RM419.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/4th Floor	RM419					
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	MUSS-RAD80-RM419.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	MUSS-RAD80-RM419.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	MUSS-RAD80-RM419.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	MUSS-RAD80-RM419.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	MUSS-RAD80-RM419.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	MUSS-RAD80-RM419.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	MUSS-RAD80-RM419.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	MUSS-RAD80-RM419.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	MUSS-RAD80-RM419.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	MUSS-RAD80-RM419.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility	MUSS-RAD80-RM419	MUSS-RAD80-RM419.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	MUSS-RAD80-RM419.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	MUSS-RAD80-RM419.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	MUSS-RAD80-RM419.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD80-RM419	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	MUSS-RAD81-RM418.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	MUSS-RAD81-RM418.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	MUSS-RAD81-RM418.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	MUSS-RAD81-RM418.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	MUSS-RAD81-RM418.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	MUSS-RAD81-RM418.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	MUSS-RAD81-RM418.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	MUSS-RAD81-RM418.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	MUSS-RAD81-RM418.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	MUSS-RAD81-RM418.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	MUSS-RAD81-RM418.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	MUSS-RAD81-RM418.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	MUSS-RAD81-RM418.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81- RM418	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81- RM418	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81- RM418	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81- RM418	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81- RM418	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81- RM418	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81- RM418	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81- RM418	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81- RM418	MUSS-RAD81-RM418.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81- RM418	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81- RM418	LO Zone Alarm	BALM			
/Carleton	MUSS-RAD81-	MUSS-RAD81-RM418.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/4th Floor	RM418					
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD81-RM418	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	MUSS-RAD82-RM417.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	MUSS-RAD82-RM417.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	MUSS-RAD82-RM417.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	MUSS-RAD82-RM417.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	MUSS-RAD82-RM417.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	MUSS-RAD82-RM417.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	MUSS-RAD82-RM417.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	MUSS-RAD82-RM417.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD82-RM417	MUSS-RAD82-RM417.RMT-STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	MUSS-RAD82-RM417.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	MUSS-RAD82-RM417.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	MUSS-RAD82-RM417.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	MUSS-RAD82-RM417.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	MUSS-RAD82-RM417.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	MUSS-RAD82-RM417.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD82-RM417	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	MUSS-RAD83-RM416.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	MUSS-RAD83-RM416.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	MUSS-RAD83-RM416.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	MUSS-RAD83-RM416.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	MUSS-RAD83-RM416.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	MUSS-RAD83-RM416.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	MUSS-RAD83-RM416.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	MUSS-RAD83-RM416.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	MUSS-RAD83-RM416.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	MUSS-RAD83-RM416.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	MUSS-RAD83-RM416.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	MUSS-RAD83-RM416.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	MUSS-RAD83-RM416.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	Heating Plant Broadcast	BBV			
/Carleton	MUSS-RAD83-	MUSS-RAD83-RM416.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/4th Floor	RM416					
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	MUSS-RAD83-RM416.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD83-RM416	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	MUSS-RAD84-RM415.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	MUSS-RAD84-RM415.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	MUSS-RAD84-RM415.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	MUSS-RAD84-RM415.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	MUSS-RAD84-RM415.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD84-RM415	MUSS-RAD84-RM415.RMT-STP / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	MUSS-RAD84-RM415.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	MUSS-RAD84-RM415.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	MUSS-RAD84-RM415.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	MUSS-RAD84-RM415.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	MUSS-RAD84-RM415.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	MUSS-RAD84-RM415.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	MUSS-RAD84-RM415.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	MUSS-RAD84-RM415.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	MUSS-RAD84-RM415.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD84-RM415	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	MUSS-RAD85-RM414.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	MUSS-RAD85-RM414.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	MUSS-RAD85-RM414.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	MUSS-RAD85-RM414.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	MUSS-RAD85-RM414.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	MUSS-RAD85-RM414.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	MUSS-RAD85-RM414.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	MUSS-RAD85-RM414.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	MUSS-RAD85-RM414.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th	MUSS-RAD85-RM414	MUSS-RAD85-RM414.RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	MUSS-RAD85-RM414.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	MUSS-RAD85-RM414.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	MUSS-RAD85-RM414.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	Zone EI Total Weight	BAV			
/Carleton	MUSS-RAD85-	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/4th Floor	RM414					
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	MUSS-RAD85-RM414.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	MUSS-RAD85-RM414.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD85-RM414	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86-RM413	MUSS-RAD86-RM413.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86-RM413	MUSS-RAD86-RM413.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD86-RM413	MUSS-RAD86-RM413.RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86-RM413	MUSS-RAD86-RM413.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86-RM413	MUSS-RAD86-RM413.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86-RM413	MUSS-RAD86-RM413.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86-RM413	MUSS-RAD86-RM413.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86-RM413	MUSS-RAD86-RM413.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86-RM413	MUSS-RAD86-RM413.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86-RM413	MUSS-RAD86-RM413.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86-RM413	MUSS-RAD86-RM413.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86-RM413	MUSS-RAD86-RM413.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86-RM413	MUSS-RAD86-RM413.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86-RM413	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86- RM413	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86- RM413	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86- RM413	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86- RM413	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86- RM413	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86- RM413	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86- RM413	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86- RM413	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86- RM413	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86- RM413	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86- RM413	MUSS-RAD86-RM413.OCC	BBV			
/Carleton College/Musser	MUSS-RAD86- RM413	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86-RM413	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86-RM413	MUSS-RAD86-RM413.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86-RM413	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD86-RM413	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	MUSS-RAD87-RM411.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	MUSS-RAD87-RM411.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	MUSS-RAD87-RM411.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	MUSS-RAD87-RM411.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	MUSS-RAD87-RM411.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	MUSS-RAD87-RM411.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	MUSS-RAD87-RM411.RMT-STP / Heating Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	MUSS-RAD87-RM411.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	MUSS-RAD87-RM411.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	MUSS-RAD87-RM411.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	MUSS-RAD87-RM411.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	MUSS-RAD87-RM411.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	MUSS-RAD87-RM411.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	RPCT	BAV			
/Carleton	MUSS-RAD87-	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/4th Floor	RM411					
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	MUSS-RAD87-RM411.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	MUSS-RAD87-RM411.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD87-RM411	Demand	ANI			
/Carleton College/Musser Hall/Facility	MUSS-RAD87-RM411	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	MUSS-RAD88-RM410.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	MUSS-RAD88-RM410.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	MUSS-RAD88-RM410.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	MUSS-RAD88-RM410.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	MUSS-RAD88-RM410.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	MUSS-RAD88-RM410.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	MUSS-RAD88-RM410.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	MUSS-RAD88-RM410.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	MUSS-RAD88-RM410.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	MUSS-RAD88-RM410.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	MUSS-RAD88-RM410.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	MUSS-RAD88-RM410.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	MUSS-RAD88-RM410.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	MUSS-RAD88-RM410.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	MUSS-RAD88-RM410.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD88-RM410	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	MUSS-RAD89-RM409.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	MUSS-RAD89-RM409.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	MUSS-RAD89-RM409.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th	MUSS-RAD89-RM409	MUSS-RAD89-RM409.RMT-STP / Cooling Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	MUSS-RAD89-RM409.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	MUSS-RAD89-RM409.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	MUSS-RAD89-RM409.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	MUSS-RAD89-RM409.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	MUSS-RAD89-RM409.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	MUSS-RAD89-RM409.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	MUSS-RAD89-RM409.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	MUSS-RAD89-RM409.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	MUSS-RAD89-RM409.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	EI Weighting	BAV			
/Carleton	MUSS-RAD89-	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/4th Floor	RM409					
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	MUSS-RAD89-RM409.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility	MUSS-RAD89-RM409	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	MUSS-RAD89-RM409.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD89-RM409	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	MUSS-RAD90-RM408.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	MUSS-RAD90-RM408.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	MUSS-RAD90-RM408.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	MUSS-RAD90-RM408.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	MUSS-RAD90-RM408.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	MUSS-RAD90-RM408.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	MUSS-RAD90-RM408.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	MUSS-RAD90-RM408.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	MUSS-RAD90-RM408.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	MUSS-RAD90-RM408.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	MUSS-RAD90-RM408.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	MUSS-RAD90-RM408.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	MUSS-RAD90-RM408.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	MUSS-RAD90-RM408.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	MUSS-RAD90-RM408.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD90-RM408	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th	MUSS-RAD91-RM407	MUSS-RAD91-RM407.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	MUSS-RAD91-RM407.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	MUSS-RAD91-RM407.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	MUSS-RAD91-RM407.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	MUSS-RAD91-RM407.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	MUSS-RAD91-RM407.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	MUSS-RAD91-RM407.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	MUSS-RAD91-RM407.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	MUSS-RAD91-RM407.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	MUSS-RAD91-RM407.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	MUSS-RAD91-RM407.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	MUSS-RAD91-RM407.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton	MUSS-RAD91-	MUSS-RAD91-RM407.RAD.HTG-	BFM		0:5	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/4th Floor	RM407	VLV / close				
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD91-RM407	Heating Plant Broadcast	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	MUSS-RAD91-RM407.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	MUSS-RAD91-RM407.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD91-RM407	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	MUSS-RAD92-RM406.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	MUSS-RAD92-RM406.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	MUSS-RAD92-RM406.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	MUSS-RAD92-RM406.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	MUSS-RAD92-RM406.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	MUSS-RAD92-RM406.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	MUSS-RAD92-RM406.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	MUSS-RAD92-RM406.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	MUSS-RAD92-RM406.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	MUSS-RAD92-RM406.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	MUSS-RAD92-RM406.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	MUSS-RAD92-RM406.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	MUSS-RAD92-RM406.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92- RM406	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92- RM406	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92- RM406	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92- RM406	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92- RM406	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92- RM406	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92- RM406	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92- RM406	MUSS-RAD92-RM406.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92- RM406	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92- RM406	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th	MUSS-RAD92- RM406	MUSS-RAD92-RM406.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD92-RM406	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	MUSS-RAD93-RM405.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	MUSS-RAD93-RM405.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	MUSS-RAD93-RM405.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	MUSS-RAD93-RM405.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	MUSS-RAD93-RM405.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	MUSS-RAD93-RM405.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	MUSS-RAD93-RM405.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	MUSS-RAD93-RM405.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	MUSS-RAD93-RM405.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton	MUSS-RAD93-	MUSS-RAD93-RM405.RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/4th Floor	RM405					
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	MUSS-RAD93-RM405.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	MUSS-RAD93-RM405.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	MUSS-RAD93-RM405.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD93-RM405	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	MUSS-RAD93-RM405.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	MUSS-RAD93-RM405.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD93-RM405	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	MUSS-RAD94-RM404.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	MUSS-RAD94-RM404.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	MUSS-RAD94-RM404.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	MUSS-RAD94-RM404.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	MUSS-RAD94-RM404.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	MUSS-RAD94-RM404.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	MUSS-RAD94-RM404.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	MUSS-RAD94-RM404.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	MUSS-RAD94-RM404.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	MUSS-RAD94-RM404.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	MUSS-RAD94-RM404.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	MUSS-RAD94-RM404.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	MUSS-RAD94-RM404.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser	MUSS-RAD94-RM404	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th	MUSS-RAD94-RM404	MUSS-RAD94-RM404.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	MUSS-RAD94-RM404.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD94-RM404	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	MUSS-RAD95-RM403.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	MUSS-RAD95-RM403.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	MUSS-RAD95-RM403.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	MUSS-RAD95-RM403.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	MUSS-RAD95-RM403.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	MUSS-RAD95-RM403.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton	MUSS-RAD95-	MUSS-RAD95-RM403.RMT-STP /	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/4th Floor	RM403	Heating Setpoint Adjust				
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	MUSS-RAD95-RM403.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	MUSS-RAD95-RM403.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	MUSS-RAD95-RM403.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	MUSS-RAD95-RM403.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	MUSS-RAD95-RM403.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	MUSS-RAD95-RM403.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD95-RM403	RPCT	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	MUSS-RAD95-RM403.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	MUSS-RAD95-RM403.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD95-RM403	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	MUSS-RAD96-RM402.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	MUSS-RAD96-RM402.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	MUSS-RAD96-RM402.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	MUSS-RAD96-RM402.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	MUSS-RAD96-RM402.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	MUSS-RAD96-RM402.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	MUSS-RAD96-RM402.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	MUSS-RAD96-RM402.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	MUSS-RAD96-RM402.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	MUSS-RAD96-RM402.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	MUSS-RAD96-RM402.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	MUSS-RAD96-RM402.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	MUSS-RAD96-RM402.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	MUSS-RAD96-RM402.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	MUSS-RAD96-RM402.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD96-RM402	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	MUSS-RAD97-RM401.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	MUSS-RAD97-RM401.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	MUSS-RAD97-RM401.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton	MUSS-RAD97-	MUSS-RAD97-RM401.RMT-STP /	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/4th Floor	RM401	Cooling Unoccupied Setpoint				
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	MUSS-RAD97-RM401.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	MUSS-RAD97-RM401.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	MUSS-RAD97-RM401.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	MUSS-RAD97-RM401.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	MUSS-RAD97-RM401.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	MUSS-RAD97-RM401.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	MUSS-RAD97-RM401.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	MUSS-RAD97-RM401.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	MUSS-RAD97-RM401.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	Active Zone	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD97-RM401	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	MUSS-RAD97-RM401.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	MUSS-RAD97-RM401.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD97-RM401	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	MUSS-RAD98-RM428.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	MUSS-RAD98-RM428.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	MUSS-RAD98-RM428.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	MUSS-RAD98-RM428.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	MUSS-RAD98-RM428.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	MUSS-RAD98-RM428.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	MUSS-RAD98-RM428.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	MUSS-RAD98-RM428.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	MUSS-RAD98-RM428.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	MUSS-RAD98-RM428.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	MUSS-RAD98-RM428.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	MUSS-RAD98-RM428.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	MUSS-RAD98-RM428.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	MUSS-RAD98-RM428.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	MUSS-RAD98-RM428.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD98-RM428	OAT	ANI			
/Carleton	MUSS-RAD99-	MUSS-RAD99-RM427.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/4th Floor	RM427					
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	MUSS-RAD99-RM427.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	MUSS-RAD99-RM427.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	MUSS-RAD99-RM427.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	MUSS-RAD99-RM427.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	MUSS-RAD99-RM427.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	MUSS-RAD99-RM427.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	MUSS-RAD99-RM427.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	MUSS-RAD99-RM427.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	MUSS-RAD99-RM427.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	MUSS-RAD99-RM427.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility	MUSS-RAD99-RM427	MUSS-RAD99-RM427.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	MUSS-RAD99-RM427.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	MUSS-RAD99-RM427.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	MUSS-RAD99-RM427.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD99-RM427	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	MUSS-RAD100-RM426.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	MUSS-RAD100-RM426.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	MUSS-RAD100-RM426.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	MUSS-RAD100-RM426.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	MUSS-RAD100-RM426.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	MUSS-RAD100-RM426.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	MUSS-RAD100-RM426.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	MUSS-RAD100-RM426.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	MUSS-RAD100-RM426.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	MUSS-RAD100-RM426.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	MUSS-RAD100-RM426.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	MUSS-RAD100-RM426.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	MUSS-RAD100-RM426.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100- RM426	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100- RM426	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100- RM426	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100- RM426	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100- RM426	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100- RM426	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100- RM426	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100- RM426	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100- RM426	MUSS-RAD100-RM426.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100- RM426	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100- RM426	LO Zone Alarm	BALM			
/Carleton	MUSS-RAD100-	MUSS-RAD100-RM426.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/4th Floor	RM426					
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD100-RM426	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	MUSS-RAD101-RM425.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	MUSS-RAD101-RM425.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	MUSS-RAD101-RM425.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	MUSS-RAD101-RM425.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	MUSS-RAD101-RM425.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	MUSS-RAD101-RM425.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	MUSS-RAD101-RM425.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	MUSS-RAD101-RM425.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD101-RM425	MUSS-RAD101-RM425.RMT-STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	MUSS-RAD101-RM425.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	MUSS-RAD101-RM425.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	MUSS-RAD101-RM425.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	MUSS-RAD101-RM425.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	MUSS-RAD101-RM425.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	MUSS-RAD101-RM425.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD101-RM425	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	MUSS-RAD102-RM424.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	MUSS-RAD102-RM424.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	MUSS-RAD102-RM424.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	MUSS-RAD102-RM424.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	MUSS-RAD102-RM424.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	MUSS-RAD102-RM424.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	MUSS-RAD102-RM424.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	MUSS-RAD102-RM424.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	MUSS-RAD102-RM424.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	MUSS-RAD102-RM424.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	MUSS-RAD102-RM424.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	MUSS-RAD102-RM424.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th	MUSS-RAD102-RM424	MUSS-RAD102-RM424.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	Heating Plant Broadcast	BBV			
/Carleton	MUSS-RAD102-	MUSS-RAD102-RM424.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/4th Floor	RM424					
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	MUSS-RAD102-RM424.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD102-RM424	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	MUSS-RAD103-RM423.RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	MUSS-RAD103-RM423.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	MUSS-RAD103-RM423.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	MUSS-RAD103-RM423.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	MUSS-RAD103-RM423.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-RAD103-RM423	MUSS-RAD103-RM423.RMT-STP / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	MUSS-RAD103-RM423.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	MUSS-RAD103-RM423.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	MUSS-RAD103-RM423.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	MUSS-RAD103-RM423.RMT	ASVI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	MUSS-RAD103-RM423.RAD.HTG-VLV	BFM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	MUSS-RAD103-RM423.RAD.HTG-VLV / open	BFM		0:4	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	MUSS-RAD103-RM423.RAD.HTG-VLV / close	BFM		0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	RPCT	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	Heating Plant Broadcast	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	MUSS-RAD103-RM423.OCC	BBV			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	MUSS-RAD103-RM423.MODE	ANI			
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/4th Floor						
/Carleton College/Musser Hall/Facility Summary/4th Floor	MUSS-RAD103-RM423	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.RMT-1st-Floor	BAI	0	1:3	Thermistor
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.RMT-2nd-Floor	BAI	0	1:4	Thermistor
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.RMT-3rd-Floor	BAI	0	1:5	Thermistor
/Carleton	MUSS-ERU1	MUSS-ERU1.RMT-4th-Floor	BAI	0	1:6	Thermistor

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/Roof						
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.CLG-DAT	BAI	0	0:7	Thermistor
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.CLG-INLET-DAT	BAI	0	0:6	Thermistor
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.DAT	BAI	0	0:5	Thermistor
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.FILT-EA-STAT	BAI	0	0:11	0-20 mA
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.HTG-VLV4-STAT	BAI	0	1:8	0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Heat Recover Exhaust Air Temp	BAI	0	0:9	Thermistor
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Heat Recover Inlet Air Temp	BAI	0	0:8	Thermistor
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.FILT-OA-STAT	BAI	0	0:10	0-20 mA
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.HTG-VLV1-STAT	BAI	0	1:7	0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.RA-SMK	BBI	normal	1:1	Dry Contact
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.EF1-STAT	BBI	normal	0:2	Dry Contact
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.ERW-STAT	BBI	normal	0:3	Dry Contact
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.FRZ	BBI	normal	0:6	Dry Contact
/Carleton College/Musser	MUSS-ERU1	MUSS-ERU1.P5-STAT	BBI	normal	0:4	Dry Contact

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Roof						
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Static Safety	BBI	reversed	1:2	Dry Contact
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.SF1-STAT	BBI	normal	0:1	Dry Contact
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.CLG-VLV1	BAO	0	1:5	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.EA-DMPR	BAO	0	1:7	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.ERW-VFD	BAO	0	1:3	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.HTG-VLV4	BAO	0	1:4	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.OA-DMPR1	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.OA-DMPR2	BAO	0	1:8	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.HTG-VLV1	BAO	0	1:6	Electrical 0-10 Volt
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.CHWR-VLV6	BBO	reversed	0:2	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.CHWS-VLV5	BBO	reversed	0:3	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.EF1-SS	BBO	normal	0:7	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU.SF2-SS	BBO	normal	0:6	Relay / Triac Output
/Carleton College/Musser Hall/Facility	MUSS-ERU1	MUSS-ERU1.HTGWR-VLV3	BBO	normal	0:4	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Roof						
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.P5-SS	BBO	normal	0:5	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU.SF1-SS	BBO	normal	0:8	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.RMT-1st-Floor	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.RMT-2nd-Floor	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.RMT-3rd-Floor	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.RMT-4th-Floor	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.MODE	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Average Corridor Space Temp	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	COOLING RUNFOR TIME	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	HEATING RUNFOR TIME	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.HTG-VLV4-STAT	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.HTG-VLV1-STAT	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	COOLING REQUEST	BBV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	HEATING REQUEST	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.SYS-EN	BBV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.RA-SMK	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	EA Dirty Filter Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Exhaust Fan Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Exhaust Fan Hand Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Exhaust Fan Runtime Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Heat Recovery Wheel Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Heat Recovery Wheel Hand Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Heat Recovery Wheel Runtime Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	CHAP-ERU1.DAT-HL	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	HI DAT Shutdown	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	CHAP-ERU1.DAT-LL	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	LO DAT Shutdown	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Low Temp Status Alarm	BALM			
/Carleton	MUSS-ERU1	Low Temp Stat Warning	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/Roof						
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.FILT-OA-STAT	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.P5-ALM	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	P-5 Hand Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	P-5 Runtime Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	CHAP-ERU1.StaticSafety-ALM	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.SF-ALM	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Supply Fan Hand Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Supply Fan Runtime Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Cool Available	BNI			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Heat Available	BNI			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	MUSS-ERU1.OAH	ANI			
/Carleton College/Musser	MUSS-ERU1	Cooling Coil Valve PID Loop	BPID			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Roof						
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Cooling Coil Valve PID Loop / Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Cooling Coil Valve PID Loop / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Cooling Coil Valve PID Loop / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	ERW Discharge Temp PID	BPID			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	ERW Discharge Temp PID / Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	ERW Discharge Temp PID / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	ERW Discharge Temp PID / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Heating Valve Freeze/Smoke/Static Active PID Loop	BPID			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Heating Valve Freeze/Smoke/Static Active PID Loop / Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Heating Valve Freeze/Smoke/Static Active PID Loop / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Heating Valve Freeze/Smoke/Static Active PID Loop / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Heating Valve PID Loop	BPID			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Heating Valve PID Loop / Setpoint	BAV			
/Carleton College/Musser Hall/Facility	MUSS-ERU1	Heating Valve PID Loop / Input	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Roof						
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Heating Valve PID Loop / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Reheat Valve Freeze/Smoke/Static Active PID Loop	BPID			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Reheat Valve Freeze/Smoke/Static Active PID Loop / Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Reheat Valve Freeze/Smoke/Static Active PID Loop / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Reheat Valve Freeze/Smoke/Static Active PID Loop / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Reheat Valve PID Loop	BPID			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Reheat Valve PID Loop / Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Reheat Valve PID Loop / Input	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-ERU1	Reheat Valve PID Loop / PID out	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1- RMROOF	MUSS-UH1-RMROOF/RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1- RMROOF	MUSS-UH1-RMROOF/RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1- RMROOF	MUSS-UH1-RMROOF/RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1- RMROOF	MUSS-UH1-RMROOF/RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1- RMROOF	MUSS-UH1-RMROOF/RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	MUSS-UH1-RMROOF/RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	MUSS-UH1-RMROOF/RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	MUSS-UH1-RMROOF/RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	MUSS-UH1-RMROOF/RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	MUSS-UH1-RMROOF.RMT	BAI	0	0:1	Thermistor
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	MUSS-UH1-RMROOF.HTG-VLV	BBO	normal	0:1	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	Zone Environmental Index	BAV			
/Carleton	MUSS-UH1-	Zone Weighted Environmental	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary/Roof	RMROOF	Index				
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	schedule	BBV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	Heat Available	BNI			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-UH1-RMROOF	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1-RMROOF	MUSS-CUH1-RMROOF/RMT-STP	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1-RMROOF	MUSS-CUH1-RMROOF/RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1-RMROOF	MUSS-CUH1-RMROOF/RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1-RMROOF	MUSS-CUH1-RMROOF/RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1-RMROOF	MUSS-CUH1-RMROOF/RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1-RMROOF	MUSS-CUH1-RMROOF/RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1-RMROOF	MUSS-CUH1-RMROOF/RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Musser	MUSS-CUH1-RMROOF	MUSS-CUH1-RMROOF/RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary/Roof						
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1- RMROOF	MUSS-CUH1-RMROOF/RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1- RMROOF	MUSS-CUH1-RMROOF.RMT	BAI	0	0:1	Thermistor
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1- RMROOF	MUSS-CUH1-RMROOF.HTG-VLV	BBO	normal	0:1	Relay / Triac Output
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1- RMROOF	Active Zone	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1- RMROOF	EI Weighting	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1- RMROOF	Environmental Index Count	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1- RMROOF	HEAT RUN FOR	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1- RMROOF	RUN REQ	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1- RMROOF	Zone EI Time Satisfied	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1- RMROOF	Zone EI Total Weight	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1- RMROOF	Zone Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1- RMROOF	Zone Weighted Environmental Index	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1- RMROOF	schedule	BBV			
/Carleton College/Musser Hall/Facility	MUSS-CUH1- RMROOF	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Roof						
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1- RMROOF	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1- RMROOF	Demand	ANI			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1- RMROOF	Heat Available	BNI			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-CUH1- RMROOF	OAT	ANI			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-Stairwell- Monitoring	Setpoint	BSPTCS			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-Stairwell- Monitoring	Setpoint / Cooling Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-Stairwell- Monitoring	Setpoint / Heating Occupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-Stairwell- Monitoring	Setpoint / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-Stairwell- Monitoring	Setpoint / Heating Unoccupied Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-Stairwell- Monitoring	Setpoint / Cooling Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-Stairwell- Monitoring	Setpoint / Heating Setpoint Adjust	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-Stairwell- Monitoring	Setpoint / Effective Cooling Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-Stairwell- Monitoring	Setpoint / Effective Heating Setpoint	BAV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-Stairwell- Monitoring	Zone Temp	BAI	0	1:15	Thermistor

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-Stairwell-Monitoring	Fan Status	BBI	normal	1:14	Dry Contact
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-Stairwell-Monitoring	schedule	BBV			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-Stairwell-Monitoring	HI Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary/Roof	MUSS-Stairwell-Monitoring	LO Zone Alarm	BALM			
/Carleton College/Musser Hall/Facility Summary	MUSS-Outside-Air-Conditions	OA HUMIDITY	BAI	0	1:10	0-20 mA
/Carleton College/Musser Hall/Facility Summary	MUSS-Outside-Air-Conditions	OA TEMPERATURE	BAI	0	1:9	0-20 mA
/Carleton College/Musser Hall/Facility Summary	MUSS-Outside-Air-Conditions	Outdoor CO2 Level	BAI	0	1:13	0-10 Volt
/Carleton College/Musser Hall/Facility Summary	MUSS-Outside-Air-Conditions	Wind Direction	BAI	0	1:12	0-20 mA
/Carleton College/Musser Hall/Facility Summary	MUSS-Outside-Air-Conditions	Wind Speed m/s	BAI	0	1:11	0-20 mA
/Carleton College/Musser Hall/Facility Summary	MUSS-Outside-Air-Conditions	OA CO2	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Outside-Air-Conditions	OA ENTHALPY	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Outside-Air-Conditions	OA HUMIDITY	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Outside-Air-Conditions	OA TEMPERATURE	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Outside-Air-Conditions	winddreg	BAV			
/Carleton	MUSS-Outside-	windspd	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary	Air-Conditions					
/Carleton College/Musser Hall/Facility Summary	MUSS-Outside-Air-Conditions	winddir	BMSV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Outside-Air-Conditions	HI_CO2	BALM			
/Carleton College/Musser Hall/Facility Summary	MUSS-Outside-Air-Conditions	OA HUMIDITY SENSOR FAIL	BALM			
/Carleton College/Musser Hall/Facility Summary	MUSS-Outside-Air-Conditions	OUTSIDE AIR TEMP SENSOR FAIL	BALM			
/Carleton College/Musser Hall/Facility Summary	MUSS-Outside-Air-Conditions	ALT OAH	ANI			
/Carleton College/Musser Hall/Facility Summary	MUSS-Outside-Air-Conditions	ALT OAT	ANI			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Bldg Steam Condensate Meter Input	BAI	0	0:7	0-20 mA
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Instant Demand	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Peak MTD	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Peak Today	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Peak YTD	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Prev Day Peak Dmnd	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Prev Day Usage	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Prev Month Peak	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary						
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Prev Month Usage	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Prev Year Peak	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Prev Year Usage	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Usage MTD	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Usage Today	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Usage YTD	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Use Every Minute	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Use Every Minute	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Use Every Minute	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	IN_FAIL	BALM			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Daily Use Write	ANO2			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Monthly Use Write	ANO2			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Steam-Meter	Yearly Use Write	ANO2			
/Carleton College/Musser Hall/Facility	MUSS-Building-Electric-Meter	Meter Input	BPTA		0:1	Counter Input

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary						
/Carleton College/Musser Hall/Facility Summary	MUSS-Building- Electric-Meter	Energy Peak Synchronization	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building- Electric-Meter	Energy Use Synchronization	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building- Electric-Meter	Instant Demand	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building- Electric-Meter	Peak MTD	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building- Electric-Meter	Peak Today	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building- Electric-Meter	Peak YTD	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building- Electric-Meter	Prev Day Peak Dmnd	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building- Electric-Meter	Prev Day Usage	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building- Electric-Meter	Prev Month Peak	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building- Electric-Meter	Prev Month Usage	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building- Electric-Meter	Prev Year Peak	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building- Electric-Meter	Prev Year Usage	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building- Electric-Meter	Usage MTD	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building- Electric-Meter	Usage Today	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Electric-Meter	Usage YTD	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Electric-Meter	Use Every Minute	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Electric-Meter	Use Every Minute	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Electric-Meter	Use Every Minute	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Electric-Meter	IN_FAIL	BALM			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Electric-Meter	Daily Use Write	ANO2			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Electric-Meter	Energy Peak Synch	ANO2			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Electric-Meter	Energy Use Synch	ANO2			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Electric-Meter	Monthly Use Write	ANO2			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Electric-Meter	Yearly Use Write	ANO2			
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic-Water-Flow-Rate-Meter	Flow Rate-1	BPTA		0:1	Dry Contact
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic-Water-Flow-Rate-Meter	Flow Rate-2	BPTA		0:2	Dry Contact
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic-Water-Flow-Rate-Meter	Instant Demand	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic-Water-Flow-Rate-Meter	Peak MTD	BAV			
/Carleton	MUSS-Domestic-	Peak Today	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Musser Hall/Facility Summary	Water-Flow-Rate- Meter					
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic- Water-Flow-Rate- Meter	Peak YTD	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic- Water-Flow-Rate- Meter	Prev Day Peak Dmnd	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic- Water-Flow-Rate- Meter	Prev Day Usage	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic- Water-Flow-Rate- Meter	Prev Month Peak	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic- Water-Flow-Rate- Meter	Prev Month Usage	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic- Water-Flow-Rate- Meter	Prev Year Peak	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic- Water-Flow-Rate- Meter	Prev Year Usage	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic- Water-Flow-Rate- Meter	Usage MTD	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic- Water-Flow-Rate- Meter	Usage Today	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic- Water-Flow-Rate- Meter	Usage YTD	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic- Water-Flow-Rate- Meter	Use Every Minute	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic- Water-Flow-Rate- Meter	Use Every Minute	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic- Water-Flow-Rate- Meter	Use Every Minute	BAV			
/Carleton College/Musser	MUSS-Domestic- Water-Flow-Rate-	Daily Use Write	ANO2			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Hall/Facility Summary	Meter					
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic-Water-Flow-Rate-Meter	Monthly Use Write	ANO2			
/Carleton College/Musser Hall/Facility Summary	MUSS-Domestic-Water-Flow-Rate-Meter	Yearly Use Write	ANO2			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	CHW Flow Rate Meter	BAI	0	0:7	0-20 mA
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Instant Demand	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Peak MTD	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Peak Today	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Peak YTD	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Prev Day Peak Dmnd	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Prev Day Usage	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Prev Month Peak	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Prev Month Usage	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Prev Year Peak	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Prev Year Usage	BAV			
/Carleton College/Musser Hall/Facility	MUSS-Building-Chilled-Water-Meter	Usage MTD	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary						
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Usage Today	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Usage YTD	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Use Every Minute	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Use Every Minute	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Use Every Minute	BAV			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Daily Use Write	ANO2			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Monthly Use Write	ANO2			
/Carleton College/Musser Hall/Facility Summary	MUSS-Building-Chilled-Water-Meter	Yearly Use Write	ANO2			