

Point List

Location: Carleton College / Skinner Memorial Chapel

Run Date: 10/10/2018 5:15:16 PM

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Active Zones	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Max Zones	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Runtime	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Time Satisfied Limit	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Total Percent	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Weighted Environmental Index	BAV			
/Carleton	Skinner Chapel	Zone Occ Limit	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Total Area Rollup					
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Environmental Index Occupancy Status	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Status	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	EI_LOW	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Active Zones #1	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Active Zones #2	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Active Zones #3	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Active Zones #4	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Active Zones #5	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Active Zones #6	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
mental Index						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Max Zones #1	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Max Zones #2	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Max Zones #3	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Max Zones #4	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Max Zones #5	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Max Zones #6	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Weighted EI #1	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Weighted EI #3	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Weighted EI #4	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Environmental Index						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Weighted EI #5	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Weighted EI #6	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Weights #1	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Weights #2	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Weights #3	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Weights #4	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Weights #5	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Skinner Chapel Total Area Rollup	Weights #6	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Active Zones	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environ mental Index	Basement Area Rollup	EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environ mental Index	Basement Area Rollup	Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environ mental Index	Basement Area Rollup	Max Zones	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environ mental Index	Basement Area Rollup	Runtime	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environ mental Index	Basement Area Rollup	Time Satisfied Limit	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environ mental Index	Basement Area Rollup	Total Percent	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environ mental Index	Basement Area Rollup	Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environ mental Index	Basement Area Rollup	Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environ mental Index	Basement Area Rollup	Zone Occ Limit	BAV			
/Carleton College/Skinner Memorial	Basement Area Rollup	Environmental Index Occupancy Status	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Environmental Index						
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Status	BBV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	EI_LOW	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Active Zones #1	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Active Zones #2	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Active Zones #3	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Active Zones #4	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Active Zones #5	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Active Zones #6	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Max Zones #1	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Max Zones #2	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Max Zones #3	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Max Zones #4	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Max Zones #5	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Max Zones #6	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Weighted EI #1	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Weighted EI #3	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Weighted EI #4	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility	Basement Area Rollup	Weighted EI #5	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Environmental Index						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Weighted EI #6	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Weights #1	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Weights #2	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Weights #3	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Weights #4	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Weights #5	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Basement Area Rollup	Weights #6	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Active Zones	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	EI Time Satisfied	BAV			
/Carleton	Main Floor Area	Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Rollup					
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Max Zones	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Runtime	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Time Satisfied Limit	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Total Percent	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Zone Occ Limit	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Environmental Index Occupancy Status	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Status	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
mental Index						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	EI_LOW	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Active Zones #1	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Active Zones #2	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Active Zones #3	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Active Zones #4	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Active Zones #5	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Active Zones #6	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Max Zones #1	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Max Zones #2	POLLTOT			
/Carleton College/Skinner	Main Floor Area Rollup	Max Zones #3	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Environmental Index						
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Max Zones #4	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Max Zones #5	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Max Zones #6	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Weighted EI #1	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Weighted EI #3	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Weighted EI #4	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Weighted EI #5	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Weighted EI #6	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Weights #1	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Weights #2	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Weights #3	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Weights #4	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Weights #5	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Main Floor Area Rollup	Weights #6	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Active Zones	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Environmental Index	BAV			
/Carleton College/Skinner Memorial	Balcony Area Rollup	Max Zones	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Environmental Index						
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Runtime	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Time Satisfied Limit	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Total Percent	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Total Weight	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Weighted Environmental Index	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Zone Occ Limit	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Environmental Index Occupancy Status	BBV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Status	BBV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	EI_LOW	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Active Zones #1	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Active Zones #2	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Active Zones #3	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Active Zones #4	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Active Zones #5	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Active Zones #6	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Max Zones #1	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Max Zones #2	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Max Zones #3	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility	Balcony Area Rollup	Max Zones #4	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Environmental Index						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Max Zones #5	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Max Zones #6	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Weighted EI #1	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Weighted EI #2	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Weighted EI #3	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Weighted EI #4	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Weighted EI #5	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Weighted EI #6	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Weights #1	POLLTOT			
/Carleton	Balcony Area	Weights #2	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Rollup					
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Weights #3	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Weights #4	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Weights #5	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Environmental Index	Balcony Area Rollup	Weights #6	POLLTOT			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	CHAP-HWS.HWPS	BAI	0	0:16	0-10 Volt
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	CHAP-HWS.PLHX	BAI	0	0:14	0-20 mA
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	CHAP-HWS.HWDP	BAI	0	0:5	0-20 mA
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	CHAP-HWS.HWRT	BAI	0	0:4	Thermistor
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	CHAP-HWS.HWSP	BAI	0	0:3	Thermistor

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	CHAP-HWS.HWP1-STAT	BAI	0	0:1	0-20 mA
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	CHAP-HWS.HWP2-STAT	BAI	0	0:2	0-20 mA
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	CHAP-HWS.HWSP	BAI	0	0:15	0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	CHAP-HWS.HWS.HX-VLV11	BAO	0	0:6	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	CHAP-HWS.HWS.HX-VLV13	BAO	0	0:5	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	CHAP-HWS.BVM	BAO	0	0:4	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	CHAP-HWS.HWP1-VFD	BAO	0	0:3	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	CHAP-HWS.HWP2-VFD	BAO	0	0:2	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	CHAP-HWS.HWP1-SS	BBO	normal	0:5	Relay / Triac Output
/Carleton College/Skinner	CHAP-HX1	CHAP-HWS.HWP2-SS	BBO	normal	0:4	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	Makeup WTR Fill Valve (V-14) (NOT USED)	BBO	normal	0:6	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	Runtime swap time	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	Heat Active	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	Schedule	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	CHAP-HWS.HWP-ROT	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	Fill Valve Runtime Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HI Campus HPS Steam Prs	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HI DIFFP	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HI Gauge Wtr Prs Leaving HX	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HI HW Loop Return Temp Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HI HW Loop Supply Temp Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HI Skinner Chapel LPS Steam Prs	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HWP-1 Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HWP-1 Hand Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HWP-1 Runtime Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HWP-2 Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HWP-2 Hand Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HWP-2 Runtime Alarm	BALM			
/Carleton College/Skinner Memorial	CHAP-HX1	LO Campus HPS Steam Prs	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	Lockout Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	LO DIFFP	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	LO Gauge Wtr Prs Leaving HX	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	LO HW Loop Return Temp Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	LO HW Loop Supply Temp Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	LO Skinner Chapel LPS Steam Prs	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	Standby Pump Enabled alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HREQ1	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HREQ2	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HREQ3	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	CHAP-HWS.OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	Bypass Valve Modulation PID	BPID			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	Bypass Valve Modulation PID / Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	Bypass Valve Modulation PID / Input	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	Bypass Valve Modulation PID / PID out	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	Convertor Valve PID	BPID			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	Convertor Valve PID / Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	Convertor Valve PID / Input	BAV			
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-HX1	Convertor Valve PID / PID out	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HW Differential Pressure PID	BPID			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HW Differential Pressure PID / Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HW Differential Pressure PID / Input	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-HX1	HW Differential Pressure PID / PID out	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.FILT-STAT	BAI	0	0:5	0-20 mA
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.DAT	BAI	0	0:4	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.SASP1	BAI	0	0:8	0-20 mA
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.SASP2	BAI	0	0:9	0-20 mA
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.SASP3	BAI	0	0:10	0-20 mA
/Carleton	CHAP-AHU1	CHAP-AHU1.MAT	BAI	0	0:3	Thermistor

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skiner Memorial Chapel/Facility Summary/Basement						
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.OA-DMPR-STAT	BAI	0	0:11	0-10 Volt
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.RA-DMPR-STAT	BAI	0	0:12	0-10 Volt
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Not used	BAI	0	0:0	0-20 mA
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.RE-DMPR-STAT	BAI	0	0:13	0-10 Volt
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.RAT	BAI	0	0:2	Thermistor
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.RACO2-LEVEL	BAI	0	0:16	0-10 Volt
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.SF1-STAT	BAI	-0.5	0:1	0-20 mA
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	SCOV-AHU1.P-1-STAT	BBI	normal	0:14	Dry Contact
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.RA-SMK	BBI	normal	0:7	Dry Contact

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.FRZ	BBI	reversed	0:6	Dry Contact
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.CLG-VLV1	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.HTG-VLV1	BAO	0	0:2	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.OA-DMPR	BAO	0	0:5	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.RA-DMPR	BAO	0	0:4	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.RE-DMPR	BAO	0	0:3	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.SF1-VFD	BAO	0	0:6	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.HTGP-CIRC-SS	BBO	normal	0:5	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.SF1-SS	BBO	normal	0:6	Relay / Triac Output
/Carleton College/Skinner	CHAP-AHU1	CHAP-AHU1.ENABLE	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Basement						
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	COOLING RUNFOR TIME	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	HEATING RUNFOR TIME	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Outside CO2 Level (CO2)	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.CO2-LEVEL	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Space CO2	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	COOLING REQUEST	BBV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	HEATING REQUEST	BBV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Circulation Pump Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Circulation Pump Hand Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Circulation Pump Runtime Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.FILT-STAT	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.RA-SMK	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	HI CO2 Diff	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.DAT-HL	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	HI DAT Shutdown	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.SASP1-HL	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.MAT-HL	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	HI RAH Alarm	BALM			
/Carleton College/Skinner Memorial	CHAP-AHU1	CHAP-AHU1.RAT-HL	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	HI Space CO2	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	LO CO2 Diff	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.DAT-LL	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	LO DAT Shutdown	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.SASP1-LL	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.MAT-LL	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	LO RAH Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.RAT-LL	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Low Temp Status Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Low Temp Stat Warning	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.SF-ALM	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Supply Fan Hand Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Supply Fan Runtime Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	AIRREQUESTS1	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	AIRREQUESTS2	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	AIRREQUESTS3	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	AIRREQUESTS4	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	AIRREQUESTS5	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-AHU1	AIRREQUESTS6	POLLTOT			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CLREQUESTS1	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CLREQUESTS2	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CLREQUESTS3	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Cool Available	BNI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Heat Available	BNI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	HTREQUESTS1	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	HTREQUESTS2	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	HTREQUESTS3	POLLTOT			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	CHAP-AHU1.OAT	ANI			
/Carleton	CHAP-AHU1	Outside Air Enthalpy	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skinner Memorial Chapel/Facility Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Outside CO2 Level	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Return CO2 Level (AHU-2)	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	RUNFORTIME1	POLLMAX			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	RUNFORTIME2	POLLMAX			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	RUNFORTIME3	POLLMAX			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Cooling Coil Valve PID Loop	BPID			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Cooling Coil Valve PID Loop / Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Cooling Coil Valve PID Loop / Input	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Cooling Coil Valve PID Loop / PID out	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Economizer OA/RA PID	BPID			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Economizer OA/RA PID / Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Economizer OA/RA PID / Input	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Economizer OA/RA PID / PID out	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Heating Valve PID Loop	BPID			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Heating Valve PID Loop / Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Heating Valve PID Loop / Input	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Heating Valve PID Loop / PID out	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Supply Duct Static Pressure Control PID	BPID			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Supply Duct Static Pressure Control PID / CHAP-AHU1.SASP-	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Basement		STP				
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Supply Duct Static Pressure Control PID / Input	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1	Supply Duct Static Pressure Control PID / PID out	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.STP / Heating Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.STP / Effective Heating Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.RMT-CENTER	BAI	0	0:7	0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.FILT-STAT	BAI	0	0:4	0-20 mA
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.DAT	BAI	0	0:3	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.RMT-EAST08	BAI	0	0:6	0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.RAT	BAI	0	0:2	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.RACO2-LEVEL	BAI	0	0:10	0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.SF-STAT	BAI	-0.9	0:1	0-20 mA
/Carleton College/Skinner Memorial	CHAP-AHU2	CHAP-AHU2.RMT-WEST07	BAI	0	0:5	0-10 Volt

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.HTG-VLV1	BAO	0	0:3	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.HTG-RAD1	BAO	0	0:2	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.SF-VFD	BAO	0	0:4	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.SF1-SS	BBO	normal	0:6	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.RMT-CENTER06	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	COOL RUN FOR	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.RMT-EAST11	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	HEAT RUN FOR	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Outside CO2 Level (CO2)	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	RETURN CO2	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	RUN REQ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Space CO2 Level (CO2)	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	VAV Cooling % output	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.RMT-EAST10	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	AHU-2 ON	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Event Mode Schedule	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Night Setback Cooling	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.FILT-STAT	BALM			
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-AHU2	HI_CO2	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	HI CO2 Diff	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	HI DAT Shutdown	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	HI RAT ALARM	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	LO CO2 Diff	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	LO DAT Shutdown	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	LO RAT ALARM	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.SF-ALM	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Supply Fan Hand Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Supply Fan Runtime Alarm	BALM			
/Carleton	CHAP-AHU2	CHAP-AHU2.ENABLE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skinner Memorial Chapel/Facility Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Event Mode	BNI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	CHAP-AHU2.OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Outside CO2 Level	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Space CO2 Level (AHU-1)	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Supply Fan Cooling PID	BPID			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Supply Fan Cooling PID / Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Supply Fan Cooling PID / Input	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Supply Fan Cooling PID / PID out	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	VAV % Out PID	BPID			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	VAV % Out PID / Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	VAV % Out PID / Input	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	VAV % Out PID / PID out	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Heating Valve PID Loop	BPID			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Heating Valve PID Loop / Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Heating Valve PID Loop / Input	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Heating Valve PID Loop / PID out	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Radiation Heating Valve PID Loop	BPID			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Radiation Heating Valve PID Loop / Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Radiation Heating Valve PID Loop / Input	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU2	Radiation Heating Valve PID Loop / PID out	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.RMT-STP / SCOV-FC11-RM11.C-ADJ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.RMT-STP / SCOV-FC11-RM11.W-ADJ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.RMT-STP / SCOV-FC11-RM11.EFF-CLG-RMT-STP	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.RMT-STP / SCOV-FC11-RM11.EFF-HTG-RMT-STP	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.DAT	BAI	0	0:1	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.RMT	ASVI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.CLG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.SS	BBO	normal	0:5	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.RAD.HTG-VLV	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.RAD.HTG-VLV / open	BFM		0:3	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.RAD.HTG-VLV / close	BFM		0:4	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	Active Zone	BAV			
/Carleton College/Skinner Memorial	CHAP-FC11-RM11	El Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	HI DAT ALARM	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	HI DAT Shutdown	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	LO DAT ALARM	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	LO DAT Shutdown	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	Low Temp Status Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	LO Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	Supply Fan Runtime Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.CLG.DEMAND	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	Heat Available	BNI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	CHAP-FC11-RM11.HTG.DEMAND	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-FC11-RM11	Cooling Coil Valve PID Loop	BPID			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	Cooling Coil Valve PID Loop / Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	Cooling Coil Valve PID Loop / Input	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC11-RM11	Cooling Coil Valve PID Loop / PID out	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.RMT-STP / SCOV-FC15-RM15.C-ADJ	BAV			
/Carleton	CHAP-FC15-	CHAP-FC15-RM15.RMT-STP /	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skinner Memorial Chapel/Facility Summary/Basement	RM15	SCOV-FC15-RM15.W-ADJ				
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.RMT-STP / SCOV-FC15-RM15.EFF-CLG-RMT-STP	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.RMT-STP / SCOV-FC15-RM15.EFF-HTG-RMT-STP	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.DAT	BAI	0	0:1	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.RMT	ASVI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.CLG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.SS	BBO	normal	0:5	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.RAD.HTG-VLV	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.RAD.HTG-VLV / open	BFM		0:3	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.RAD.HTG-VLV / close	BFM		0:4	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	HI DAT ALARM	BALM			
/Carleton College/Skinner	CHAP-FC15-RM15	HI DAT Shutdown	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Basement						
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	HI Zone Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	LO DAT ALARM	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	LO DAT Shutdown	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	Low Temp Status Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	LO Zone Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	Supply Fan Runtime Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.CLG.DEMAND	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	Heat Available	BNI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	CHAP-FC15-RM15.HTG.DEMAND	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	Cooling Coil Valve PID Loop	BPID			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	Cooling Coil Valve PID Loop / Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	Cooling Coil Valve PID Loop / Input	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-FC15-RM15	Cooling Coil Valve PID Loop / PID out	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	CHAP-AHU1-VAV17 .SA-CFM-STP	BAF			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	CHAP-AHU1-VAV17 .SA-CFM-STP / CHAP-AHU1-VAV17.SA-CFM	BAI	0	0:1	Flow Input
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	CHAP-AHU1-VAV17 .RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	CHAP-AHU1-VAV17 .RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial	CHAP-AHU1-VAV17	CHAP-AHU1-VAV17 .RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	CHAP-AHU1-VAV17 .RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	CHAP-AHU1-VAV17 .RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	CHAP-AHU1-VAV17 .RMT-STP / SCOV-AHU1-VAV17C-ADJ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	CHAP-AHU1-VAV17 .RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	CHAP-AHU1-VAV17 .RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	CHAP-AHU1-VAV17 .RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	CHAP-AHU1-VAV17 .DAT	BAI	0	0:1	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	CHAP-AHU1-VAV17 .RMT	ASVI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	Not Used	BAO	0	0:0	Electrical 0-10 Volt

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	CHAP-AHU1-VAV17 .HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	Not Used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	Not Used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	CHAP-AHU1-VAV17 .CLG.DEMAND	BAV			
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-AHU1-VAV17	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	HEAT RUN FOR	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	RUN REQ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	Airflow Request	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	CHAP-AHU1-VAV17 .OCC	BBV			
/Carleton	CHAP-AHU1-	Zone CO2	BMSV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skiner Memorial Chapel/Facility Summary/Basement	VAV17					
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	ZONE HUMIDITY	BMSV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	HI DAT Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	HI Zone Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	LO DAT Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	LO Zone Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	CHAP-AHU1-VAV17 .MODE	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	Demand	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV17	OAT	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	CHAP-AHU1-VAV43 .SA-CFM-STP	BAF			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	CHAP-AHU1-VAV43 .SA-CFM-STP / CHAP-AHU1-VAV43.SA-CFM	BAI	0	0:1	Flow Input
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	CHAP-AHU1-VAV43 .RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	CHAP-AHU1-VAV43 .RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	CHAP-AHU1-VAV43 .RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	CHAP-AHU1-VAV43 .RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	CHAP-AHU1-VAV43 .RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	CHAP-AHU1-VAV43 .RMT-STP / SCOV-AHU1-VAV43.C-ADJ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	CHAP-AHU1-VAV43 .RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	CHAP-AHU1-VAV43 .RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	CHAP-AHU1-VAV43 .RMT-STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	CHAP-AHU1-VAV43 .DAT	BAI	0	0:1	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	CHAP-AHU1-VAV43 .RMT	ASVI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	Not Used	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	CHAP-AHU1-VAV43 .HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	Not Used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	Not Used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	Not Used / open	BFM		0:0	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	CHAP-AHU1-VAV43 .CLG.DEMAND	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	HEAT RUN FOR	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	RUN REQ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial	CHAP-AHU1-VAV43	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	Airflow Request	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	CHAP-AHU1-VAV43 .OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	Zone CO2	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	ZONE HUMIDITY	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	HI DAT Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	HI Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	LO DAT Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	CHAP-AHU1-VAV43 .MODE	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	Demand	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV43	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	CHAP-AHU1-VAV45 .SA-CFM-STP	BAF			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	CHAP-AHU1-VAV45 .SA-CFM-STP / CHAP-AHU1-VAV45.SA-CFM	BAI	0	0:1	Flow Input
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	CHAP-AHU1-VAV45 .RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	CHAP-AHU1-VAV45 .RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	CHAP-AHU1-VAV45 .RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	CHAP-AHU1-VAV45 .RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-AHU1-VAV45	CHAP-AHU1-VAV45 .RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	CHAP-AHU1-VAV45 .RMT-STP / SCOV-AHU1-VAV45.C-ADJ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	CHAP-AHU1-VAV45 .RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	CHAP-AHU1-VAV45 .RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	CHAP-AHU1-VAV45 .RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	CHAP-AHU1-VAV45 .DAT	BAI	0	0:1	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	CHAP-AHU1-VAV45 .RMT	ASVI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	Not Used	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	CHAP-AHU1-VAV45 .HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	Not Used	BFM			
/Carleton	CHAP-AHU1-	Not Used / open	BFM		0:0	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skinner Memorial Chapel/Facility Summary/Basement	VAV45					
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	Not Used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	CHAP-AHU1-VAV45 .CLG.DEMAND	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	RUN REQ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	Airflow Request	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	CHAP-AHU1-VAV45 .OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	Zone CO2	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	ZONE HUMIDITY	BMSV			
/Carleton College/Skinner	CHAP-AHU1-VAV45	HI DAT Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Basement						
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	HI Zone Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	LO DAT Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	LO Zone Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	CHAP-AHU1-VAV45 .MODE	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	Demand	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV45	OAT	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	CHAP-AHU1-VAV51 .SA-CFM-STP	BAF			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	CHAP-AHU1-VAV51 .SA-CFM-STP / CHAP-AHU1-VAV51.SA-CFM	BAI	0	0:1	Flow Input
/Carleton College/Skiner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	CHAP-AHU1-VAV51 .RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	CHAP-AHU1-VAV51 .RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	CHAP-AHU1-VAV51 .RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	CHAP-AHU1-VAV51 .RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	CHAP-AHU1-VAV51 .RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	CHAP-AHU1-VAV51 .RMT-STP / SCOV-AHU1-VAV51.C-ADJ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	CHAP-AHU1-VAV51 .RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	CHAP-AHU1-VAV51 .RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	CHAP-AHU1-VAV51 .RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	CHAP-AHU1-VAV51 .DAT	BAI	0	0:1	Thermistor
/Carleton College/Skinner Memorial	CHAP-AHU1-VAV51	CHAP-AHU1-VAV51 .RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	Not Used	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	CHAP-AHU1-VAV51 .HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	Not Used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	Not Used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	Active Zone	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	CHAP-AHU1-VAV51 .CLG.DEMAND	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	HEAT RUN FOR	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	RUN REQ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-AHU1-VAV51	Airflow Request	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	CHAP-AHU1-VAV51 .OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	Zone CO2	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	ZONE HUMIDITY	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	HI DAT Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	HI Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	LO DAT Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	LO Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	CHAP-AHU1-VAV51 .MODE	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV51	Demand	ANI			
/Carleton	CHAP-AHU1-	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skinner Memorial Chapel/Facility Summary/Basement	VAV51					
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	CHAP-AHU1-VAV54 .SA-CFM-STP	BAF			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	CHAP-AHU1-VAV54 .SA-CFM-STP / CHAP-AHU1-VAV54.SA-CFM	BAI	0	0:1	Flow Input
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	CHAP-AHU1-VAV54 .RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	CHAP-AHU1-VAV54 .RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	CHAP-AHU1-VAV54 .RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	CHAP-AHU1-VAV54 .RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	CHAP-AHU1-VAV54 .RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	CHAP-AHU1-VAV54 .RMT-STP / SCOV-AHU1-VAV54.C-ADJ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	CHAP-AHU1-VAV54 .RMT-STP / Heating Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	CHAP-AHU1-VAV54 .RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	CHAP-AHU1-VAV54 .RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	CHAP-AHU1-VAV54 .DAT	BAI	0	0:1	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	CHAP-AHU1-VAV54 .RMT	ASVI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	Not Used	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	CHAP-AHU1-VAV54 .HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	Not Used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner	CHAP-AHU1-VAV54	Not Used	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	CHAP-AHU1-VAV54 .CLG.DEMAND	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	HEAT RUN FOR	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	RUN REQ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	Airflow Request	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	CHAP-AHU1-VAV54 .OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	Zone CO2	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	ZONE HUMIDITY	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	HI DAT Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	HI Zone Alarm	BALM			
/Carleton College/Skinner Memorial	CHAP-AHU1-VAV54	LO DAT Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	LO Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	CHAP-AHU1-VAV54 .MODE	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	Demand	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-AHU1-VAV54	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	CHAP-RAD18-RM18.RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	CHAP-RAD18-RM18.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	CHAP-RAD18-RM18.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	CHAP-RAD18-RM18.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	CHAP-RAD18-RM18.RMT-STP / Heating Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	CHAP-RAD18-RM18.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	CHAP-RAD18-RM18.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	CHAP-RAD18-RM18.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	CHAP-RAD18-RM18.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	not used	BAI	0	0:0	0-5 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	not used	BAI	0	0:0	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	CHAP-RAD18-RM18.RMT	ASVI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	CHAP-RAD18-RM18.RAD.HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	Not Used	BBO	normal	0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-RAD18-RM18	Not Used	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	HEAT RUN FOR	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	RUN REQ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	Zone EI Total Weight	BAV			
/Carleton	CHAP-RAD18-	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skinner Memorial Chapel/Facility Summary/Basement	RM18					
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	CHAP-RAD18-RM18.OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	HI Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	LO Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	RH Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	ZT Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	CHAP-RAD18-RM18.MODE	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	Demand	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD18-RM18	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
ent						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	CHAP-RAD16-RM16.RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	CHAP-RAD16-RM16.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	CHAP-RAD16-RM16.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	CHAP-RAD16-RM16.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	CHAP-RAD16-RM16.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	CHAP-RAD16-RM16.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	CHAP-RAD16-RM16.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	CHAP-RAD16-RM16.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	CHAP-RAD16-RM16.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Skinner	CHAP-RAD16-RM16	East Organ Attic RH	BAI	0	0:1	0-5 Volt

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	East Organ Attic ZT	BAI	0	0:2	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	CHAP-RAD16-RM16.RMT	ASVI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	CHAP-RAD16-RM16.RAD.HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	Not Used	BBO	normal	0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	Not Used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	HEAT RUN FOR	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	RUN REQ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	CHAP-RAD16-RM16.OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	HI Zone Alarm	BALM			
/Carleton College/Skinner Memorial	CHAP-RAD16-RM16	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Basement						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	RH Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	ZT Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	CHAP-RAD16-RM16.MODE	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	Demand	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Basement	CHAP-RAD16-RM16	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	CHAP-FC111-RM111.RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	CHAP-FC111-RM111.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	CHAP-FC111-RM111.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	CHAP-FC111-RM111.RMT-STP / Cooling Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	CHAP-FC111-RM111.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	CHAP-FC111-RM111.RMT-STP / SCOV-FC111-RM11.C-ADJ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	CHAP-FC111-RM111.RMT-STP / SCOV-FC111-RM11.W-ADJ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	CHAP-FC111-RM111.RMT-STP / SCOV-FC111-RM111.EFF-CLG-RMT-STP	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	CHAP-FC111-RM111.RMT-STP / SCOV-FC111-RM111.EFF-HTG-RMT-STP	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	CHAP-FC111-RM111.DAT	BAI	0	0:1	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	CHAP-FC111-RM111.RMT	ASVI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	CHAP-FC111-RM111.CLG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	CHAP-FC111-RM111.SS	BBO	normal	0:5	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-FC111-RM111	CHAP-FC111-RM111.RAD.HTG-VLV	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	CHAP-FC111-RM111.RAD.HTG-VLV / open	BFM		0:3	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	CHAP-FC111-RM111.RAD.HTG-VLV / close	BFM		0:4	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	Zone Weighted Environmental Index	BAV			
/Carleton	CHAP-FC111-	CHAP-FC111-RM111.OCC	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skinner Memorial Chapel/Facility Summary/Main Floor	RM111					
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	HI DAT ALARM	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	HI DAT Shutdown	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	HI Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	LO DAT ALARM	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	LO DAT Shutdown	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	Low Temp Status Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	LO Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	Supply Fan Runtime Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main	CHAP-FC111-RM111	CHAP-FC111-RM111.CLG.DEMAND	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	Heat Available	BNI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	CHAP-FC111-RM111.HTG.DEMAND	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	Cooling Coil Valve PID Loop	BPID			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	Cooling Coil Valve PID Loop / Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	Cooling Coil Valve PID Loop / Input	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC111-RM111	Cooling Coil Valve PID Loop / PID out	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.RMT-STP / SCOV-FC113-RM113.C-ADJ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.RMT-STP / SCOV-FC113-RM113.W-ADJ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.RMT-STP / SCOV-FC113-RM113.EFF-CLG-RMT-STP	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.RMT-STP / SCOV-FC113-RM113.EFF-HTG-RMT-STP	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.DAT	BAI	0	0:1	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.RMT	ASVI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.CLG-VLV	BAO	0	0:1	Electrical 0-10 Volt

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.SS	BBO	normal	0:5	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.RAD.HTG-VLV	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.RAD.HTG-VLV / open	BFM		0:3	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.RAD.HTG-VLV / close	BFM		0:4	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial	CHAP-FC113-RM113	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Main Floor						
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	Zone Weighted Environmental Index	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.OCC	BBV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	HI DAT ALARM	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	HI DAT Shutdown	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	HI Zone Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	LO DAT ALARM	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	LO DAT Shutdown	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	Low Temp Status Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	Supply Fan Runtime Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.CLG.DEMAND	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	Heat Available	BNI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	CHAP-FC113-RM113.HTG.DEMAND	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	Cooling Coil Valve PID Loop	BPID			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	Cooling Coil Valve PID Loop / Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	Cooling Coil Valve PID Loop / Input	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC113-RM113	Cooling Coil Valve PID Loop / PID out	BAV			
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-EF1-RMWEST	Setpoint	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	Setpoint / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	Setpoint / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	Setpoint / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	Setpoint / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	Setpoint / Cooling Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	Setpoint / Heating Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	Setpoint / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	Setpoint / Effective Heating Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	Not Used	BAI	0	0:0	9
/Carleton	CHAP-EF1-	Not Used	BAI	0	0:0	Thermistor

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skinner Memorial Chapel/Facility Summary/Main Floor	RMWEST					
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	CHAP-EF1-RMWEST.STAT	BBI	normal	0:1	Dry Contact
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	CHAP-EF1-RMWEST.EFF-OCC	BBI	normal	0:2	Dry Contact
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	not used	BBI	normal	0:0	1
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	Not Used	BTLO		0:0	Binary Input
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	CHAP-EF1-RMWE.SS	BBO	normal	0:2	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main	CHAP-EF1-RMWEST	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	EF STATUS	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	Schedule	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	Exhaust Fan System Configuration	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	EF Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	EF Hand Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	EF Runtime Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Main Floor						
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	LO Zone Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	AHU ON	BNI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF1-RMWEST	OAT	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Setpoint	BSPTCS			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Setpoint / Cooling Occupied Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Setpoint / Heating Occupied Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Setpoint / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Setpoint / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Setpoint / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Setpoint / Heating Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Setpoint / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Setpoint / Effective Heating Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Not Used	BAI	0	0:0	9
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Not Used	BAI	0	0:0	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	CHAP-EF1-RMWEST.STAT	BBI	normal	0:1	Dry Contact
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	CHAP-EF2-RMEAST.EFF-OCC	BBI	normal	0:2	Dry Contact
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Not Used	BBI	normal	0:0	1
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Not Used	BTLO		0:0	Binary Input
/Carleton College/Skinner Memorial	CHAP-EF2-RMEAST	CHAP-EF1-RMWE.SS	BBO	normal	0:2	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	EF STATUS	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Schedule	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	Exhaust Fan System Configuration	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	EF Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	EF Hand Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	EF Runtime Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	HI Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	LO Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	AHU ON	BNI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-EF2-RMEAST	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	CHAP-AHU1-VAV121.SA-CFM-STP	BAF			
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-AHU1-VAV121	CHAP-AHU1-VAV121.SA-CFM-STP / CHAP-AHU1-VAV121.SA-CFM	BAI	0	0:1	Flow Input

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	CHAP-AHU1-VAV121 .RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	CHAP-AHU1-VAV121 .RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	CHAP-AHU1-VAV121 .RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	CHAP-AHU1-VAV121 .RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	CHAP-AHU1-VAV121 .RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	CHAP-AHU1-VAV121 .RMT-STP / SCOV-AHU1-VAV121.C-ADJ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	CHAP-AHU1-VAV121 .RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	CHAP-AHU1-VAV121 .RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	CHAP-AHU1-VAV121 .RMT-STP / Effective Heating Setpoint	BAV			
/Carleton	CHAP-AHU1-	CHAP-AHU1-VAV121 .DAT	BAI	0	0:1	Thermistor

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skiner Memorial Chapel/Facility Summary/Main Floor	VAV121					
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	CHAP-AHU1-VAV121 .RMT	ASVI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	Not Used	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	CHAP-AHU1-RMWEST.HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	No Used	BFM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	No Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	No Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	Not Used	BFM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main	CHAP-AHU1-VAV121	Not Used / close	BFM		0:0	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	CHAP-AHU1-VAV121 .CLG.DEMAND	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	HEAT RUN FOR	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	RUN REQ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Main Floor						
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	Airflow Request	BBV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	CHAP-AHU1-VAV121 .OCC	BBV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	Zone CO2	BMSV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	ZONE HUMIDITY	BMSV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	HI DAT Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	HI Zone Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	LO DAT Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	LO Zone Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	CHAP-AHU1-VAV121 .MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	Demand	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV121	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU2-VAV122A	CHAP-AHU2-VAV122A.SA-CFM-STP	BAF			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU2-VAV122A	CHAP-AHU2-VAV122A.SA-CFM-STP / CHAP-AHU2-VAV122A.SA-CFM	BAI	0	0:1	Flow Input
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU2-VAV122A	Airflow Request	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU2-VAV122A	AHU-2 N/S Cooling	BNI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU2-VAV122A	AHU-2 ON	BNI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU2-VAV122A	CHAP-AHU2-VAV122A.MODE	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU2-VAV122A	Cooling % From AHU-2	ANI			
/Carleton College/Skinner Memorial	CHAP-AHU2-VAV122B	CHAP-AHU2-VAV122B.SA-CFM-STP	BAF			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Main Floor						
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU2-VAV122B	CHAP-AHU2-VAV122B.SA-CFM-STP / CHAP-AHU2-VAV122B.SA-CFM	BAI	0	0:1	Flow Input
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU2-VAV122B	Airflow Request	BBV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU2-VAV122B	AHU-2 N/S Cooling	BNI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU2-VAV122B	AHU-2 ON	BNI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU2-VAV122B	CHAP-AHU2-VAV122B.MODE	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU2-VAV122B	Cooling % From AHU-2	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	CHAP-AHU1-VAV123.SA-CFM-STP	BAF			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	CHAP-AHU1-VAV123.SA-CFM-STP / CHAP-AHU1-VAV123.SA-CFM	BAI	0	0:1	Flow Input
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	CHAP-AHU1-VAV123.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	CHAP-AHU1-VAV123 .RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	CHAP-AHU1-VAV123 .RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	CHAP-AHU1-VAV123 .RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	CHAP-AHU1-VAV123 .RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	CHAP-AHU1-VAV123 .RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	CHAP-AHU1-VAV123 .RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	CHAP-AHU1-VAV123 .RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	CHAP-AHU1-VAV123 .RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	CHAP-AHU1-VAV123 .DAT	BAI	0	0:1	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-AHU1-VAV123	CHAP-AHU1-VAV123 .RMT	BAI	0	0:2	0-5 Volt

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	Not Used	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	CHAP-AHU1-VAV123 .HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	Not Used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	Not Used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	Active Zone	BAV			
/Carleton	CHAP-AHU1-	CHAP-AHU1-VAV123	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skiner Memorial Chapel/Facility Summary/Main Floor	VAV123	.CLG.DEMAND				
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	El Weighting	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	Environmental Index Count	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	HEAT RUN FOR	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	RUN REQ	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	Zone El Time Satisfied	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	Zone El Total Weight	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	Zone Environmental Index	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	Zone Weighted Environmental Index	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main	CHAP-AHU1-VAV123	Airflow Request	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	CHAP-AHU1-VAV123 .OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	Zone CO2	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	ZONE HUMIDITY	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	HI DAT Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	HI Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	LO DAT Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	LO Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	CHAP-AHU1-VAV123 .MODE	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	Demand	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV123	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	CHAP-AHU1-VAV152 .SA-CFM-STP	BAF			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	CHAP-AHU1-VAV152 .SA-CFM-STP / CHAP-AHU1-VAV152.SA-CFM	BAI	0	0:1	Flow Input
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	CHAP-AHU1-VAV152 .RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	CHAP-AHU1-VAV152 .RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	CHAP-AHU1-VAV152 .RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	CHAP-AHU1-VAV152 .RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	CHAP-AHU1-VAV152 .RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	CHAP-AHU1-VAV152 .RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	CHAP-AHU1-VAV152 .RMT-STP / Heating Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	CHAP-AHU1-VAV152 .RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	CHAP-AHU1-VAV152 .RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	CHAP-AHU1-VAV152 .DAT	BAI	0	0:1	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	CHAP-AHU1-VAV152 .RMT	BAI	0	0:2	0-5 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	Not Used	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	CHAP-AHU1-VAV152 .HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	Not Used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial	CHAP-AHU1-VAV152	Not Used	BFM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	CHAP-AHU1-VAV152 .CLG.DEMAND	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	HEAT RUN FOR	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	RUN REQ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	Airflow Request	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	CHAP-AHU1-VAV152 .OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	Zone CO2	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	ZONE HUMIDITY	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	HI DAT Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	HI Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-AHU1-VAV152	LO DAT Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	LO Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	CHAP-AHU1-VAV152 .MODE	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	Demand	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV152	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	CHAP-AHU1-VAV156 .SA-CFM-STP	BAF			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	CHAP-AHU1-VAV156 .SA-CFM-STP / CHAP-AHU1-VAV156.SA-CFM	BAI	0	0:1	Flow Input
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	CHAP-AHU1-VAV156 .RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	CHAP-AHU1-VAV156 .RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	CHAP-AHU1-VAV156 .RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton	CHAP-AHU1-	CHAP-AHU1-VAV156 .RMT-STP /	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skinner Memorial Chapel/Facility Summary/Main Floor	VAV156	Cooling Unoccupied Setpoint				
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	CHAP-AHU1-VAV156 .RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	CHAP-AHU1-VAV156 .RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	CHAP-AHU1-VAV156 .RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	CHAP-AHU1-VAV156 .RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	CHAP-AHU1-VAV156 .RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	CHAP-AHU1-VAV156 .DAT	BAI	0	0:1	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	CHAP-AHU1-VAV156 .RMT	BAI	0	0:2	0-5 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	Not Used	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main	CHAP-AHU1-VAV156	CHAP-AHU1-VAV156 .HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	Not Used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	Not Used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	CHAP-AHU1-VAV156 .CLG.DEMAND	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	HEAT RUN FOR	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	RUN REQ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	Airflow Request	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	CHAP-AHU1-VAV156 .OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	Zone CO2	BMSV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	ZONE HUMIDITY	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	HI DAT Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	HI Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	LO DAT Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	LO Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	CHAP-AHU1-VAV156 .MODE	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	Demand	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV156	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.SA-CFM-STP	BAF			
/Carleton College/Skinner Memorial	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.SA-CFM-STP / CHAP-AHU1-VAV154A.SA-CFM	BAI	0	0:1	Flow Input

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.RMT-STP / Effective Heating Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.DAT	BAI	0	0:1	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.RMT	BAI	0	0:2	0-5 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	Not Used	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154 .HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.HTG-VLV	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.HTG-VLV / open	BFM		0:2	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.HTG-VLV / close	BFM		0:1	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.RAD.HTG-VLV	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.RAD.HTG-VLV / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.RAD.HTG-VLV / close	BFM		0:0	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.CLG.DEMAND	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	HEAT RUN FOR	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	RUN REQ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	Zone Environmental Index	BAV			
/Carleton	CHAP-AHU1-	Zone Weighted Environmental	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skinner Memorial Chapel/Facility Summary/Main Floor	VAV154A	Index				
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	Airflow Request	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	Zone CO2	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	ZONE HUMIDITY	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	HI DAT Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	HI Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	LO DAT Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	LO Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main	CHAP-AHU1-VAV154A	CHAP-AHU1-VAV154A.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	Demand	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154A	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.SA-CFM-STP	BAF			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.SA-CFM-STP / CHAP-AHU1-VAV154B.SA-CFM	BAI	0	0:1	Flow Input
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.RMT-STP / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.DAT	BAI	0	0:1	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.RMT	BAI	0	0:2	0-5 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	Not Used	BAO	0	0:0	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B .HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.HTG-VLV	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.HTG-VLV / open	BFM		0:2	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.HTG-VLV / close	BFM		0:1	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.RAD.HTG-VLV	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.RAD.HTG-VLV / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.RAD.HTG-VLV / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.CLG.DEMAND	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	HEAT RUN FOR	BAV			
/Carleton College/Skinner Memorial	CHAP-AHU1-VAV154B	RUN REQ	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	Airflow Request	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	Zone CO2	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	ZONE HUMIDITY	BMSV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	HI DAT Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	HI Zone Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	LO DAT Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	LO Zone Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	CHAP-AHU1-VAV154B.MODE	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	Demand	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-AHU1-VAV154B	OAT	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	CHAP-RAD111A-RM111A.RMT-STP	BSPTCS			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	CHAP-RAD111A-RM111A.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	CHAP-RAD111A-RM111A.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility	CHAP-RAD111A-RM111A	CHAP-RAD111A-RM111A.RMT-STP / Cooling Unoccupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Main Floor						
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	CHAP-RAD111A-RM111A.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	CHAP-RAD111A-RM111A.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	CHAP-RAD111A-RM111A.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	CHAP-RAD111A-RM111A.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	CHAP-RAD111A-RM111A.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	CHAP-RAD111A-RM111A.RMT	ASVI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	CHAP-RAD111A-RM111A.RAD.HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	Not Used	BBO	normal	0:0	Relay / Triac Output
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	Not Used	BFM			
/Carleton	CHAP-RAD111A-	Not Used / open	BFM		0:0	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skinner Memorial Chapel/Facility Summary/Main Floor	RM111A					
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	HEAT RUN FOR	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	RUN REQ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main	CHAP-RAD111A-RM111A	Zone Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	CHAP-RAD111A-RM111A.OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	HI Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	LO Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	CHAP-RAD111A-RM111A.MODE	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	Demand	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD111A-RM111A	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	CHAP-RAD102-RM102.RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	CHAP-RAD102-RM102.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	CHAP-RAD102-RM102.RMT-STP / Heating Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	CHAP-RAD102-RM102.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	CHAP-RAD102-RM102.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	CHAP-RAD102-RM102.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	CHAP-RAD102-RM102.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	CHAP-RAD102-RM102.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	CHAP-RAD102-RM102.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	CHAP-RAD102-RM102.RMT	ASVI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	CHAP-RAD102-RM102.RAD.HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	Not Used	BBO	normal	0:0	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	Not Used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	HEAT RUN FOR	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	RUN REQ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial	CHAP-RAD102-RM102	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	CHAP-RAD102-RM102.OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	HI Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	LO Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	CHAP-RAD102-RM102.MODE	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	Demand	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD102-RM102	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	CHAP-RAD106-RM106.RMT-STP	BSPTCS			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	CHAP-RAD106-RM106.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	CHAP-RAD106-RM106.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	CHAP-RAD106-RM106.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	CHAP-RAD106-RM106.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	CHAP-RAD106-RM106.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	CHAP-RAD106-RM106.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	CHAP-RAD106-RM106.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	CHAP-RAD106-RM106.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	CHAP-RAD106-RM106.RMT	ASVI			
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-RAD106-RM106	CHAP-RAD106-RM106.RAD.HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	Not Used	BBO	normal	0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	Not Used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	HEAT RUN FOR	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	RUN REQ	BAV			
/Carleton	CHAP-RAD106-	Zone EI Time Satisfied	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skinner Memorial Chapel/Facility Summary/Main Floor	RM106					
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	CHAP-RAD106-RM106.OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	HI Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	LO Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	CHAP-RAD106-RM106.MODE	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD106-RM106	Demand	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main	CHAP-RAD106-RM106	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	CHAP-RAD104A-RM104A.RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	CHAP-RAD104A-RM104A.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	CHAP-RAD104A-RM104A.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	CHAP-RAD104A-RM104A.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	CHAP-RAD104A-RM104A.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	CHAP-RAD104A-RM104A.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	CHAP-RAD104A-RM104A.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	CHAP-RAD104A-RM104A.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	CHAP-RAD104A-RM104A.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	CHAP-RAD104A-RM104A.RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	CHAP-RAD104A-RM104A.RAD.HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	Not Used	BBO	normal	0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	Not Used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	Not Used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	Not Used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	HEAT RUN FOR	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	RUN REQ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	CHAP-RAD104A-RM104A.OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	HI Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	LO Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	CHAP-RAD104A-RM104A.MODE	ANI			
/Carleton College/Skinner Memorial	CHAP-RAD104A-RM104A	Demand	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Main Floor						
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD104A-RM104A	OAT	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	CHAP-RAD155-RM155.RMT-STP	BSPTCS			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	CHAP-RAD155-RM155.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	CHAP-RAD155-RM155.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	CHAP-RAD155-RM155.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	CHAP-RAD155-RM155.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	CHAP-RAD155-RM155.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	CHAP-RAD155-RM155.RMT-STP / Heating Setpoint Adjust	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	CHAP-RAD155-RM155.RMT-STP / Effective Cooling Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	CHAP-RAD155-RM155.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	CHAP-RAD155-RM155.RMT	BAI	0	0:2	0-5 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	CHAP-RAD155-RM155.RAD.HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	not used	BBO	normal	0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	not used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	not used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	not used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-RAD155-RM155	Environmental Index Count	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	HEAT RUN FOR	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	RUN REQ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	Zone Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	Zone Weighted Environmental Index	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	CHAP-RAD155-RM155.OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	HI Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	LO Zone Alarm	BALM			
/Carleton	CHAP-RAD155-	CHAP-RAD155-RM155.MODE	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skiner Memorial Chapel/Facility Summary/Main Floor	RM155					
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	Demand	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD155-RM155	OAT	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	CHAP-RAD153-RM153.RMT-STP	BSPTCS			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	CHAP-RAD153-RM153.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	CHAP-RAD153-RM153.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	CHAP-RAD153-RM153.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	CHAP-RAD153-RM153.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	CHAP-RAD153-RM153.RMT-STP / Cooling Setpoint Adjust	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main	CHAP-RAD153-RM153	CHAP-RAD153-RM153.RMT-STP / Heating Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	CHAP-RAD153-RM153.RMT-STP / Effective Cooling Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	CHAP-RAD153-RM153.RMT-STP / Effective Heating Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	CHAP-RAD153-RM153.RMT	BAI	0	0:2	0-5 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	CHAP-RAD153-RM153.RAD.HTG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	not used	BBO	normal	0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	not used	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	not used / open	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	not used / close	BFM		0:0	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	EI Weighting	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Main Floor						
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	Environmental Index Count	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	HEAT RUN FOR	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	RUN REQ	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	Zone EI Time Satisfied	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	Zone EI Total Weight	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	Zone Environmental Index	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	Zone Weighted Environmental Index	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	CHAP-RAD153-RM153.OCC	BBV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	HI Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	LO Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	CHAP-RAD153-RM153.MODE	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	Demand	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-RAD153-RM153	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Setpoint	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Setpoint / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Setpoint / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Setpoint / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Setpoint / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial	CHAP-FC1-RMSTAGE	Setpoint / Cooling Setpoint Adjust	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Main Floor						
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Setpoint / Heating Setpoint Adjust	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Setpoint / Effective Cooling Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Setpoint / Effective Heating Setpoint	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Discharge Temp	BAI	0	0:3	Thermistor
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	West Organ Attic RH	BAI	0	0:2	0-5 Volt
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	West Organ Attic ZT	BAI	0	0:4	Thermistor
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Fan Status	BBI	normal	0:1	Dry Contact
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Cooling Valve	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skiner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Fan Start/Stop	BBO	normal	0:1	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Cooling Run Request	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Cool Request	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Occupancy	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Run	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Schedule	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	DAT_HI	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	DAT_LO	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	FAN_FAIL	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	FAN_HAND	BALM			
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-FC1-RMSTAGE	FAN_RNTM	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Main Floor						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	RH Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	ZTMP_HI	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	ZTMP_LO	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	ZT Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	Demand Level	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Main Floor	CHAP-FC1-RMSTAGE	OA Temp	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	CHAP-FC251-FC251.RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	CHAP-FC251-FC251.RMT-STP / Cooling Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	CHAP-FC251-FC251.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton	CHAP-FC251-	CHAP-FC251-FC251.RMT-STP /	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skinner Memorial Chapel/Facility Summary/Balcony	RM251	Cooling Unoccupied Setpoint				
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	CHAP-FC251-FC251.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	CHAP-FC251-FC251.RMT-STP / SCOV-FC251-RM251.C-ADJ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	CHAP-FC251-FC251.RMT-STP / SCOV-FC251-RM251.W-ADJ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	CHAP-FC251-FC251.RMT-STP / SCOV-FC251-RM251.EFF-CLG-RMT-STP	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	CHAP-FC251-FC251.RMT-STP / SCOV-FC251-RM251.EFF-HTG-RMT-STP	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	CHAP-FC251-FC251.DAT	BAI	0	0:1	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	CHAP-FC251-FC251.RMT	ASVI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	CHAP-FC251-FC251.CLG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	CHAP-FC251-FC251.SS	BBO	normal	0:5	Relay / Triac Output

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
y						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	CHAP-FC251-FC251.RAD.HTG-VLV	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	CHAP-FC251-FC251.RAD.HTG-VLV / open	BFM		0:3	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	CHAP-FC251-FC251.RAD.HTG-VLV / close	BFM		0:4	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	Zone EI Total Weight	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	Zone Environmental Index	BAV			
/Carleton College/Skinner	CHAP-FC251-RM251	Zone Weighted Environmental Index	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary/Balcon y						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcon y	CHAP-FC251- RM251	CHAP-FC251-FC251.OCC	BBV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcon y	CHAP-FC251- RM251	HI DAT ALARM	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcon y	CHAP-FC251- RM251	HI DAT Shutdown	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcon y	CHAP-FC251- RM251	HI Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcon y	CHAP-FC251- RM251	LO DAT ALARM	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcon y	CHAP-FC251- RM251	LO DAT Shutdown	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcon y	CHAP-FC251- RM251	Low Temp Status Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcon y	CHAP-FC251- RM251	LO Zone Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcon y	CHAP-FC251- RM251	Supply Fan Runtime Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	CHAP-FC251-FC251.CLG.DEMAND	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	Heat Available	BNI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	CHAP-FC251-FC251.HTG.DEMAND	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	Cooling Coil Valve PID Loop	BPID			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	Cooling Coil Valve PID Loop / Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	Cooling Coil Valve PID Loop / Input	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC251-RM251	Cooling Coil Valve PID Loop / PID out	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.RMT-STP	BSPTCS			
/Carleton College/Skinner Memorial	CHAP-FC255-RM255	CHAP-FC255-FC255.RMT-STP / Cooling Occupied Setpoint	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary/Balcony						
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.RMT-STP / Heating Occupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.RMT-STP / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.RMT-STP / Heating Unoccupied Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.RMT-STP / SCOV-FC255-RM255.C-ADJ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.RMT-STP / SCOV-FC255-RM255.W-ADJ	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.RMT-STP / SCOV-FC255-RM255.EFF-CLG-RMT-STP	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.RMT-STP / SCOV-FC255-RM255.EFF-HTG-RMT-STP	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.DAT	BAI	0	0:1	Thermistor
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.RMT	ASVI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.CLG-VLV	BAO	0	0:1	Electrical 0-10 Volt
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.SS	BBO	normal	0:5	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.RAD.HTG-VLV	BFM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.RAD.HTG-VLV / open	BFM		0:3	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.RAD.HTG-VLV / close	BFM		0:4	Relay / Triac Output
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	Active Zone	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	EI Weighting	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	Environmental Index Count	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	Zone EI Time Satisfied	BAV			
/Carleton College/Skinner Memorial Chapel/Facility	CHAP-FC255-RM255	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary/Balcony						
/Carleton College/Skiner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	Zone Environmental Index	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	Zone Weighted Environmental Index	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.OCC	BBV			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	HI DAT ALARM	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	HI DAT Shutdown	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	HI Zone Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	LO DAT ALARM	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	LO DAT Shutdown	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	Low Temp Status Alarm	BALM			
/Carleton	CHAP-FC255-	LO Zone Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skinner Memorial Chapel/Facility Summary/Balcony	RM255					
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	Supply Fan Runtime Alarm	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.CLG.DEMAND	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	Heat Available	BNI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	CHAP-FC255-FC255.HTG.DEMAND	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	Cooling Coil Valve PID Loop	BPID			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	Cooling Coil Valve PID Loop / Setpoint	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	Cooling Coil Valve PID Loop / Input	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary/Balcony	CHAP-FC255-RM255	Cooling Coil Valve PID Loop / PID out	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
y						
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-OAC	OA CO2	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-OAC	OA ENTHALPY	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-OAC	OA HUMIDITY	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-OAC	OA TEMPERATURE	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-OAC	HI_CO2	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-OAC	OA HUMIDITY SENSOR FAIL	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-OAC	OUTSIDE AIR TEMP SENSOR FAIL	BALM			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-OAC	OAH	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-OAC	OAT	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-OAC	Outdoor CO2 Level	ANI			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-STM_MTR	City Water Flow Rate Meter	BPTA		0:1	Counter Input
/Carleton	CHAP-STM_MTR	Instant Demand	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skinner Memorial Chapel/Facility Summary						
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Peak MTD	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Peak Today	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Peak YTD	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Prev Day Peak Dmnd	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Prev Day Usage	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Prev Month Peak	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Prev Month Usage	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Prev Year Peak	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Prev Year Usage	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Usage MTD	BAV			
/Carleton College/Skinner Memorial	CHAP-STM_MTR	Usage Today	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary						
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Usage YTD	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Use Every Minute	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Use Every Minute	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Use Every Minute	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Use Every Minute	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Daily Use Write	ANO2			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Monthly Use Write	ANO2			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-STM_MTR	Yearly Use Write	ANO2			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-CITY_WTR_MTR	City Water Flow Rate Meter	BPTA		0:1	Counter Input
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-CITY_WTR_MTR	Instant Demand	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-CITY_WTR_MTR	Peak MTD	BAV			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-CITY_WTR_MTR	Peak Today	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR	Peak YTD	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR	Prev Day Peak Dmnd	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR	Prev Day Usage	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR	Prev Month Peak	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR	Prev Month Usage	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR	Prev Year Peak	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR	Prev Year Usage	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR	Usage MTD	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR	Usage Today	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR	Usage YTD	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR	Use Every Minute	BAV			
/Carleton College/Skinner	CHAP- CITY_WTR_MTR	Use Every Minute	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Memorial Chapel/Facility Summary						
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR	Use Every Minute	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR	Daily Use Write	ANO2			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR	Monthly Use Write	ANO2			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR	Yearly Use Write	ANO2			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR _BTU	CHW BTU/HR	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR _BTU	Instant Demand	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR _BTU	Peak MTD	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR _BTU	Peak Today	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR _BTU	Peak YTD	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR _BTU	Prev Day Peak Dmnd	BAV			
/Carleton College/Skinner Memorial Chapel/Facility	CHAP- CITY_WTR_MTR _BTU	Prev Day Usage	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary						
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR _BTU	Prev Month Peak	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR _BTU	Prev Month Usage	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR _BTU	Prev Year Peak	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR _BTU	Prev Year Usage	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR _BTU	Usage MTD	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR _BTU	Usage Today	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR _BTU	Usage YTD	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR _BTU	Use Every Minute	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR _BTU	Use Every Minute	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR _BTU	Use Every Minute	BAV			
/Carleton College/Skinner Memorial Chapel/Facility Summary	CHAP- CITY_WTR_MTR _BTU	HI CHW Loop Return Temp Alarm	BALM			
/Carleton	CHAP-	HI CHW Loop Supply Temp Alarm	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Skiner Memorial Chapel/Facility Summary	CITY_WTR_MTR_BTU					
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-CITY_WTR_MTR_BTU	LO CHW Loop Return Temp Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-CITY_WTR_MTR_BTU	LO CHW Loop Supply Temp Alarm	BALM			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-CITY_WTR_MTR_BTU	CHW Energy Meter (BTU/HR)	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-CITY_WTR_MTR_BTU	CHW Flow Meter (GPM)	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-CITY_WTR_MTR_BTU	CHW Loop Return Temp	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-CITY_WTR_MTR_BTU	CHW Loop Supply Temp	ANI			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-CITY_WTR_MTR_BTU	Daily Use Write	ANO2			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-CITY_WTR_MTR_BTU	Monthly Use Write	ANO2			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-CITY_WTR_MTR_BTU	Yearly Use Write	ANO2			
/Carleton College/Skiner Memorial Chapel/Facility Summary	CHAP-EVENT_MODE_S SCHEDULE	Event Mode	BBV			
/Carleton College/Skiner Memorial	CHAP-EVENT_MODE_S SCHEDULE	Event Mode Schedule	BBV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Chapel/Facility Summary						