

Point List

Location: Carleton College / Faculty Club & Annex

Run Date: 10/10/2018 5:14:50 PM

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	FACX-LPSB.BLR_FAIL	BBI	reversed	0:3	Dry Contact
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	FACX-LPSB.BLR-STAT	BBI	reversed	0:2	Dry Contact
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	EXT Combustion DAMPER STATUS	BBI	reversed	0:4	Dry Contact
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	INT Combustion DAMPER STATUS	BBI	reversed	0:7	Dry Contact
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	FACX-LPSB.BLR-PANEL-CTRL	BBO	normal	0:6	Relay / Triac Output
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	FACX-LPSB.COMB-DAMP-CTRL	BBO	normal	0:5	Relay / Triac Output
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	Heat Active	BBV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	Schedule	BBV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	BOILER ALARM	BALM			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	BOILER FAILURE ALARM	BALM			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	BOILER HAND ALARM	BALM			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	BOILER RUNTIME ALARM	BALM			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	Combustion DAMPER ALARM	BALM			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	Combustion DAMPER HAND ALARM	BALM			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	HREQ1	POLLTOT			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	HREQ2	POLLTOT			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	HREQ3	POLLTOT			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	OAT	ANI			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	point name	ANI			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	point name	ANI			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	point name	ANI			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	point name	BNI			
/Carleton College/Faculty	FACX-Low-Pres-Steam-Boiler B-1	point name	BNI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Club & Annex/Facility Summary						
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-Low-Pres-Steam-Boiler B-1	point name	BNI			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Setpoint	BSPTCS			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Setpoint / Cooling Occupied Setpoint	BAV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Setpoint / Heating Occupied Setpoint	BAV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Setpoint / Cooling Unoccupied Setpoint	BAV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Setpoint / Heating Unoccupied Setpoint	BAV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Setpoint / Cooling Setpoint Adjust	BAV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Setpoint / Heating Setpoint Adjust	BAV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Setpoint / Effective Cooling Setpoint	BAV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Setpoint / Effective Heating Setpoint	BAV			
/Carleton College/Faculty Club & Annex/Facility	FACX-UH1	FACX-UH1.RMT	BAI	0	0:6	Thermistor

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Summary						
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	FACX-UH1.SF-STAT	BBI	normal	0:5	Dry Contact
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	FACX-UH1.SF-S/S	BBO	normal	0:1	Relay / Triac Output
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	FACX-UH1.HTG-VLV	BFM			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	FACX-UH1.HTG-VLV / open	BFM		0:3	Relay / Triac Output
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	FACX-UH1.HTG-VLV / close	BFM		0:2	Relay / Triac Output
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Active Zone	BAV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	EI Weighting	BAV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Environmental Index Count	BAV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	HEAT RUN FOR	BAV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	RUN REQ	BAV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Zone EI Time Satisfied	BAV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Zone EI Total Weight	BAV			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
College/Faculty Club & Annex/Facility Summary						
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Zone Environmental Index	BAV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Zone Weighted Environmental Index	BAV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	schedule	BBV			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Fan-1 Alarm	BALM			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Fan-1 Hand Alarm	BALM			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Fan-1 Runtime Alarm	BALM			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	HI Zone Alarm	BALM			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	LO Zone Alarm	BALM			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Demand	ANI			
/Carleton College/Faculty Club & Annex/Facility Summary	FACX-UH1	Heat Available	BNI			
/Carleton College/Faculty Club &	FACX-UH1	OAT	ANI			

Location	Control Program	Name	Type	Offset / Polarity	Exp:Num	I/O Type
Annex/Facility Summary						